



Minnesota Pollution Control Agency

520 Lafayette Road
St. Paul, MN 55155-4194

Site: 738 - Junction Oasis ICO #34
1711 Highway 210
Carlton MN 55718

Field Citation Warning

Storage Tank Facility

Inspection # 4

Owner: INTER CITY OIL CO INC
PO Box 3048
Duluth MN 55803
Contact: KELLY JOHNSON

218-728-3641
218-728-3641

This is a Field Citation Warning issued for violations found during a 11/03/2010 inspection. Pursuant to Minn. Stat. 116.073, the Minnesota Pollution Control Agency (MPCA) is required to give you an opportunity to correct the violations before it issues a Field Citation that imposes a penalty for violation of rules governing management of underground storage tanks. If you fail to correct the violations noted below and submit proof to the MPCA that you have done so within 60 days of receipt of this Field Citation Warning, the MPCA will issue you a Field Citation imposing a penalty in the amount listed below.

Rule/Statute	Violation Description	Corrective Action	# Systems	Per Tank/Pipe	Penalty
7150.0215 subp. 1	Cathodic protection not repaired when needed.	Repair cathodic protection system and submit passing results to the MPCA inspector listed below.	5	X \$250.00 =	\$1250.00
					Due Date: 6/1/2011
Subtotal (not to exceed \$2000.00):					\$1250.00

A field citation in the amount of: **\$1250.00** will be assessed if the corrective actions are not completed and sent to the MPCA by the due date.

Notes:

- CP test conducted 6-17-10 failed.
- Rectifier repair and CP retest 8-11-10 failed.
- August 2010 Tanknology submitted bid for groundbed replacement.
- No passing CP test results submitted to the MPCA.

Inspector:

Jeffery Brandon
218-302-6610
jeffery.brandon@state.mn.us
MPCA Duluth Office
525 Lake Avenue South, Suite 400
Duluth MN 55802-