



506 First Avenue NE, Suite 100, Rochester, Minnesota 55906  
(507) 252-0945 • FAX: (507) 288-7592

*attw  
Matt*

### FAX TRANSMITTAL FORM

TO: Joanne Henry DATE: 4-11-97

FROM: Zane Nevada TIME: \_\_\_\_\_

Number of Page (including this page) 3

REMARKS I recently completed the MPCA self compliance audit on behalf of B/F Distributing, Inc. I have summerized all of the changes that need to be made on the MPCA info. sheets. This info was taken directly off of the audit checklists which were reviewed and signed by B/F. Beth Endersbe suggested I send you all of the info instead of filling out the forms for each change needed. Please look over the list and contact us to let us know what further info. you need to update the database.

If there was a problem receiving the fax please call us at (507) 252-0945 THANK YOU!

**MPCA TANK INFORMATION SHEET UPDATES NEEDED FOR B&F  
DISTRIBUTING SITES.**

**La Crescent Gas-N-Go, 304 South 3rd Street, La Crescent**

Show that the site has been placed on SIRAS and change the name of the owner from La Crescent Gas-N-Go to B&F Distributing, Inc. 7172

**Pump-N-Munch, 3601 Noble Avenue North, Robbinsdale**

Show that the site is on SIRAS and that the tanks currently have spill prevention. 11094 1860

**Pump-N-Munch, 318 West Broadway Street, Monticello**

Show that the tanks are lined, and that the piping currently has no form of corrosion protection. 12042

**Petrol Pumper, 4100 Highway 63 South, Rochester**

Show that there currently is an auto line leak detector installed at the site. 4744

**Petrol Pumper, 11650 Courthouse Boulevard, Inver Grove Heights**

Show that the tanks have been updated with spill prevention and overfill protection. 13003

**Pump-N-Munch, 1131 Hilltop Avenue, Mankato**

Show that the site is on SIRAS. 624

**Petrol Pumper, I 90 and Highway 109, Aiden**

Show that the waste oil tank 008 has been removed and that the site has an auto line leak detector. 12849

**Petrol Pumper, 1800 Hoffman Drive, Owatonna**

Show that Jay Clark is the owner of the waste oil tank 007, and that the piping is protected by anodes, and that there is a auto line leak detector at the site. Tanks 9392 ✓

**Pump-N-Munch, 503 South Mantorville Avenue, Kasson**

The tank information sheets for the sites are current.

**Petrol Pumper, I 90 and CO Road 8, Clearwater**

Show that the site is on SIRAS. 94 12032

**Pump-N-Munch North, 2620 North Broadway, Rochester**

Show that the tanks and piping have been upgraded with corrosion protection, an auto line leak detector and spill prevention and overfill protection.

**Pump-N-Munch, 2225 East Main Street, Albert Lea**

Tank information sheets are current.