

7/11/05

Dave Olson 763-245-9579 cell #

~~612-789-4121~~

re Clearwater Truck Stop 7/7/05

612-789-0105

Stop N60 Stone Hpls

- ① Need Not-form for owner change - internet or SS send
- ② Tank leak detect - just entering daily inventory
what going to do & when - SIR, new ATG?
- ③ Piping leak detect - was SIR, need annual MLLD tests
- ④ CP Test for all tanks & lines
- ⑤ Spill buckets - some liquid & debris (rags)
some tilted
is there a bottom to outer ring?

Pumpo-Meter said OK

left message

- ① In process of completing. Had questions + sending to former owner
- ② Checked probes & can do test. Need to repair. Will use ATG

Test lines

He can't understand why SS doesn't go after old owner for test results. He will do what he needs to for this year. He just took over ownership May 20, 2005. Bought from someone he knew

Will call former owner & see what he can get