



Report Title. Tank Site and Owner Information  
**Minnesota Pollution Control Agency**  
**TALES Report**

Report Number 43

*Beppu*

20 February, 2008

**Petrol Pumper**  
**Site ID: 12032**

**Autocare/Autoparts**  
**Type of Site: Underground Only**

12032

Address: ~~I94 & County Road 8 Exit 183  
Clearwater, MN 55380  
County, Wright~~  
Site Phone: ~~NO CORE PL PH~~  
Old Phone: ~~6128781655~~

Region: M  
AST Registration  
UST Registration: 1/29/1986  
Contact Phone

\*\*\*\*\* OWNER INFORMATION \*\*\*\*\*

Owner Name: KATO INC  
Owner ID: ~~-186802~~  
Address: ~~P.O. Box 6758  
Rochester, MN 55903~~

\*\*\*\*\* TANK INFORMATION SUMMARY \*\*\*\*\*

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
002	U	Active	Diesel	20,000	02/10/1976		01/29/1986
003	U	Active	Alcohol Blend	20,000	02/10/1976		01/29/1986
004	U	Active	Alcohol Blend Diesel	10,000	02/10/1976		01/29/1986
005	U	Active	Alcohol Blend	10,000	02/10/1976		01/29/1986
001	U	Removed	Diesel	20,000	02/10/1976	01/01/1988	01/29/1986
006	U	Removed	Diesel	10,000	02/10/1976	12/10/1998	01/29/1986
007	U	Removed	Fuel Oil	10,000	01/01/1900	07/07/1999	06/14/1994
008	U	Removed	Used Or Waste Oil	550	01/01/1900	12/10/1998	06/14/1994

\*\*\*\*\* 002 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr. 002 U	Client Tank Nbr 002
Dispenser Type Submersible	Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Diesel
Used For Heating? U	Tank Status Active
Tank Disposal Company	2nd Cont Tank
Tank Cath Prot Impressed Current	Pipe Cath Prot: Impressed Current
Pipe Material Coated Steel	Piping Material Desc
HW Generator ID:	Product Replaced Date:
Tank Registration Date. 01/29/1986	Unreg Tank Report Date

----- 002 - UST TANK INFORMATION -----

# of Tank Compartments: 1	Compart Capacity: 20000
Compart Number 1	Compart Stored Desc DIESEL
Compart Stored Prod Diesel	
Compart Other Desc	

---- Overfill Information ----

Overfill Prot Alarm  
Overfill Prot Ballfloat Y  
Overfill Prot No Info:  
Overfill Prot Type Unk

Overfill Prot Autoshut:  
Overfill Prot Manual.  
Overfill Prot None:

---- Tank Release Protection ----

Daily Stick *Y*  
Tightness Test *Y*  
Manual Gauging N  
Auto Gauging N *Y*  
Soil Vapor Monitor N  
Groundwater Monitor N  
Interstit Monitor N  
SIR Approve Date 01/01/1999

---- Piping Release Protection ----

Auto Line Leak Detection. Y  
Annual Tightness Test N  
Vapor Monitoring. N  
Groundwater Monitor N  
Interstit Monitor N  
3 Year Tightness Test N  
European Suction. N  
SIR Approve Date 01/01/1999



Petrol Pumper  
Site ID: 12032

Autocare/Autoparts  
Type of Site: Underground Only

SIR Vendor Nbr: 0  
Other Desc: SIRAS  
Other Flag: Y

SIR Vendor Nbr: 0

\*\*\*\*\* 003 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 003 U  
Dispenser Type Submersible  
Tank Const Mtl Bare/Paint/Asph Coat Steel  
Used For Heating?: N  
Tank Disposal Company  
Tank Cath Prot Impressed Current  
Pipe Material Steel/Iron  
HW Generator ID  
Tank Registration Date 01/29/1986

Client Tank Nbr 003  
Total Capacity: 20,000  
Stored Product Alcohol Blend  
Tank Status Active  
2nd Cont Tank  
Pipe Cath Prot Impressed Current  
Piping Material Desc  
Product Replaced Date  
Unreg Tank Report Date

----- 003 - UST TANK INFORMATION -----

# of Tank Compartments: 1  
Compartment Number: 1  
Compartment Stored Prod Alcohol Blend  
Compartment Other Desc:

Compartment Capacity: 20000  
Compartment Stored Desc: ALCOHOL BLEND

---- Overfill Information ----

Overfill Prot Alarm  
Overfill Prot Ballfloat: Y  
Overfill Prot No Info.  
Overfill Prot Type Unk

Overfill Prot Autoshut  
Overfill Prot Manual  
Overfill Prot None.

---- Tank Release Protection ----

Daily Stick: Y  
Tightness Test Y  
Manual Gauging N  
Auto Gauging: N  
Soil Vapor Monitor N  
Groundwater Monitor N  
Interstit Monitor: N  
SIR Approve Date: 01/01/1999  
SIR Vendor Nbr: 0  
Other Desc: SIRAS  
Other Flag: Y

---- Piping Release Protection ----

Auto Line Leak Detection: Y  
Annual Tightness Test N  
Vapor Monitoring N  
Groundwater Monitor N  
Interstit Monitor: N  
3 Year Tightness Test: N  
European Suction: N  
SIR Approve Date 01/01/1999  
SIR Vendor Nbr 0

\*\*\*\*\* 004 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 004 U  
Dispenser Type Submersible  
Tank Const Mtl Bare/Paint/Asph Coat Steel  
Used For Heating? N  
Tank Disposal Company:  
Tank Cath Prot Impressed Current  
Pipe Material: Steel/Iron  
HW Generator ID  
Tank Registration Date: 01/29/1986

Client Tank Nbr: 004  
Total Capacity: 10,000  
Stored Product: Alcohol Blend  
Tank Status Active  
2nd Cont Tank:  
Pipe Cath Prot Impressed Current  
Piping Material Desc:  
Product Replaced Date  
Unreg Tank Report Date:

----- 004 - UST TANK INFORMATION -----

# of Tank Compartments: 1  
Compartment Number 1  
Compartment Stored Prod Alcohol Blend  
Compartment Other Desc:

Compartment Capacity: 10000  
Compartment Stored Desc ALCOHOL BLEND

---- Overfill Information ----



Petrol Pumper  
Site ID: 12032

Autocare/Autoparts  
Type of Site: Underground Only

Overfill Prot Alarm  
Overfill Prot Ballfloat Y  
Overfill Prot No Info  
Overfill Prot Type Unk  
---- Tank Release Protection ----  
Daily Stick Y  
Tightness Test Y  
Manual Gauging: N  
Auto Gauging: N  
Soil Vapor Monitor: N  
Groundwater Monitor N  
Interstit Monitor: N  
SIR Approve Date 01/01/1999  
SIR Vendor Nbr: 0  
Other Desc SIRAS  
Other Flag Y

Overfill Prot Autoshut  
Overfill Prot Manual  
Overfill Prot None  
---- Piping Release Protection ----  
Auto Line Leak Detection Y  
Annual Tightness Test N  
Vapor Monitoring: N  
Groundwater Monitor N  
Interstit Monitor: N  
3 Year Tightness Test. N  
European Suction: N  
SIR Approve Date. 01/01/1999  
SIR Vendor Nbr: 0

\*\*\*\*\* 005 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 005 U  
Dispenser Type Submersible  
Tank Const Mtl: Bare/Paint/Asph Coat Steel  
Used For Heating? U  
Tank Disposal Company  
Tank Cath Prot Impressed Current  
Pipe Material Steel/Iron  
HW Generator ID:  
Tank Registration Date 01/29/1986

Client Tank Nbr: 005  
Total Capacity 10,000  
Stored Product: Alcohol Blend  
Tank Status Active  
2nd Cont Tank  
Pipe Cath Prot. Impressed Current  
Piping Material Desc  
Product Replaced Date.  
Unreg Tank Report Date

----- 005 - UST TANK INFORMATION -----

# of Tank Compartments 1  
Compart Number: 1  
Compart Stored Prod Alcohol Blend  
Compart Other Desc

Compart Capacity 10000  
Compart Stored Desc: ALCOHOL BLEND

---- Overfill Information ----  
Overfill Prot Alarm:  
Overfill Prot Ballfloat Y  
Overfill Prot No Info  
Overfill Prot Type Unk  
---- Tank Release Protection ----  
Daily Stick Y  
Tightness Test: Y  
Manual Gauging N  
Auto Gauging N  
Soil Vapor Monitor: N  
Groundwater Monitor N  
Interstit Monitor: N  
SIR Approve Date. 01/01/1999  
SIR Vendor Nbr. 0  
Other Desc. SIRAS  
Other Flag Y

Overfill Prot Autoshut  
Overfill Prot Manual.  
Overfill Prot None  
---- Piping Release Protection ----  
Auto Line Leak Detection Y  
Annual Tightness Test: N  
Vapor Monitoring. N  
Groundwater Monitor. N  
Interstit Monitor: N  
3 Year Tightness Test. N  
European Suction: N  
SIR Approve Date: 01/01/1999  
SIR Vendor Nbr: 0

\*\*\*\*\* 001 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr: 001 U  
Dispenser Type Submersible  
Tank Const Mtl Bare/Paint/Asph Coat Steel

Client Tank Nbr 001  
Total Capacity 20,000  
Stored Product Diesel



**Petrol Pumper**

**Autocare/Autoparts**

Site ID: 12032

Type of Site: Underground Only

Used For Heating? U  
Tank Disposal Company  
Tank Cath Prot Anode  
Pipe Material Steel/Iron  
HW Generator ID:  
Tank Registration Date 01/29/1986

Tank Status: Removed  
2nd Cont Tank:  
Pipe Cath Prot None  
Piping Material Desc:  
Product Replaced Date  
Unreg Tank Report Date:

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments: 1  
Compart Number 1  
Compart Stored Prod. Diesel  
Compart Other Desc:

Compart Capacity: 20000  
Compart Stored Desc. DIESEL

---- Overfill Information ----

Overfill Prot Alarm:  
Overfill Prot Ballfloat  
Overfill Prot No Info Y  
Overfill Prot Type Unk:

Overfill Prot Autoshut:  
Overfill Prot Manual:  
Overfill Prot None

---- Tank Release Protection ----

Daily Stick Y  
Tightness Test Y  
Manual Gauging N  
Auto Gauging: N  
Soil Vapor Monitor N  
Groundwater Monitor N  
Interstit Monitor N  
SIR Approve Date  
SIR Vendor Nbr. 0  
Other Desc.  
Other Flag: N

---- Piping Release Protection ----

Auto Line Leak Detection: N  
Annual Tightness Test: N  
Vapor Monitoring N  
Groundwater Monitor: N  
Interstit Monitor N  
3 Year Tightness Test: N  
European Suction. N  
SIR Approve Date  
SIR Vendor Nbr. 0

\*\*\*\*\* 006 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 006 U  
Dispenser Type Submersible  
Tank Const Mtl. Bare/Paint/Asph Coat Steel  
Used For Heating? U  
Tank Disposal Company:  
Tank Cath Prot Impressed Current  
Pipe Material Steel/Iron  
HW Generator ID  
Tank Registration Date 01/29/1986

Client Tank Nbr 006  
Total Capacity. 10,000  
Stored Product Diesel  
Tank Status: Removed  
2nd Cont Tank:  
Pipe Cath Prot Impressed Current  
Piping Material Desc:  
Product Replaced Date:  
Unreg Tank Report Date.

----- 006 - UST TANK INFORMATION -----

# of Tank Compartments. 1  
Compart Number 1  
Compart Stored Prod. Diesel  
Compart Other Desc.

Compart Capacity: 10000  
Compart Stored Desc DIESEL

---- Overfill Information ----

Overfill Prot Alarm:  
Overfill Prot Ballfloat. Y  
Overfill Prot No Info.  
Overfill Prot Type Unk:

Overfill Prot Autoshut.  
Overfill Prot Manual:  
Overfill Prot None

---- Tank Release Protection ----

Daily Stick Y  
Tightness Test Y

---- Piping Release Protection ----

Auto Line Leak Detection. Y  
Annual Tightness Test: N



Petrol Pumper

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Manual Gauging	N	Vapor Monitoring	N
Auto Gauging	N	Groundwater Monitor	N
Soil Vapor Monitor	N	Interstit Monitor	N
Groundwater Monitor	N	3 Year Tightness Test	N
Interstit Monitor	N	European Suction	N
SIR Approve Date		SIR Approve Date	
SIR Vendor Nbr	0	SIR Vendor Nbr	0
Other Desc	SIRAS		
Other Flag	Y		

\*\*\*\*\* 007 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr:	007 U	Client Tank Nbr	007
Dispenser Type	Suction	Total Capacity:	10,000
Tank Const Mtl	Bare/Paint/Asph Coat Steel	Stored Product:	Fuel Oil
Used For Heating?	Y	Tank Status:	Removed
Tank Disposal Company		2nd Cont Tank:	
Tank Cath Prot	None	Pipe Cath Prot	None
Pipe Material	Steel/Iron	Piping Material Desc:	
HW Generator ID.		Product Replaced Date	
Tank Registration Date	06/14/1994	Unreg Tank Report Date:	

----- 007 - UST TANK INFORMATION -----

# of Tank Compartments.	1	Compart Capacity.	10000
Compart Number	1	Compart Stored Desc:	FUEL OIL
Compart Stored Prod	Fuel Oil		
Compart Other Desc			

--- Overfill Information ---

Overfill Prot Alarm		Overfill Prot Autoshut.	
Overfill Prot Ballfloat		Overfill Prot Manual.	
Overfill Prot No Info	Y	Overfill Prot None	
Overfill Prot Type	Unk		

---- Tank Release Protection ----

Daily Stick	N	---- Piping Release Protection ----	
Tightness Test	N	Auto Line Leak Detection.	N
Manual Gauging	N	Annual Tightness Test.	N
Auto Gauging	N	Vapor Monitoring	N
Soil Vapor Monitor.	N	Groundwater Monitor.	N
Groundwater Monitor	N	Interstit Monitor	N
Interstit Monitor	N	3 Year Tightness Test	N
SIR Approve Date		European Suction:	N
SIR Vendor Nbr:	0	SIR Approve Date.	
Other Desc	SIRAS	SIR Vendor Nbr:	0
Other Flag	Y		

\*\*\*\*\* 008 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr:	008 U	Client Tank Nbr:	008
Dispenser Type:	Suction	Total Capacity	550
Tank Const Mtl	Bare/Paint/Asph Coat Steel	Stored Product.	Used Or Waste Oil
Used For Heating?	N	Tank Status.	Removed
Tank Disposal Company		2nd Cont Tank	
Tank Cath Prot	None	Pipe Cath Prot	None
Pipe Material	Steel/Iron	Piping Material Desc.	
HW Generator ID.		Product Replaced Date.	
Tank Registration Date	06/14/1994	Unreg Tank Report Date:	

----- 008 - UST TANK INFORMATION -----



Petrol Pumper  
Site ID: 12032

Autocare/Autoparts  
Type of Site: Underground Only

# of Tank Compartments: 1  
Compart Number 1  
Compart Stored Prod Used Or Waste Oil  
Compart Other Desc:

Compart Capacity: 550  
Compart Stored Desc: WASTE OIL

--- Overfill Information ---

Overfill Prot Alarm  
Overfill Prot Ballfloat.  
Overfill Prot No Info. Y  
Overfill Prot Type Unk:

Overfill Prot Autoshut:  
Overfill Prot Manual.  
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick N  
Tightness Test: N  
Manual Gauging N  
Auto Gauging N  
Soil Vapor Monitor: N  
Groundwater Monitor N  
Interstit Monitor. N  
SIR Approve Date.  
SIR Vendor Nbr: 0  
Other Desc: SIRAS  
Other Flag: Y

--- Piping Release Protection ---

Auto Line Leak Detection N  
Annual Tightness Test N  
Vapor Monitoring. N  
Groundwater Monitor: N  
Interstit Monitor N  
3 Year Tightness Test N  
European Suction. N  
SIR Approve Date  
SIR Vendor Nbr: 0

\*\*\*\*\* CORRESPONDENCE \*\*\*\*\*

Number: 1  
Company:  
Type: Registration Form

Date 01/01/1901  
Person At Co  
PCS:

Number 2  
Company: HASTY TRUCK T  
Type: Registration Form

Date 01/10/1994  
Person At Co ERVIN RADUNZ  
PCS.

Signature: ERVIN RADUNZ

Title :

Date Form Received 12/20/93 (CHANGE OF STATUS-REMOVAL FOR TANK 001)

Number 3  
Company: PETROL PUMPER  
Type: Registration Form

Date 11/18/1994  
Person At Co JAY CLARK  
PCS

Signature JAY CLARK

Title VICE PRESIDENT

Date Form Received 6/7/94 (CHANGED OWNERSHIP, SITE NAME INITIAL REG FOR TANKS 007-008 B & F DIST PURCHASED THE PROPERTY ON A BANKRUPCY PREVIOUS OWNER DID REG TANKS 007-008. TANKS 002-003-004-005-006 INSTALLED IMPRESSED CURRENT SYSTEM BY HARCO TECHNOLOGIES WITH B & F DIST ELECTRICIAN)

Number: 4  
Company: PETROL PUMPER  
Type: Phone Call

Date: 05/02/1997  
Person At Co: MATT-OMNI ENV  
PCS:

MATT, OMNI ENV CALLED 5/1/97 AND STATED ALL TANKS HAVE LEAK DETECTION-



---

**Petrol Pumper**

Site ID: 12032

**Autocare/Autoparts**Type of Site: Underground Only

---

SIRAS

Number 5  
Company B&F  
Type LetterDate 06/26/1997  
Person At Co RAY COLBERT  
PCS

-LETTER IN RESPONSE TO SELF-AUDIT FOLLOWING VIOLATIONS DISCOVERED:

-FAILURE TO PERFORM ANNUAL FUNCTION TEST OF LINE LEAK DETECTOR

-FAILURE TO REGISTER TANKS 007-008 BY JUNE 1, 1986, OR WITHIN 30 DAYS OF  
INSTALLATION OR DISCOVERY.Number 6  
Company: OMNI ENVIRONM  
Type: Field NotesDate 06/12/1998  
Person At Co MATT GIKAS  
PCS

REQUESTED DATA BASE REPORT FOR COMPLIANCE REVIEW WITH O/O.

Number 7  
Company: ADVANCED TANK  
Type: Phone CallDate 01/29/1999  
Person At Co MATT  
PCS

PRE-NOTICE OF THE REMOVAL OF UST'S 001 - 002 TO BE DONE ON 12/10/98

Number 8  
Company: ADVANCED TANK  
Type: Phone CallDate 06/29/1999  
Person At Co JULIE  
PCS

PRE-NOTICE OF THE REMOVAL OF UST 007 TO BE DONE ON 7/7/99

Number 9  
Company: PETROL PUMPER  
Type: AuditDate 04/11/1997  
Person At Co RAYMOND COLBER  
PCS RS

4/11/97 AUDIT WAS RECEIVED

Number 10  
Company Kato, Inc.  
Type LetterDate: 09/22/1998  
Person At Co Raymond Colber  
PCS EEB

9/22/98 EEB-Audit file closure letter sent

Number: 11  
Company: EDWIN BALCOS  
Type: Field NotesDate: 05/07/2001  
Person At Co  
PCS JCH5/7/2001 EDWIN BALCOS, TANKS LEARNED SITE #12032 AND 12031 IS THE SAME SITE  
12031 TO BE DELETED-

REMARKS ON 12031 SITE- LISTED BELOW

7/20/94, JAY K CLARK, B&amp;F DIST -

FORM RECEIVED 8/14/94- CHANGE OF OWNERSHIP, SITE NAME AND CHANGED TANK 001-002



**Petrol Pumper**

**Autocare/Autoparts**

**Site ID: 12032**

**Type of Site: Underground Only**

PRODUCTS PREVIOUSLY CONTAINED BOTH FUEL OIL- B&F DIST. CLEANED TANKS AND TAKEN OUT OF PETROLEUM SERVICE BOTH TANKS ARE NOW CONNECTED TO GREY WATER DISCHARGE SEWER LINE FROM BLDG THEY NOW CONTAIN AN UNREG. SUBSTANCE AND WILL BE USED FROM TODAY FORWARD AS GREY WATER STORAGE PER COMMENT.

1/20/00- MATT GIKAS, PETROL PUMPER-  
FORM RECIEVED 1/19/99- TANK 003 REMOVED AND NOTIFICATION OF TANK

7/7/99, MATT GIKAS, PETROL PUMPER  
FORM RECEIVED 7/7/99- NOTIFICATION FORM RECEIVED STATING TANK 004 WAS REMOVED ON 7/7/99 TANK WAS NOT PREVIOUSLY REG.

Number 12  
Company: Olson's Truck Stop  
Type: Field Notes

Date: 07/07/2005  
Person At Co: LuAnn Bock  
PCS: SJS

Ownership change May 20, 2005. New owners are Dave and Ron Olson (also own Stop & Go in Minneapolis) Need to verify what method of leak detection they are going to use. Per site mgr, to date just recording tank inventory each day.

\*\*\*\*\* INSPECTIONS \*\*\*\*\*

Date 10-APR-97  
Type Routine  
Reason Audit Visit  
-----

Date 12-JUN-98  
Type Routine  
Reason Site Visit  
-----

Date: 07-JUL-05  
Type Routine  
Reason Facility  
-----





Report Title. Tank Site and Owner Information  
**Minnesota Pollution Control Agency**  
**TALES Report**

Report Number 43

*Debate*

20 February, 2008

**Petrol Pumper**

Site ID: 12031

*good add*

**Service Station**

Type of Site: Underground Only

*to the  
address*

Address 4101 148th St NW  
 Clearwater, MN 55320  
 County Wright  
 Site Phone NO CORE PI PH  
 Old Phone: 6128781655

Region: M  
 AST Registration  
 UST Registration: 1/29/1986  
 Contact Phone: 7638781655

\*\*\*\*\* OWNER INFORMATION \*\*\*\*\*

Owner Name: David Olson  
 Owner ID -264848  
 Address 3419 Highlands Rd  
 Brooklyn Park, MN 55443

*change on 12032*

\*\*\*\*\* TANK INFORMATION SUMMARY \*\*\*\*\*

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
001	U	Active	Unregulated	20,000	09/01/1981		01/29/1986
002	U	Active	Unregulated	20,000	09/01/1981		01/29/1986
003	U	Removed	Used Or Waste Oil	1,000	01/01/1900	12/10/1998	01/19/1999
Removal Contractor: ADVANCED TANK SERVICE INC							
004	U	Removed	Fuel Oil	10,000		07/07/1999	10/13/1999
Removal Contractor: ADVANCED TANK SERVICE INC							

\*\*\*\*\* 001 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 001 U	Client Tank Nbr: 001
Dispenser Type: Suction	Total Capacity: 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product: Unregulated
Used For Heating? N	Tank Status: Active
Tank Disposal Company:	2nd Cont Tank
Tank Cath Prot: Anode	Pipe Cath Prot: None
Pipe Material: Steel/Iron	Piping Material Desc
HW Generator ID	Product Replaced Date: 01/01/1994
Tank Registration Date: 01/29/1986	Unreg Tank Report Date:

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity: 20000
Compart Number 1	Compart Stored Desc: GREY WATER
Compart Stored Prod Unregulated	
Compart Other Desc	

---- Overfill Information ----

Overfill Prot Alarm  
 Overfill Prot Ballfloat  
 Overfill Prot No Info. Y  
 Overfill Prot Type Unk:

Overfill Prot Autoshut  
 Overfill Prot Manual  
 Overfill Prot None

---- Tank Release Protection ----

Daily Stick Y  
 Tightness Test: Y  
 Manual Gauging: N  
 Auto Gauging N  
 Soil Vapor Monitor N  
 Groundwater Monitor N  
 Interstit Monitor: N  
 SIR Approve Date: 07/28/1994  
 SIR Vendor Nbr 1  
 Other Desc:

---- Piping Release Protection ----

Auto Line Leak Detection N  
 Annual Tightness Test N  
 Vapor Monitoring: N  
 Groundwater Monitor N  
 Interstit Monitor: N  
 3 Year Tightness Test: N  
 European Suction: Y  
 SIR Approve Date 07/28/1994  
 SIR Vendor Nbr 1



Petrol Pumper  
Site ID: 12031

Service Station  
Type of Site: Underground Only

Other Flag: N

\*\*\*\*\* 002 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 002 U  
Dispenser Type Suction  
Tank Const Mtl Bare/Paint/Asph Coat Steel  
Used For Heating?. N  
Tank Disposal Company:  
Tank Cath Prot. Anode  
Pipe Material Steel/Iron  
HW Generator ID:  
Tank Registration Date 01/29/1986

Client Tank Nbr: 002  
Total Capacity: 20,000  
Stored Product Unregulated  
Tank Status Active  
2nd Cont Tank  
Pipe Cath Prot: None  
Piping Material Desc.  
Product Replaced Date: 01/01/1994  
Unreg Tank Report Date:

----- 002 - UST TANK INFORMATION -----

# of Tank Compartments: 1  
Compartment Number: 1  
Compartment Stored Prod Unregulated  
Compartment Other Desc

Compartment Capacity 20000  
Compartment Stored Desc: GREY WATER

---- Overfill Information ----

Overfill Prot Alarm:  
Overfill Prot Ballfloat  
Overfill Prot No Info Y  
Overfill Prot Type Unk:

Overfill Prot Autoshut:  
Overfill Prot Manual:  
Overfill Prot None.

---- Tank Release Protection ----

Daily Stick: Y  
Tightness Test Y  
Manual Gauging N  
Auto Gauging N  
Soil Vapor Monitor: N  
Groundwater Monitor: N  
Interstit Monitor N  
SIR Approve Date: 07/28/1994  
SIR Vendor Nbr: 1  
Other Desc:  
Other Flag: N

---- Piping Release Protection ----

Auto Line Leak Detection N  
Annual Tightness Test N  
Vapor Monitoring: N  
Groundwater Monitor N  
Interstit Monitor: N  
3 Year Tightness Test: N  
European Suction Y  
SIR Approve Date 07/28/1994  
SIR Vendor Nbr: 1

\*\*\*\*\* 003 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 003 U  
Dispenser Type Gravity  
Tank Const Mtl Bare/Paint/Asph Coat Steel  
Used For Heating?. N  
Tank Disposal Company:  
Tank Cath Prot: None  
Pipe Material Steel/Iron  
HW Generator ID:  
Tank Registration Date 01/19/1999

Client Tank Nbr: 003  
Total Capacity: 1,000  
Stored Product: Used Or Waste Oil  
Tank Status: Removed  
2nd Cont Tank:  
Pipe Cath Prot. None  
Piping Material Desc:  
Product Replaced Date  
Unreg Tank Report Date:

----- 003 - UST TANK INFORMATION -----

# of Tank Compartments: 1  
Compartment Number 1  
Compartment Stored Prod Used Or Waste Oil  
Compartment Other Desc

Compartment Capacity: 1000  
Compartment Stored Desc: WASTE OIL

---- Overfill Information ----

Overfill Prot Alarm:  
Overfill Prot Ballfloat:

Overfill Prot Autoshut:  
Overfill Prot Manual



Petrol Pumper  
Site ID: 12031

Service Station  
Type of Site: Underground Only

Overfill Prot No Info Y  
Overfill Prot Type Unk  
---- Tank Release Protection ----  
Daily Stick N  
Tightness Test N  
Manual Gauging N  
Auto Gauging: N  
Soil Vapor Monitor N  
Groundwater Monitor: N  
Interstit Monitor N  
SIR Approve Date:  
SIR Vendor Nbr. 0  
Other Desc  
Other Flag N

Overfill Prot None:  
---- Piping Release Protection ----  
Auto Line Leak Detection: N  
Annual Tightness Test: N  
Vapor Monitoring N  
Groundwater Monitor. N  
Interstit Monitor N  
3 Year Tightness Test N  
European Suction N  
SIR Approve Date.  
SIR Vendor Nbr. 0

\*\*\*\*\* 004 - COMMON TANK INFORMATION \*\*\*\*\*

Our Tank Nbr 004 U  
Dispenser Type Suction  
Tank Const Mtl. Bare/Paint/Asph Coat Steel  
Used For Heating?  
Tank Disposal Company. Advanced Tank Services  
Tank Cath Prot. Unknown  
Pipe Material Copper  
HW Generator ID  
Tank Registration Date 10/13/1999

Client Tank Nbr 004  
Total Capacity 10,000  
Stored Product Fuel Oil  
Tank Status: Removed  
2nd Cont Tank:  
Pipe Cath Prot: Unknown  
Piping Material Desc. 10  
Product Replaced Date:  
Unreg Tank Report Date 10/14/1999

----- 004 - UST TANK INFORMATION -----

# of Tank Compartments. 1  
Compart Number 1  
Compart Stored Prod Fuel Oil  
Compart Other Desc

Compart Capacity: 10000  
Compart Stored Desc Fuel Oil

---- Overfill Information ----  
Overfill Prot Alarm:  
Overfill Prot Ballfloat  
Overfill Prot No Info Y  
Overfill Prot Type Unk  
---- Tank Release Protection ----  
Daily Stick  
Tightness Test.  
Manual Gauging  
Auto Gauging  
Soil Vapor Monitor.  
Groundwater Monitor:  
Interstit Monitor  
SIR Approve Date  
SIR Vendor Nbr  
Other Desc  
Other Flag

Overfill Prot Autoshut:  
Overfill Prot Manual  
Overfill Prot None: Y  
---- Piping Release Protection ----  
Auto Line Leak Detection  
Annual Tightness Test:  
Vapor Monitoring  
Groundwater Monitor.  
Interstit Monitor:  
3 Year Tightness Test  
European Suction  
SIR Approve Date:  
SIR Vendor Nbr

\*\*\*\*\* CORRESPONDENCE \*\*\*\*\*

Number: 1  
Company  
Type. Registration Form

Date: 01/01/1901  
Person At Co:  
PCS:



**Petrol Pumper**  
**Site ID: 12031**

**Service Station**  
**Type of Site: Underground Only**

Number 2  
Company. B & F DISTR.  
Type. Registration Form

Date: 07/20/1994  
Person At Co. JAY K. CLARK  
PCS.

Signature: JAY K CLARK  
Title VICE PRESIDENT/B & F DIST.

Date Form Received 6/14/94 (CHANGED OF OWNERSHIP, SITE NAME, AND CHANGED TANK 001-002 PRODUCTS PREVIOUSLY CONTAINED BOTH FUEL OIL B & F DIST CLEANED TANKS AND TAKEN OUT OF PETROLEUM SERVICE. BOTH TANKS ARE NOW CONNECTED TO GREY WATER DISCHARGE SEWER LINE FROM BLDG THEY NOW CONTAIN AN UNREGULATED SUBSTANCE AND WILL BE USED FROM TODAY FORWARD AS GREY WATER STORAGE PER COMMENT ON THE BACK FORM)

Number 3  
Company: PETROL PUMPER  
Type Registration Form

Date: 01/20/1999  
Person At Co: MATT GIKAS  
PCS:

Signature MATT GIKAS  
Title GEN MGR

Date Form Received 1/19/99 (TANK 003 REMOVAL AND NOTIFICATION OF TANK)

Number 4  
Company. Petrol Pumper  
Type: Registration Form

Date: 07/07/1999  
Person At Co: Matt Gikas  
PCS Aaron Am

Signature Matt Gikas, Gen Manager  
Date. 07/07/1999

Notification form recieved stating that ust 004 wasremoved on 7/7/1999 This tank was previously unregistered

Number 5  
Company Kato, Inc  
Type Phone Call

Date 05/08/2001  
Person At Co Ray Colbert  
PCS EEB

5/08/01 EEB-Spoke with Ray Colbert (Kato, Inc ). The 2-20K USTs are used for run-off ("grey water") and have been used as such since about '94/'95 The tanks are active but unregulated.  
-Changed status for 001 and 002 to active, unregulated substance.  
-Left a message for Matt Gikas (Omni Environmental, 507/252-0945) to discuss why this site has a different UST ID# than 12032. 12031 and 12032 are at the same location  
-Spoke with Matt Gikas (Omni). This is the same facility as 12032. Kato, Inc. is the owner  
-Asked JCH to merge 12031 into 12032 12031 will be deleted

Number. 6  
Company OLSONS TRAVEL STOP  
Type: Registration Form

Date 12/24/2007  
Person At Co:  
PCS JCH

12/24/2007 RECEIVED NOTIFICATION FORM FOR CHANGE OF OWNERSHIP 5/20/2005  
FORM SIGNED DAVID M. OLSON, PRES 12/21/2007

\*\*\*\*\* INSPECTIONS \*\*\*\*\*