



Minnesota Pollution Control Agency
Tales - Tank Site Information-Short Report

Report Number 68

07 May, 2001

Site Information

Preferred ID 12032
 PETROL PUMPER
 I94 & CO RD 8 EXIT 183
 CLEARWATER MN 55380

Region M - Metro
 District METRO
 County Wright

Owner Information

KATO INC
 PO BOX 6758
 ROCHESTER MN 55903

Phone ~~507-875-4499~~

507/280-7910 Rzy Colburn

Tank Information

<u>Client Tank</u>	<u>MPCA Tank</u>	<u>A/U</u>	<u>Status</u>	<u>Substance Stored</u>	<u>Capacity</u>	<u>Registration</u>	<u>Removed Date</u>	<u>Installed Date</u>
001	001	Under Ground	Removed	Diesel	20,000	1/29/1986	01/01/1988	02/10/1976
002	002	Under Ground	Active	Diesel	20,000	1/29/1986		02/10/1976
003	003	Under Ground	Active	Alcohol Blend	20,000	1/29/1986		02/10/1976
004	004	Under Ground	Active	Alcohol Blend	10,000	1/29/1986		02/10/1976
005	005	Under Ground	Active	Alcohol Blend	10,000	1/29/1986		02/10/1976
006	006	Under Ground	Removed	Diesel	10,000	1/29/1986	12/10/1998	02/10/1976
007	007	Under Ground	Removed	Fuel Oil	10,000	6/14/1994	07/07/1999	01/01/1900
008	008	Under Ground	Removed	Used Or Waste Oil	550	6/14/1994	12/10/1998	01/01/1900



07 May, 2001

PETROL PUMPER

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Address I94 & CO RD 8 EXIT 183
 CLEARWATER, MN 55380
 County Wright
 Site Phone 612-878-1655

Region M
 AST Registration
 UST Registration 1/29/86

***** OWNER INFORMATION *****

Owner Name KATO INC
 Owner ID 186802
 Address PO BOX 6758
 ROCHESTER, MN 55903

***** TANK INFORMATION SUMMARY *****

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
001	U	Removed	Diesel	20,000	02/10/1976	01/01/1988	01/29/1986
002	U	Active	Diesel	20,000	02/10/1976		01/29/1986
003	U	Active	Alcohol Blend	20,000	02/10/1976		01/29/1986
004	U	Active	Alcohol Blend	10,000	02/10/1976		01/29/1986
005	U	Active	Alcohol Blend	10,000	02/10/1976		01/29/1986
006	U	Removed	Diesel	10,000	02/10/1976	12/10/1998	01/29/1986
007	U	Removed	Fuel Oil	10,000	01/01/1900	07/07/1999	06/14/1994
008	U	Removed	Used Or Waste Oil	550	01/01/1900	12/10/1998	06/14/1994

***** 001 - COMMON TANK INFORMATION *****

Our Tank Nbr 001 U	Client Tank Nbr: 001
Dispenser Type Submersible	Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Diesel
Used For Heating? U	Tank Status Removed
Tank Disposal Company	2nd Cont Tank
Tank Cath Prot	Pipe Cath Prot None
Pipe Material Steel/Iron	Piping Material Desc
HW Generator ID	Product Replaced Date
Tank Registration Date 01/29/1986	Unreg Tank Report Date.

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity 20000
Compart Number 1	Compart Stored Desc DIESEL
Compart Stored Prod Diesel	
Compart Other Desc	

---- Overfill Information ----

Overfill Prot Alarm
 Overfill Prot Ballfloat
 Overfill Prot No Info Y
 Overfill Prot Type Unk

Overfill Prot Autoshut
 Overfill Prot Manual
 Overfill Prot None

---- Tank Release Protection ----

Daily Stick Y
 Tightness Test Y
 Manual Gauging N
 Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date
 SIR Vendor Nbr 0

---- Piping Release Protection ----

Auto Line Leak Detection N
 Annual Tightness Test N
 Vapor Monitoring N
 Groundwater Monitor N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction N
 SIR Approve Date
 SIR Vendor Nbr 0



PETROL PUMPER

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Other Desc
Other Flag N

***** 002 - COMMON TANK INFORMATION *****

Our Tank Nbr 002 U	Client Tank Nbr 002
Dispenser Type Submersible	Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Diesel
Used For Heating? U	Tank Status Active
Tank Disposal Company	2nd Cont Tank
Tank Cath Prot	Pipe Cath Prot Impressed Current
Pipe Material Coated Steel	Piping Material Desc
HW Generator ID	Product Replaced Date
Tank Registration Date 01/29/1986	Unreg Tank Report Date

----- 002 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity 20000
Compart Number 1	Compart Stored Desc DIESEL
Compart Stored Prod Diesel	
Compart Other Desc	

---- Overfill Information ----

Overfill Prot Alarm	Overfill Prot Autoshut
Overfill Prot Ballfloat Y	Overfill Prot Manual
Overfill Prot No Info	Overfill Prot None
Overfill Prot Type Unk	

---- Tank Release Protection ----

Daily Stick Y
Tightness Test Y
Manual Gauging N
Auto Gauging N
Soil Vapor Monitor N
Groundwater Monitor: N
Interstit Monitor N
SIR Approve Date 01/
SIR Vendor Nbr 0
Other Desc SIR
Other Flag Y

---- Piping Release Protection ----

Auto Line Leak Detection Y
Annual Tightness Test N
Vapor Monitoring N
Groundwater Monitor N
Interstit Monitor N
3 Year Tightness Test N
European Suction N
SIR Approve Date 01/0
SIR Vendor Nbr 0

***** 003 - COMMON TANK INFORMATION *****

Our Tank Nbr 003 U	Client Tank Nbr 003
Dispenser Type Submersible	Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Alcohol Blend
Used For Heating? N	Tank Status Active
Tank Disposal Company	2nd Cont Tank
Tank Cath Prot	Pipe Cath Prot: Impressed Current
Pipe Material Steel/Iron	Piping Material Desc
HW Generator ID	Product Replaced Date
Tank Registration Date 01/29/1986	Unreg Tank Report Date.

----- 003 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity 20000
Compart Number 1	Compart Stored Desc ALCOHOL BLEND
Compart Stored Prod Alcohol Blend	
Compart Other Desc	

---- Overfill Information ----

Overfill Prot Alarm	Overfill Prot Autoshut
---------------------	------------------------



PETROL PUMPER

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Overfill Prot Ballfloat Y
 Overfill Prot No Info
 Overfill Prot Type Unk
 --- Tank Release Protection ---
 Daily Stick Y
 Tightness Test Y
 Manual Gauging N
 Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date 01/
 SIR Vendor Nbr 0
 Other Desc SIR
 Other Flag Y

Overfill Prot Manual
 Overfill Prot None
 --- Piping Release Protection ---
 Auto Line Leak Detection Y
 Annual Tightness Test N
 Vapor Monitoring N
 Groundwater Monitor. N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction N
 SIR Approve Date 01/0
 SIR Vendor Nbr 0

***** 004 - COMMON TANK INFORMATION *****

Our Tank Nbr 004 U
 Dispenser Type Submersible
 Tank Const Mtl Bare/Paint/Asph Coat Steel
 Used For Heating? N
 Tank Disposal Company
 Tank Cath Prot
 Pipe Material Steel/Iron
 HW Generator ID
 Tank Registration Date 01/29/1986

Client Tank Nbr 004
 Total Capacity 10,000
 Stored Product Alcohol Blend
 Tank Status: Active
 2nd Cont Tank
 Pipe Cath Prot Impressed Current
 Piping Material Desc
 Product Replaced Date
 Unreg Tank Report Date

----- 004 - UST TANK INFORMATION -----

of Tank Compartments 1
 Compartment Number 1
 Compartment Stored Prod Alcohol Blend
 Compartment Other Desc

Compartment Capacity 10000
 Compartment Stored Desc ALCOHOL BLEND

--- Overfill Information ---
 Overfill Prot Alarm
 Overfill Prot Ballfloat Y
 Overfill Prot No Info
 Overfill Prot Type Unk
 --- Tank Release Protection ---
 Daily Stick Y
 Tightness Test Y
 Manual Gauging N
 Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date 01/
 SIR Vendor Nbr 0
 Other Desc SIR
 Other Flag Y

Overfill Prot Autosht
 Overfill Prot Manual
 Overfill Prot None
 --- Piping Release Protection ---
 Auto Line Leak Detection Y
 Annual Tightness Test N
 Vapor Monitoring N
 Groundwater Monitor N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction N
 SIR Approve Date 01/0
 SIR Vendor Nbr. 0

***** 005 - COMMON TANK INFORMATION *****

Our Tank Nbr 005 U
 Dispenser Type Submersible
 Tank Const Mtl Bare/Paint/Asph Coat Steel
 Used For Heating? U

Client Tank Nbr. 005
 Total Capacity 10,000
 Stored Product Alcohol Blend
 Tank Status Active



PETROL PUMPER

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Tank Disposal Company
Tank Cath Prot
Pipe Material Steel/Iron
HW Generator ID
Tank Registration Date 01/29/1986

2nd Cont Tank
Pipe Cath Prot Impressed Current
Piping Material Desc
Product Replaced Date
Unreg Tank Report Date

005 - UST TANK INFORMATION

of Tank Compartments 1
Compartment Number 1
Compartment Stored Prod Alcohol Blend
Compartment Other Desc

Compartment Capacity 10000
Compartment Stored Desc ALCOHOL BLEND

Overfill Information

Overfill Prot Alarm
Overfill Prot Ballfloat Y
Overfill Prot No Info
Overfill Prot Type Unk

Overfill Prot Autoshut
Overfill Prot Manual
Overfill Prot None

Tank Release Protection

Daily Stick Y
Tightness Test Y
Manual Gauging N
Auto Gauging N
Soil Vapor Monitor N
Groundwater Monitor N
Interstit Monitor N
SIR Approve Date 01/
SIR Vendor Nbr 0
Other Desc SIR
Other Flag Y

Piping Release Protection

Auto Line Leak Detection Y
Annual Tightness Test N
Vapor Monitoring N
Groundwater Monitor N
Interstit Monitor N
3 Year Tightness Test N
European Suction N
SIR Approve Date 01/0
SIR Vendor Nbr 0

***** 006 - COMMON TANK INFORMATION *****

Our Tank Nbr 006 U
Dispenser Type Submersible
Tank Const Mtl Bare/Paint/Asph Coat Steel
Used For Heating? U
Tank Disposal Company
Tank Cath Prot
Pipe Material Steel/Iron
HW Generator ID
Tank Registration Date 01/29/1986

Client Tank Nbr 006
Total Capacity 10,000
Stored Product Diesel
Tank Status Removed
2nd Cont Tank
Pipe Cath Prot Impressed Current
Piping Material Desc
Product Replaced Date
Unreg Tank Report Date

006 - UST TANK INFORMATION

of Tank Compartments 1
Compartment Number 1
Compartment Stored Prod Diesel
Compartment Other Desc

Compartment Capacity 10000
Compartment Stored Desc DIESEL

Overfill Information

Overfill Prot Alarm
Overfill Prot Ballfloat Y
Overfill Prot No Info
Overfill Prot Type Unk

Overfill Prot Autoshut
Overfill Prot Manual
Overfill Prot None

Tank Release Protection

Daily Stick Y
Tightness Test Y
Manual Gauging N

Piping Release Protection

Auto Line Leak Detection Y
Annual Tightness Test N
Vapor Monitoring N



PETROL PUMPER

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Auto Gauging	N	Groundwater Monitor	N
Soil Vapor Monitor	N	Interstit Monitor	N
Groundwater Monitor	N	3 Year Tightness Test	N
Interstit Monitor	N	European Suction	N
SIR Approve Date		SIR Approve Date	
SIR Vendor Nbr	0	SIR Vendor Nbr	0
Other Desc	SIR		
Other Flag	Y		

***** 007 - COMMON TANK INFORMATION *****

Our Tank Nbr	007 U	Client Tank Nbr	007
Dispenser Type	Suction	Total Capacity	10,000
Tank Const Mtl	Bare/Paint/Asph Coat Steel	Stored Product	Fuel Oil
Used For Heating?	Y	Tank Status	Removed
Tank Disposal Company		2nd Cont Tank	
Tank Cath Prot		Pipe Cath Prot	None
Pipe Material	Steel/Iron	Piping Material Desc	
HW Generator ID		Product Replaced Date	
Tank Registration Date	06/14/1994	Unreg Tank Report Date	

----- 007 - UST TANK INFORMATION -----

# of Tank Compartments	1	Compart Capacity	10000
Compart Number	1	Compart Stored Desc	FUEL OIL
Compart Stored Prod	Fuel Oil		
Compart Other Desc			

--- Overfill Information ---

Overfill Prot Alarm		Overfill Prot Autosht	
Overfill Prot Ballfloat		Overfill Prot Manual	
Overfill Prot No Info	Y	Overfill Prot None	
Overfill Prot Type	Unk		

--- Tank Release Protection ---

Daily Stick	N	Auto Line Leak Detection	N
Tightness Test	N	Annual Tightness Test	N
Manual Gauging	N	Vapor Monitoring	N
Auto Gauging	N	Groundwater Monitor	N
Soil Vapor Monitor	N	Interstit Monitor	N
Groundwater Monitor	N	3 Year Tightness Test	N
Interstit Monitor	N	European Suction	N
SIR Approve Date		SIR Approve Date	
SIR Vendor Nbr	0	SIR Vendor Nbr	0
Other Desc	SIR		
Other Flag	Y		

--- Piping Release Protection ---

***** 008 - COMMON TANK INFORMATION *****

Our Tank Nbr	008 U	Client Tank Nbr	008
Dispenser Type	Suction	Total Capacity	550
Tank Const Mtl	Bare/Paint/Asph Coat Steel	Stored Product	Used Or Waste Oil
Used For Heating?	N	Tank Status	Removed
Tank Disposal Company		2nd Cont Tank	
Tank Cath Prot		Pipe Cath Prot	None
Pipe Material	Steel/Iron	Piping Material Desc	
HW Generator ID		Product Replaced Date	
Tank Registration Date	06/14/1994	Unreg Tank Report Date	

----- 008 - UST TANK INFORMATION -----

of Tank Compartments 1



PETROL PUMPER

Autocare/Autoparts

Site ID: 12032

Type of Site: Underground Only

Compartment Number 1
Compartment Stored Prod Used Or Waste Oil
Compartment Other Desc

Compartment Capacity 550
Compartment Stored Desc WASTE OIL

Overfill Information

Overfill Prot Alarm
Overfill Prot Ballfloat
Overfill Prot No Info Y
Overfill Prot Type Unk.

Overfill Prot Autoshut
Overfill Prot Manual
Overfill Prot None

Tank Release Protection

Daily Stick N
Tightness Test N
Manual Gauging N
Auto Gauging N
Soil Vapor Monitor N
Groundwater Monitor N
Interstit Monitor N
SIR Approve Date
SIR Vendor Nbr 0
Other Desc SIR
Other Flag Y

Piping Release Protection

Auto Line Leak Detection N
Annual Tightness Test N
Vapor Monitoring N
Groundwater Monitor N
Interstit Monitor N
3 Year Tightness Test N
European Suction N
SIR Approve Date
SIR Vendor Nbr 0

CORRESPONDENCE

Number 1
Company
Type Registration Form

Date 01/01/1901
Person At Co
PCS

Number 2
Company HASTY TRUCK T
Type Registration Form

Date 01/10/1994
Person At Co ERVIN RADUNZ
PCS

Signature ERVIN RADUNZ
Title

Date Form Received 12/20/93 (CHANGE OF STATUS-REMOVAL FOR TANK 001)

Number 3
Company PETROL PUMPER
Type Registration Form

Date 11/18/1994
Person At Co JAY CLARK
PCS

Signature JAY CLARK
Title VICE PRESIDENT

Date Form Received 6/7/94 (CHANGED OWNERSHIP, SITE NAME INITIAL REG FOR TANKS 007-008 B & F DIST PURCHASED THE PROPERTY ON A BANKRUPTCY PREVIOUS OWNER DID REG TANKS 007-008 TANKS 002-003-004-005-006 INSTALLED IMPRESSED CURRENT SYSTEM BY HARCO TECHNOLOGIES WITH B & F DIST ELECTRICIAN)

Number 4
Company PETROL PUMPER
Type Phone Call

Date 05/02/1997
Person At Co MATT-OMNI ENV
PCS

MATT, OMNI ENV CALLED 5/1/97 AND STATED ALL TANKS HAVE LEAK DETECTION-SIRAS



PETROL PUMPER

Site ID: 12032

Autocare/Autoparts**Type of Site: Underground Only**

Number 5
Company B&F
Type Letter

Date 06/26/1997
Person At Co RAY COLBERT
PCS

-LETTER IN RESPONSE TO SELF-AUDIT FOLLOWING VIOLATIONS DISCOVERED

-FAILURE TO PERFORM ANNUAL FUNCTION TEST OF LINE LEAK DETECTOR

-FAILURE TO REGISTER TANKS 007-008 BY JUNE 1, 1986, OR WITHIN 30 DAYS OF
INSTALLATION OR DISCOVERY

Number 6
Company OMNI ENVIRONM
Type Field Notes

Date 06/12/1998
Person At Co MATT GIKAS
PCS

REQUESTED DATA BASE REPORT FOR COMPLIANCE REVIEW WITH O/O

Number 7
Company ADVANCED TANK
Type Phone Call

Date 01/29/1999
Person At Co. MATT
PCS

PRE-NOTICE OF THE REMOVAL OF UST'S 001 - 002 TO BE DONE ON 12/10/98

Number 8
Company ADVANCED TANK
Type Phone Call

Date 06/29/1999
Person At Co JULIE
PCS.

PRE-NOTICE OF THE REMOVAL OF UST 007 TO BE DONE ON 7/7/99

Number 9
Company PETROL PUMPER
Type Audit

Date 04/11/1997
Person At Co RAYMOND COLBER
PCS RS

4/11/97 AUDIT WAS RECEIVED



Minnesota Pollution Control Agency
Tales - Tank Site Information-Short Report

Report Number 68

Delite
07 May, 2001

Site Information

Preferred ID 12031
 PETROL PUMPER
 4101 148TH ST NW EXIT 183 -I94 -ROUTE 1
 CLEARWATER MN 55320

Region M - Metro
 District METRO
 County Wright

Owner Information

B & F DISTRIBUTING INC
 PO BOX 6536
 ROCHESTER MN 55903
 Phone 507-288-9590

Kato, Inc.

Tank Information

<u>Client Tank</u>	<u>MPCA Tank</u>	<u>A/U</u>	<u>Status</u>	<u>Substance Stored</u>	<u>Capacity</u>	<u>Registration</u>	<u>Removed Date</u>	<u>Installed Date</u>
001	001	Under Ground	Abandoned	Other Substance	20,000	1/29/1986		09/01/1981
002	002	Under Ground	Abandoned <i>active</i>	Other Substance	20,000	1/29/1986		09/01/1981
003	003	Under Ground	Removed	Used Or Waste Oil	1,000	1/19/1999	12/10/1998	01/01/1900
004	004	Under Ground	Removed	Fuel Oil	10,000	0/13/1999	07/07/1999	

300 gal/yr.
GREY WATER since '94/95



07 May, 2001

PETROL PUMPER

Service Station/Bulk

Site ID: 12031

Type of Site: Underground Only

Address 4101 148TH ST NW
 CLEARWATER, MN 55320
 County Wright
 Site Phone 612-878-1655

Region M
 AST Registration
 UST Registration 1/29/86

***** OWNER INFORMATION *****

Owner Name B & F DISTRIBUTING INC
 Owner ID 185108
 Address PO BOX 6536
 ROCHESTER, MN 55903

***** TANK INFORMATION SUMMARY *****

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
001	U	Abandoned	Other Substance	20,000	09/01/1981		01/29/1986
002	U	Abandoned	Other Substance	20,000	09/01/1981		01/29/1986
003	U	Removed	Used Or Waste Oil	1,000	01/01/1900	12/10/1998	01/19/1999
			Removal Contractor: ADVANCED TANK SERVICE INC				
004	U	Removed	Fuel Oil	10,000		07/07/1999	10/13/1999
			Removal Contractor: ADVANCED TANK SERVICE INC				

***** 001 - COMMON TANK INFORMATION *****

Our Tank Nbr 001 U	Client Tank Nbr. 001
Dispenser Type Suction	Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Other Substance
Used For Heating? N	Tank Status Abandoned
Tank Disposal Company	2nd Cont Tank
Tank Cath Prot	Pipe Cath Prot None
Pipe Material Steel/Iron	Piping Material Desc
HW Generator ID	Product Replaced Date 01/01/1994
Tank Registration Date 01/29/1986	Unreg Tank Report Date

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity 20000
Compart Number 1	Compart Stored Desc GREY WATER
Compart Stored Prod Other Substance	
Compart Other Desc	

---- Overfill Information ----

Overfill Prot Alarm
 Overfill Prot Ballfloat
 Overfill Prot No Info Y
 Overfill Prot Type Unk

Overfill Prot Autosht
 Overfill Prot Manual
 Overfill Prot None

---- Tank Release Protection ----

Daily Stick Y
 Tightness Test Y
 Manual Gauging N
 Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date 07/
 SIR Vendor Nbr 1
 Other Desc
 Other Flag N

---- Piping Release Protection ----

Auto Line Leak Detection N
 Annual Tightness Test N
 Vapor Monitoring N
 Groundwater Monitor N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction Y
 SIR Approve Date 07/2
 SIR Vendor Nbr 1



PETROL PUMPER

Service Station/Bulk

Site ID: 12031

Type of Site: Underground Only

***** 002 - COMMON TANK INFORMATION *****

Our Tank Nbr 002 U
Dispenser Type Suction
Tank Const Mtl Bare/Paint/Asph Coat Steel
Used For Heating? N
Tank Disposal Company
Tank Cath Prot
Pipe Material Steel/Iron
HW Generator ID
Tank Registration Date 01/29/1986

Client Tank Nbr 002
Total Capacity 20,000
Stored Product Other Substance
Tank Status Abandoned
2nd Cont Tank
Pipe Cath Prot None
Piping Material Desc
Product Replaced Date 01/01/1994
Unreg Tank Report Date

----- 002 - UST TANK INFORMATION -----

of Tank Compartments 1
Compartment Number 1
Compartment Stored Prod Other Substance
Compartment Other Desc

Compartment Capacity 20000
Compartment Stored Desc GREY WATER

---- Overfill Information ----

Overfill Prot Alarm
Overfill Prot Ballfloat
Overfill Prot No Info Y
Overfill Prot Type Unk

Overfill Prot Autosht
Overfill Prot Manual
Overfill Prot None

---- Tank Release Protection ----

Daily Stick Y
Tightness Test Y
Manual Gauging N
Auto Gauging N
Soil Vapor Monitor N
Groundwater Monitor N
Interstit Monitor N
SIR Approve Date 07/
SIR Vendor Nbr 1
Other Desc
Other Flag N

---- Piping Release Protection ----

Auto Line Leak Detection N
Annual Tightness Test N
Vapor Monitoring N
Groundwater Monitor N
Interstit Monitor N
3 Year Tightness Test N
European Suction Y
SIR Approve Date 07/2
SIR Vendor Nbr 1

***** 003 - COMMON TANK INFORMATION *****

Our Tank Nbr 003 U
Dispenser Type Gravity
Tank Const Mtl Bare/Paint/Asph Coat Steel
Used For Heating? N
Tank Disposal Company
Tank Cath Prot
Pipe Material Steel/Iron
HW Generator ID
Tank Registration Date 01/19/1999

Client Tank Nbr 003
Total Capacity 1,000
Stored Product Used Or Waste Oil
Tank Status Removed
2nd Cont Tank
Pipe Cath Prot None
Piping Material Desc
Product Replaced Date
Unreg Tank Report Date

----- 003 - UST TANK INFORMATION -----

of Tank Compartments 1
Compartment Number 1
Compartment Stored Prod Used Or Waste Oil
Compartment Other Desc

Compartment Capacity 1000
Compartment Stored Desc WASTE OIL

---- Overfill Information ----

Overfill Prot Alarm
Overfill Prot Ballfloat
Overfill Prot No Info Y

Overfill Prot Autosht
Overfill Prot Manual
Overfill Prot None



PETROL PUMPER

Service Station/Bulk

Site ID: 12031

Type of Site: Underground Only

Overfill Prot Type Unk
 --- Tank Release Protection ---
 Daily Stick N
 Tightness Test N
 Manual Gauging N
 Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date
 SIR Vendor Nbr 0
 Other Desc
 Other Flag N

--- Piping Release Protection ---
 Auto Line Leak Detection N
 Annual Tightness Test N
 Vapor Monitoring N
 Groundwater Monitor N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction N
 SIR Approve Date
 SIR Vendor Nbr 0

***** 004 - COMMON TANK INFORMATION *****

Our Tank Nbr 004 U
 Dispenser Type Suction
 Tank Const Mtl Bare/Paint/Asph Coat Steel
 Used For Heating?
 Tank Disposal Company Advanced Tank Services
 Tank Cath Prot
 Pipe Material Copper
 HW Generator ID
 Tank Registration Date 10/13/1999

Client Tank Nbr 004
 Total Capacity 10,000
 Stored Product Fuel Oil
 Tank Status Removed
 2nd Cont Tank
 Pipe Cath Prot Unknown
 Piping Material Desc 10
 Product Replaced Date
 Unreg Tank Report Date 10/14/1999

----- 004 - UST TANK INFORMATION -----

of Tank Compartments 1
 Compart Number 1
 Compart Stored Prod Fuel Oil
 Compart Other Desc

Compart Capacity 10000
 Compart Stored Desc Fuel Oil

--- Overfill Information ---
 Overfill Prot Alarm
 Overfill Prot Ballfloat
 Overfill Prot No Info Y
 Overfill Prot Type Unk

Overfill Prot Autoshut
 Overfill Prot Manual
 Overfill Prot None Y

--- Tank Release Protection ---
 Daily Stick
 Tightness Test
 Manual Gauging
 Auto Gauging
 Soil Vapor Monitor
 Groundwater Monitor
 Interstit Monitor
 SIR Approve Date
 SIR Vendor Nbr
 Other Desc
 Other Flag

--- Piping Release Protection ---
 Auto Line Leak Detection
 Annual Tightness Test
 Vapor Monitoring
 Groundwater Monitor
 Interstit Monitor
 3 Year Tightness Test
 European Suction
 SIR Approve Date
 SIR Vendor Nbr

***** CORRESPONDENCE *****

Number 1
 Company
 Type Registration Form

Date 01/01/1901
 Person At Co
 PCS



PETROL PUMPER**Service Station/Bulk**

Site ID: 12031

Type of Site: Underground Only

Number 2
Company B & F DISTR
Type Registration Form

Date 07/20/1994
Person At Co JAY K CLARK
PCS

Signature JAY K CLARK

Title VICE PRESIDENT/B & F DIST

Date Form Received 6/14/94 (CHANGED OF OWNERSHIP, SITE NAME, AND CHANGED
TANK 001-002 PRODUCTS PREVIOUSLY CONTAINED BOTH FUEL OIL B & F DIST
CLEANED TANKS AND TAKEN OUT OF PETROLEUM SERVICE BOTH TANKS ARE NOW
CONNECTED TO GREY WATER DISCHARGE SEWER LINE FROM BLDG THEY NOW CONTAIN AN
UNREGULATED SUBSTANCE AND WILL BE USED FROM TODAY FORWARD AS GREY WATER
STORAGE PER COMMENT ON THE BACK FORM)

Number 3
Company PETROL PUMPER
Type Registration Form

Date 01/20/1999
Person At Co MATT GIKAS
PCS

Signature MATT GIKAS

Title GEN MGR

Date Form Received 1/19/99 (TANK 003 REMOVAL AND NOTIFICATION OF TANK)

Number 4
Company Petrol Pumper
Type Registration Form

Date. 07/07/1999
Person At Co Matt Gikas
PCS Aaron Am

Signature Matt Gikas, Gen Manager

Date 07/07/1999

Notification form recieved stating that ust 004 wasremoved on 7/7/1999 This tank was
previously unregistered