



06 July, 2005

PETROL PUMPER *Olson's Truck Stop*
 Site ID 12032

Autocare/Autoparts
 Type of Site Underground Only

Address 194 & CO RD 8 EXIT 183
 CLEARWATER, MN 55380
 County Wright
 Site Phone ~~612~~ 878-1655

Region M
 AST Registration
 UST Registration 1/29/1986

***** OWNER INFORMATION *****

Owner Name KATO INC
 Owner ID 186802
 Address PO BOX 6758
 ROCHESTER, MN 55903

LuAnn Bock, Mgr
stop + 60 new owners May 20, 2005
Ron + Dave Olson
763-245-9579 cell
763-242-1570 all

***** TANK INFORMATION SUMMARY *****

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
001	U	Removed	Diesel	20,000	02/10/1976	01/01/1988	01/29/1986
002	U	Active	Diesel #2	20,000	02/10/1976		01/29/1986
003	U	Active	Alcohol Blend reg	20,000	02/10/1976		01/29/1986
004	U	Active	Alcohol Blend super	10,000	02/10/1976		01/29/1986
005	U	Active	Alcohol Blend prem	10,000	02/10/1976		01/29/1986
006	U	Removed Active	Diesel #1 or perform <i>sold</i>	10,000	02/10/1976	12/10/1998	01/29/1986
007	U	Removed	Fuel Oil	10,000	01/01/1900	07/07/1999	06/14/1994
008	U	Removed	Used Or Waste Oil	550	01/01/1900	12/10/1998	06/14/1994

Jerry's Tow My Lease Shop

***** 001 - COMMON TANK INFORMATION *****

Our Tank Nbr 001 U	Client Tank Nbr 001
Dispenser Type Submersible	Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Diesel
Used For Heating? U	Tank Status Removed
Tank Disposal Company	2nd Cont Tank:
Tank Cath Prot Anode	Pipe Cath Prot None
Pipe Material Steel/Iron	Piping Material Desc
HW Generator ID	Product Replaced Date
Tank Registration Date 01/29/1986	Unreg Tank Report Date

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity 20000
Compart Number 1	Compart Stored Desc DIESEL
Compart Stored Prod Diesel	
Compart Other Desc	

---- Overfill Information ----	Overfill Prot Autoshut
Overfill Prot Alarm	Overfill Prot Manual
Overfill Prot Ballfloat	Overfill Prot None
Overfill Prot No Info Y	
Overfill Prot Type Unk	
---- Tank Release Protection ----	---- Piping Release Protection ----
Daily Stick Y	Auto Line Leak Detection N
Tightness Test Y	Annual Tightness Test N
Manual Gauging N	Vapor Monitoring N
Auto Gauging N	Groundwater Monitor N
Soil Vapor Monitor N	Interstit Monitor N
Groundwater Monitor N	3 Year Tightness Test N
Interstit Monitor N	European Suction N
SIR Approve Date	SIR Approve Date
SIR Vendor Nbr 0	SIR Vendor Nbr 0



PETROL PUMPER

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

Other Desc
Other Flag N

***** 002 - COMMON TANK INFORMATION *****

Our Tank Nbr 002 U Client Tank Nbr 002
Dispenser Type Submersible Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel Stored Product Diesel
Used For Heating? U Tank Status Active
Tank Disposal Company 2nd Cont Tank
Tank Cath Prot Impressed Current Pipe Cath Prot Impressed Current
Pipe Material Coated Steel Piping Material Desc
HW Generator ID Product Replaced Date
Tank Registration Date 01/29/1986 Unreg Tank Report Date

----- 002 - UST TANK INFORMATION -----

of Tank Compartments 1
Compart Number 1
Compart Stored Prod Diesel
Compart Other Desc
Compart Capacity 20000
Compart Stored Desc DIESEL

--- Overfill Information ---

Overfill Prot Alarm Overfill Prot Autoshut
Overfill Prot Ballfloat Y Overfill Prot Manual
Overfill Prot No Info Overfill Prot None
Overfill Prot Type Unk

--- Tank Release Protection ---

Daily Stick Y Auto Line Leak Detection Y
Tightness Test Y Annual Tightness Test N
Manual Gauging N Vapor Monitoring N
Auto Gauging N Groundwater Monitor N
Soil Vapor Monitor N Interstit Monitor N
Groundwater Monitor N 3 Year Tightness Test N
Interstit Monitor N European Suction N
SIR Approve Date 01/01/1999 SIR Approve Date 01/01/1999
SIR Vendor Nbr 0 SIR Vendor Nbr 0
Other Desc SIRAS
Other Flag Y

***** 003 - COMMON TANK INFORMATION *****

Our Tank Nbr 003 U Client Tank Nbr 003
Dispenser Type Submersible Total Capacity 20,000
Tank Const Mtl Bare/Paint/Asph Coat Steel Stored Product Alcohol Blend
Used For Heating? N Tank Status Active
Tank Disposal Company 2nd Cont Tank
Tank Cath Prot Impressed Current Pipe Cath Prot Impressed Current
Pipe Material Steel/Iron Piping Material Desc
HW Generator ID Product Replaced Date
Tank Registration Date 01/29/1986 Unreg Tank Report Date

----- 003 - UST TANK INFORMATION -----

of Tank Compartments 1
Compart Number 1
Compart Stored Prod Alcohol Blend
Compart Other Desc
Compart Capacity 20000
Compart Stored Desc ALCOHOL BLEND

--- Overfill Information ---

Overfill Prot Alarm Overfill Prot Autoshut



PETROL PUMPER

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

Overfill Prot Ballfloat Y	Overfill Prot Manual
Overfill Prot No Info	Overfill Prot None
Overfill Prot Type Unk	
---- Tank Release Protection ----	---- Piping Release Protection ----
Daily Stick Y	Auto Line Leak Detection Y
Tightness Test Y	Annual Tightness Test N
Manual Gauging N	Vapor Monitoring N
Auto Gauging N	Groundwater Monitor N
Soil Vapor Monitor N	Interstit Monitor N
Groundwater Monitor N	3 Year Tightness Test N
Interstit Monitor N	European Suction N
SIR Approve Date 01/01/1999	SIR Approve Date 01/01/1999
SIR Vendor Nbr 0	SIR Vendor Nbr 0
Other Desc SIRAS	
Other Flag Y	

***** 004 - COMMON TANK INFORMATION *****

Our Tank Nbr 004 U	Client Tank Nbr 004
Dispenser Type Submersible	Total Capacity 10,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Alcohol Blend
Used For Heating? N	Tank Status Active
Tank Disposal Company	2nd Cont Tank
Tank Cath Prot Impressed Current	Pipe Cath Prot Impressed Current
Pipe Material Steel/Iron	Piping Material Desc
HW Generator ID	Product Replaced Date
Tank Registration Date 01/29/1986	Unreg Tank Report Date

----- 004 - UST TANK INFORMATION -----

# of Tank Compartments 1	Compart Capacity 10000
Compart Number 1	Compart Stored Desc ALCOHOL BLEND
Compart Stored Prod Alcohol Blend	
Compart Other Desc	

---- Overfill Information ----	Overfill Prot Autoshut
Overfill Prot Alarm	Overfill Prot Manual
Overfill Prot Ballfloat Y	Overfill Prot None
Overfill Prot No Info	
Overfill Prot Type Unk	
---- Tank Release Protection ----	---- Piping Release Protection ----
Daily Stick Y	Auto Line Leak Detection Y
Tightness Test Y	Annual Tightness Test N
Manual Gauging N	Vapor Monitoring N
Auto Gauging N	Groundwater Monitor N
Soil Vapor Monitor N	Interstit Monitor N
Groundwater Monitor N	3 Year Tightness Test N
Interstit Monitor N	European Suction N
SIR Approve Date 01/01/1999	SIR Approve Date 01/01/1999
SIR Vendor Nbr 0	SIR Vendor Nbr 0
Other Desc SIRAS	
Other Flag Y	

***** 005 - COMMON TANK INFORMATION *****

Our Tank Nbr 005 U	Client Tank Nbr 005
Dispenser Type Submersible	Total Capacity 10,000
Tank Const Mtl Bare/Paint/Asph Coat Steel	Stored Product Alcohol Blend
Used For Heating? U	Tank Status Active



PETROL PUMPER

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

Tank Disposal Company
Tank Cath Prot Impressed Current
Pipe Material Steel/Iron
HW Generator ID
Tank Registration Date 01/29/1986

2nd Cont Tank
Pipe Cath Prot Impressed Current
Piping Material Desc
Product Replaced Date
Unreg Tank Report Date

005 - UST TANK INFORMATION

of Tank Compartments 1
Compart Number 1
Compart Stored Prod Alcohol Blend
Compart Other Desc

Compart Capacity 10000
Compart Stored Desc ALCOHOL BLEND

--- Overfill Information ---

Overfill Prot Alarm
Overfill Prot Ballfloat Y
Overfill Prot No Info
Overfill Prot Type Unk

Overfill Prot Autoshut
Overfill Prot Manual
Overfill Prot None

--- Tank Release Protection ---

Daily Stick Y
Tightness Test Y
Manual Gauging N
Auto Gauging N
Soil Vapor Monitor N
Groundwater Monitor N
Interstit Monitor N
SIR Approve Date 01/01/1999
SIR Vendor Nbr 0
Other Desc SIRAS
Other Flag Y

--- Piping Release Protection ---

Auto Line Leak Detection Y
Annual Tightness Test N
Vapor Monitoring N
Groundwater Monitor N
Interstit Monitor N
3 Year Tightness Test N
European Suction N
SIR Approve Date 01/01/1999
SIR Vendor Nbr 0

***** 006 - COMMON TANK INFORMATION *****

Our Tank Nbr 006 U
Dispenser Type Submersible
Tank Const Mtl Bare/Paint/Asph Coat Steel
Used For Heating? U
Tank Disposal Company
Tank Cath Prot Impressed Current
Pipe Material Steel/Iron
HW Generator ID
Tank Registration Date 01/29/1986

ACTIVE

Client Tank Nbr 006
Total Capacity 10,000
Stored Product Diesel
Tank Status ~~Removed~~ **Active**
2nd Cont Tank
Pipe Cath Prot Impressed Current
Piping Material Desc
Product Replaced Date
Unreg Tank Report Date

006 - UST TANK INFORMATION

of Tank Compartments 1
Compart Number 1
Compart Stored Prod Diesel
Compart Other Desc

Compart Capacity 10000
Compart Stored Desc DIESEL

--- Overfill Information ---

Overfill Prot Alarm
Overfill Prot Ballfloat Y
Overfill Prot No Info
Overfill Prot Type Unk

Overfill Prot Autoshut
Overfill Prot Manual
Overfill Prot None

--- Tank Release Protection ---

Daily Stick Y
Tightness Test Y
Manual Gauging N

--- Piping Release Protection ---

Auto Line Leak Detection Y
Annual Tightness Test N
Vapor Monitoring N



PETROL PUMPER

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date
 SIR Vendor Nbr 0
 Other Desc SIRAS
 Other Flag Y

Groundwater Monitor N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction N
 SIR Approve Date
 SIR Vendor Nbr 0

***** 007 - COMMON TANK INFORMATION *****

Our Tank Nbr 007 U
 Dispenser Type Suction
 Tank Const Mtl Bare/Paint/Asph Coat Steel
 Used For Heating? Y
 Tank Disposal Company
 Tank Cath Prot None
 Pipe Material Steel/Iron
 HW Generator ID
 Tank Registration Date 06/14/1994

Client Tank Nbr 007
 Total Capacity 10,000
 Stored Product Fuel Oil
 Tank Status Removed
 2nd Cont Tank
 Pipe Cath Prot None
 Piping Material Desc
 Product Replaced Date
 Unreg Tank Report Date

----- 007 - UST TANK INFORMATION -----

of Tank Compartments 1
 Compartment Number 1
 Compartment Stored Prod Fuel Oil
 Compartment Other Desc

Compartment Capacity 10000
 Compartment Stored Desc FUEL OIL

---- Overfill Information ----

Overfill Prot Alarm
 Overfill Prot Ballfloat
 Overfill Prot No Info Y
 Overfill Prot Type Unk

Overfill Prot Autoshut
 Overfill Prot Manual
 Overfill Prot None

---- Tank Release Protection ----

Daily Stick N
 Tightness Test N
 Manual Gauging N
 Auto Gauging N
 Soil Vapor Monitor N
 Groundwater Monitor N
 Interstit Monitor N
 SIR Approve Date
 SIR Vendor Nbr 0
 Other Desc SIRAS
 Other Flag Y

---- Piping Release Protection ----

Auto Line Leak Detection N
 Annual Tightness Test N
 Vapor Monitoring N
 Groundwater Monitor N
 Interstit Monitor N
 3 Year Tightness Test N
 European Suction N
 SIR Approve Date
 SIR Vendor Nbr 0

***** 008 - COMMON TANK INFORMATION *****

Our Tank Nbr 008 U
 Dispenser Type Suction
 Tank Const Mtl Bare/Paint/Asph Coat Steel
 Used For Heating? N
 Tank Disposal Company
 Tank Cath Prot None
 Pipe Material Steel/Iron
 HW Generator ID
 Tank Registration Date 06/14/1994

Client Tank Nbr 008
 Total Capacity 550
 Stored Product Used Or Waste Oil
 Tank Status Removed
 2nd Cont Tank
 Pipe Cath Prot None
 Piping Material Desc
 Product Replaced Date
 Unreg Tank Report Date

----- 008 - UST TANK INFORMATION -----

of Tank Compartments 1



PETROL PUMPER

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

Compartment Number 1
Compartment Stored Product Used Or Waste Oil
Compartment Other Description

Compartment Capacity 550
Compartment Stored Description WASTE OIL

Overfill Information

Overfill Protection Alarm
Overfill Protection Ballfloat
Overfill Protection No Info Y
Overfill Protection Type Unk

Overfill Protection Autoshut
Overfill Protection Manual
Overfill Protection None

Tank Release Protection

Daily Stick N
Tightness Test N
Manual Gauging N
Auto Gauging N
Soil Vapor Monitor N
Groundwater Monitor N
Interstit Monitor N
SIR Approve Date
SIR Vendor Number 0
Other Description SIRAS
Other Flag Y

Piping Release Protection

Auto Line Leak Detection N
Annual Tightness Test N
Vapor Monitoring N
Groundwater Monitor N
Interstit Monitor N
3 Year Tightness Test N
European Suction N
SIR Approve Date
SIR Vendor Number 0

CORRESPONDENCE

Number 1
Company
Type Registration Form

Date 01/01/1901
Person At Company
PCS

Number 2
Company HASTY TRUCK T
Type Registration Form

Date 01/10/1994
Person At Company ERVIN RADUNZ
PCS

Signature ERVIN RADUNZ
Title

Date Form Received 12/20/93 (CHANGE OF STATUS-REMOVAL FOR TANK 001)

Number 3
Company PETROL PUMPER
Type Registration Form

Date 11/18/1994
Person At Company JAY CLARK
PCS

Signature JAY CLARK
Title VICE PRESIDENT

Date Form Received 6/7/94 (CHANGED OWNERSHIP, SITE NAME INITIAL REG FOR TANKS 007-008 B & F DIST PURCHASED THE PROPERTY ON A BANKRUPTCY PREVIOUS OWNER DID REG TANKS 007-008 TANKS 002-003-004-005-006 INSTALLED IMPRESSED CURRENT SYSTEM BY HARCO TECHNOLOGIES WITH B & F DIST ELECTRICIAN)

Number 4
Company PETROL PUMPER
Type Phone Call

Date 05/02/1997
Person At Company MATT-OMNI ENV
PCS

MATT, OMNI ENV CALLED 5/1/97 AND STATED ALL TANKS HAVE LEAK DETECTION-SIRAS

**PETROL PUMPER**

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

Number 5
Company B&F
Type Letter

Date 06/26/1997
Person At Co RAY COLBERT
PCS

-LETTER IN RESPONSE TO SELF-AUDIT FOLLOWING VIOLATIONS DISCOVERED

-FAILURE TO PERFORM ANNUAL FUNCITON TEST OF LINE LEAK DETECTOR

-FAILURE TO REGISTER TANKS 007-008 BY JUNE 1, 1986, OR WITHIN 30 DAYS OF
INSTALLATION OR DISCOVERY

Number 6
Company OMNI ENVIRONM
Type Field Notes

Date 06/12/1998
Person At Co MATT GIKAS
PCS

REQUESTED DATA BASE REPORT FOR COMPLIANCE REVIEW WITH O/O

Number 7
Company ADVANCED TANK
Type Phone Call

Date 01/29/1999
Person At Co MATT
PCS

PRE-NOTICE OF THE REMOVAL OF UST'S 001 - 002 TO BE DONE ON 12/10/98

Number 8
Company ADVANCED TANK
Type Phone Call

Date 06/29/1999
Person At Co JULIE
PCS

PRE-NOTICE OF THE REMOVAL QF UST 007 TO BE DONE ON 7/7/99

Number 9
Company PETROL PUMPER
Type Audit

Date 04/11/1997
Person At Co RAYMOND COLBER
PCS RS

4/11/97 AUDIT WAS RECEIVED

Number 10
Company Kato, Inc
Type Letter

Date 09/22/1998
Person At Co Raymond Colber
PCS EEB

9/22/98 EEB-Audit file closure letter sent

Number 11
Company EDWIN BALCOS
Type Field Notes

Date 05/07/2001
Person At Co
PCS JCH

5/7/2001 EDWIN BALCOS, TANKS LEARNED SITE #12032 AND 12031 IS THE SAME SITE
12031 TO BE DELETED-

REMARKS ON 12031 SITE- LISTED BELOW

7/20/94, JAY K CLARK, B&F DIST -

FORM RECEIVED 8/14/94- CHANGE OF OWNERSHIP, SITE NAME AND CHANGED TANK 001-002
PRODUCTS PREVIOUSLY CONTAINED BOTH FUEL OIL- B&F DIST CLEANED TANKS AND TAKEN



PETROL PUMPER

Autocare/Autoparts

Site ID 12032

Type of Site Underground Only

OUT OF PETROLEUM SERVICE BOTH TANKS ARE NOW CONNECTED TO GREY WATER DISCHARGE SEWER LINE FROM BLDG THEY NOW CONTAIN AN UNREG SUBSTANCE AND WILL BE USED FROM TODAY FORWARD AS GREY WATER STORAGE PER COMMENT

1/20/00- MATT GIKAS, PETROL PUMPER-
FORM RECIEVED 1/19/99- TANK 003 REMOVED AND NOTIFICATION OF TANK

7/7/99, MATT GIKAS, PETROL PUMPER
FORM RECEIVED 7/7/99- NOTIFICATION FORM RECEIVED STATING TANK 004 WAS REMOVED ON 7/7/99 TANK WAS NOT PREVIOUSLY REG

***** INSPECTIONS *****

Date 10-APR-97
Type Routine
Reason Audit Visit

Date 12-JUN-98
Type Routine
Reason Site Visit
