

Kerry Patterson

Dave Korbky  
4-12-88

Waste Management  
Leak 990

OK go with wells. Must be

Steel wells. Sample VOC THC gas, fuel.

borings or test pits needed north, northeast  
of building to investigate abandoned tank  
in buildg.

.45 gal/hr tank leak = 3942 gal per year

base on the discription of tank (crack in  
seam) this tank was probably damaged  
during installation i.e. there's possibly

30,000 + gallons of fuel and gas somewhere.

Sample wells 209940, 207947, & 207946 for  
VOC THC gas fuel.

these guys will probably need bedrock  
wells at some point but we can  
keep it superficial to start.

Note they are already anticipating having  
to go off site.