



Leaking Petroleum Storage Tanks

Minnesota Pollution Control Agency

http://www.pca.state.mn.us/programs/lust_p.html

Annual Monitoring Report

Fact Sheet 3.26

After the Corrective Action Design (CAD) has been approved, update and submit this worksheet annually. If a remedial system has been installed, submit fact sheet 3.31 *CAD System Monitoring Worksheet* along with this worksheet.

Under certain circumstances Minnesota Pollution Control Agency (MPCA) staff may request submittal of the monitoring information on a quarterly schedule. This should be conducted according to fact sheet 3.25, *Quarterly Monitoring Report*.

MPCA Site ID: Leak00014698

Date: March 9, 2005 *3/9/05*

Responsible Party: North American State Bank R.P. phone #: (320) 254-8271

Consultant: Coteau Environmental Consultant phone #: (320) 846-4668


Facility Name: Former K-C Kwik Stop

Facility Address: 230 1st Street City: Brooten, Minnesota

County: Stearns Zip Code: 56316

Site location: The required coordinate scheme for reporting site location is Universal Transverse Mercator (UTM), Extended Zone 15, 1983 North American Datum (NAD83). Refer to http://www.ot.state.mn.us/ot_files/handbook/standard/std17-1.html for Minnesota spatial data standards, or <http://mac.usgs.gov/mac/isb/pubs/factsheets/fs15799.html> for more information about UTM Coordinates.

X coordinate (Easting) 15 333791E meters
Y coordinate (Northing) 5040564N meters



6

2000-10-16

What feature does the coordinate represent? (i.e. center of parcel, approximate center of source area, etc. Please describe)

The coordinates represent the approximate center of the source area.

What method was used to determine the coordinate? (i.e. GPS receiver, map interpolation, address matching, etc. Please describe)

The coordinates were determined utilizing a digital topographic map at the website www.topozone.com.

If a paper map, digital map, aerial photo or digital orthophotoquad was used to find the site location, please provide the scale of the map or photo (i.e. 1:24,000, etc.)

The scale of the map is 1:25,000.

Section 1. GROUND WATER MONITORING

Discuss the groundwater monitoring results, including water level measurements and analytical results, performed since the remedial investigation (RI) report or the last progress report submitted. Indicate whether samples were purged or unpurged (see fact sheet 3.23). If purged, indicate purging method.

Fluid levels were measured in all monitor wells on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004. Based on fluid levels measured in the monitor wells on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004, ground water flow is to the southeast. The predominant flow direction at the site appears to be to the southeast. Ground water elevations are illustrated by the water table contour maps shown on Figure 3A, 3B, 3C, 3D, 3E and 3F. Historical ground water elevations are illustrated on Figure 4.

Ground water samples were collected for laboratory analysis from monitor wells MW-1, MW-2, MW-3, MW-4, MW-5 and MW-6 on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004. Ground water samples were purged by removing a minimum of five (5) well casing volumes from the well prior to sampling using a dedicated polyethylene bailer.

BTEX impacts in ground water from MW-1, MW-2, MW-4 and MW-6 on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 were below the Health Risk Limit (HRL) for these constituents. Benzene was detected in MW-3 on August 14 and November 4, 2003 at concentrations of 29.0 and 38.0 parts per billion (ppb), respectively. TPH as GRO was detected in monitor well MW-3 on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 at concentrations of 2,171.0, 837.0, 2,500, 970, 260 and 740 ppb, respectively. TPH as GRO was detected in monitor well MW-4 August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 at concentrations of 147.0, 418.0, 380, 690, 710 and 640 ppb, respectively. Benzene was detected in MW-5 on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 at concentrations of 900.0, 2,313.0, 1,600, 1,100, 1,300 and 960 ppb, respectively. Toluene was detected in MW-5 on

November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 at concentrations of 16,671.0, 7,800, 9,300, 8,800 and 6,900 ppb, respectively. Ethyl benzene was detected in MW-5 on November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 at concentrations of 1,740.0, 1,400, 1,100, 870 and 910 ppb, respectively. TPH as GRO was detected in monitor well MW-5 on August 14 and November 4, 2003 and February 9, May 11, August 2 and November 3, 2004 at concentrations of 21,505.0, 38,200.0, 33,000, 27,000, 26,000 and 19,000 ppb, respectively. Naphthalene was detected in monitor well MW-5 on November 3, 2004 at a concentration of 690 ppb. These concentrations of benzene, toluene, ethyl benzene and naphthalene are above the HRL's of 10, 1,000, 700 and 300 ppb, respectively. Historic fluctuations in benzene and TPH as GRO concentrations are shown on Figures 5 and 6, respectively. Ground water contaminant concentrations are included in Table 3 and 4.

A duplicate ground water quality assurance/quality control (QA/QC) sample was collected from one (1) monitor well during each monitoring event, and was laboratory analyzed for BTEX and TPH as GRO. In addition, a trip blank QA/QC sample was laboratory analyzed for BTEX. The duplicate ground water sample and trip blank historical data are illustrated in Table 3. No field or laboratory interference's were identified in the QA/QC samples.

Section 2. VAPOR IMPACT MONITORING

If vapor impacts were detected during previous assessments, discuss the results of follow-up vapor monitoring. Include in your discussion the sampling instrument and sampling method.

A vapor survey was completed in the vicinity of the former KC Kwik Stop site on February 9, May 11, August 2 and November 3, 2004. Two (2) sanitary sewer manholes and two (2) storm sewer basins at the junction of Highway 55 and South Western Avenue and the basements of residences at 100, 110, 111 and 120 South Western Avenue were screened for organic vapors using a photoionization detector and explosimeter (Figure 2). No elevated vapor concentrations were identified in the sewer manholes, storm sewer basins or residences 100, 111 and 120. Elevated organic vapor concentrations were encountered in the basement of 110 South Western Avenue on February 9, May 11 and November 3, 2004 at concentration of 550.7, 33.8 and 128.7 parts per million (ppm), respectively (Table 6). It appears that the vapors originated from a former cistern in the basement floor. It appears that the PID readings in the basement of 110 South Western Avenue may be a result of petroleum impacts originating from the former KC Kwik Stop property as this residence is down gradient of the former KC Kwik Stop property.

NOTE: If vapor concentrations exceed 10 percent of the lower explosive limit, exit the building and contact the local fire department immediately. Then contact the Minnesota Duty Officer (24 hours) at 651/649-5451 (metro and outside Minnesota) or 1-800/422-0798

(Greater Minnesota). TTY users call 651/297-5353 (V/TTY) or 1-800/627-3529 (V/TTY).
Vapor mitigation is required.

Section 3. RECOMMENDATIONS

Discuss your recommendations. Your recommendation should be based on fact sheet #3.1, *Leaking Underground Storage Tank Program*.

Based on laboratory analytical results of ground water samples collected from the monitor wells and the vapor screening results conducted, Coteau recommends continued ground water sampling for laboratory analysis of BTEX, total petroleum hydrocarbons (TPH) using gasoline range organics (GRO) and naphthalene and vapor screening of residence 110 South Western Avenue for volatile organic compounds (VOC's) using a photoionization detector (PID). In addition, based on MPCA correspondence dated December 18, 2003, Coteau recommends vapor screening of the basement of the 111 South Western Avenue residence south of the site.

If additional corrective action is recommended, please provide your justification.

Additionally, Coteau recommends one (1) soil boring to a depth of approximately 6 feet through the concrete floor of the basement of 110 South Western Avenue residence due to the vapor screening results conducted on February 9, May 11 and November 3, 2004. Soil samples will be collected in 2 foot intervals and screened for volatile organic compounds (VOC's) using a photoionization detector (PID). One (1) soil sample would be collected for laboratory analysis of BTEX and total petroleum hydrocarbons (TPH) using gasoline range organics (GRO) methodology. If petroleum impacts are identified in the soil beneath the basement, Coteau recommends that the basement be ventilated using a blower and may recommend active remediation utilizing a vacuum enhanced vapor recovery system.

If significant reduction of risk has been achieved at the site, recommendations and rationale for the reduction or termination of corrective actions may be presented.

If additional monitoring is recommended, indicate the proposed monitoring schedule and frequency.

If closure is recommended, summarize significant site investigative events and describe how site specific risk issues have been adequately addressed or minimized to acceptable low risk levels.

Section 4: CONSULTANT (OR OTHER) INFORMATION

By signing this document, I/we acknowledge that we are submitting this document on behalf of and as agents of the responsible person or volunteer for this leaksite. I/we acknowledge that if information in this document is inaccurate or incomplete, it will delay the completion of

remediation and may harm the environment and may result in reduction of reimbursement awards. In addition, I/we acknowledge on behalf of the responsible person or volunteer for this leaksite that if this document is determined to contain a false material statement, representation, or certification, or if it omits material information, the responsible person or volunteer may be found to be in violation of Minn. Stat. § 115.075 (1994) or Minn. Rules 7000.0300 (Duty of Candor), and that the responsible person or volunteer may be liable for civil penalties.


MPCA staff are instructed to reject unsigned monitoring reports or if the report form has been altered.

Name and Title:

Scott Hunke
Environmental Technician
Andy Schmidt, EIT
Environmental Engineer

Nathan T. Hunke, P.G., M.S.
Senior Hydrogeologist

Signature:



Date signed:

3/9/05

3/9/05

3/9/05

Company and mailing address:

Coteau Environmental
728 Janes Circle Dr. SW
Alexandria, MN 58203

Phone:

(320) 846-4668

Fax:

(320) 846-4668

Upon request, this document can be made available in other formats, including Braille, large print and audio tape. TTY users call 651/282-5332 or Greater Minnesota 1-800/657-3864 (voice/TTY).

Printed on recycled paper containing at least 10 percent fibers from paper recycled by consumers.

Attach Tables:

- Table 1 - Monitoring Well Completion Information
- Table 2 - Summary of Water Levels Measurements
- Table 3 - Analytical Results of Water Samples
- Table 4 - Other Contaminants Detected in Water Samples
(Petroleum or Non-petroleum Derived)
- Table 5 - Results of Natural Attenuation
- Table 6 - Results of Vapor Monitoring

Tables

Table 1
Monitoring Well Completion Information

Well Number	Unique Well Number	Date Installed	Surface Elevation	Top of Riser Elevation	Bottom of Well (Elevation)	Screen Interval (Elev. - Elev.)
MW-1	672919	8/7/02	99.88	100.00	80.88	95.88-80.88
MW-2	672922	8/7/02	99.67	102.46	80.67	95.67-80.67
MW-3	672921	8/7/02	99.69	102.58	80.69	95.69-80.69
MW-4	672920	8/7/02	99.99	102.73	80.99	95.99-80.99
MW-5	672918	8/7/02	99.57	99.64	80.57	95.57-80.57
MW-6	672950	2/4/03	99.74	99.76	80.74	95.74-80.74

Notes: (location and elevation of benchmark)

Table 2
Water Level Measurements

Well Number	Date	Depth of Water from Top of Riser	Product Thickness	Depth of Water Below Grade	Relative Groundwater Elevation	Water Level Above Screen (Y/N)
MW-1	8/14/03	10.21	0.0	10.09	89.79	No
MW-1	11/4/03	11.48	0.0	11.36	88.52	No
MW-1	2/9/04	12.13	0.0	12.01	87.87	No
MW-1	5/11/04	11.69	0.0	11.57	88.31	No
MW-1	8/2/04	10.45	0.0	10.33	89.55	No
MW-1	11/3/04	10.52	0.0	10.40	89.48	No
MW-2	8/14/03	12.90	0.0	10.11	89.56	No
MW-2	11/4/03	14.15	0.0	11.36	88.31	No
MW-2	2/9/04	14.75	0.0	11.96	87.71	No
MW-2	5/11/04	14.33	0.0	11.54	88.13	No
MW-2	8/2/04	13.16	0.0	10.37	89.30	No
MW-2	11/3/04	13.20	0.0	10.41	89.26	No
MW-3	8/14/03	13.08	0.0	10.19	89.50	No
MW-3	11/4/03	14.39	0.0	11.50	88.19	No
MW-3	2/9/04	15.05	0.0	12.16	87.53	No
MW-3	5/11/04	14.65	0.0	11.76	87.93	No
MW-3	8/2/04	13.42	0.0	10.53	89.16	No
MW-3	11/3/04	13.49	0.0	10.60	89.09	No
MW-4	8/14/03	13.21	0.0	10.47	89.52	No
MW-4	11/4/03	14.47	0.0	11.73	88.26	No
MW-4	2/9/04	15.14	0.0	12.40	87.59	No
MW-4	5/11/04	14.73	0.0	11.99	88.00	No
MW-4	8/2/04	13.55	0.0	10.81	89.18	No
MW-4	11/3/04	13.58	0.0	10.84	89.15	No
MW-5	8/14/03	10.06	0.0	9.99	89.58	No
MW-5	11/4/03	11.35	0.0	11.28	88.29	No
MW-5	2/9/04	12.00	0.0	11.93	87.64	No
MW-5	5/11/04	11.58	0.0	11.51	88.06	No
MW-5	8/2/04	10.32	0.0	10.25	89.32	No
MW-5	11/3/04	10.38	0.0	10.31	89.26	No
MW-6	8/14/03	10.58	0.0	10.56	89.18	No
MW-6	11/4/03	11.85	0.0	11.83	87.91	No
MW-6	2/9/04	12.51	0.0	12.49	87.25	No
MW-6	5/11/04	12.14	0.0	12.12	87.62	No
MW-6	8/2/04	10.91	0.0	10.89	88.85	No
MW-6	11/3/04	10.97	0.0	10.95	88.79	No

Describe the methods and procedures used to measure water levels and product thickness.

Notes:

Annual Monitoring Report

Page 8

February 2001

Table 3
Analytical Results of Water Samples

Well #	Date	Benzene	Toluene	Ethyl Benzene	Xylenes	MTBE	GRO	DRO	Lab Type
	8/14/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
MW-1	11/4/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
MW-1	2/9/04	<0.50	<0.50	<0.50	<1.0	<5.0	<100.0	NS	F
MW-1	5/11/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NS	F
MW-1	8/2/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NS	F
MW-1	11/3/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NS	F
MW-2	8/14/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
MW-2	11/4/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
MW-2	2/9/04	<0.50	<0.50	<0.50	<1.0	<5.0	<100.0	NA	F
MW-2	5/11/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NA	F
MW-2	8/2/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NA	F
MW-2	11/3/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NA	F
MW-3	8/14/03	22.0	211.0	444.0	NA	2,171.0	NA	NA	F
MW-3	11/4/03	13.0	110.0	175.0	NA	837.0	NA	NA	F
MW-3	2/9/04	4.0	180	350	820	<5.0	2,500	NA	F
MW-3	5/11/04	<25.0	<25.0	190	170	<25.0	970	NA	F
MW-3	8/2/04	<0.50	<5.0	51	<10.0	<5.0	260	NA	F
MW-3	11/3/04	<10.0	12	210	124	<10.0	740	NA	F
MW-4	8/14/03	<1.0	<1.0	<1.0	<1.0	NA	147.0	NA	F
MW-4	11/4/03	8.0	<1.0	3.0	<1.0	NA	418.0	NA	F
MW-4	2/9/04	2.2	0.58	3.1	2.4	<5.0	380	NA	F
MW-4	5/11/04	5.4	<0.50	8.7	5.1	0.50	690	NA	F
MW-4	8/2/04	<0.50	<0.50	5.9	10.3	<0.50	710	NA	F
MW-4	11/3/04	2.9	<0.50	18	6.0	<5.0	640	NA	F
MW-5	8/14/03	19.0	114	3,075.0	NA	21,505.0	NA	NA	F
MW-5	11/4/03	1.0	11	8,035.0	NA	38,200.0	NA	NA	F
MW-5	2/9/04	1,600	1,800	1,400	5,600	<250	33,000	NA	F
MW-5	5/11/04	1,100	9,300	1,100	4,500	<250	27,000	NA	F
MW-5	8/2/04	1,300	8,800	8.0	3,800	<250	26,000	NA	F
MW-5	11/3/04	960	6,900	910	3,590	<250	19,000	NA	F
MW-6	8/14/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
MW-6	11/4/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
MW-6	2/9/04	<0.50	<0.50	<0.50	<1.0	<5.0	<100.0	NA	F
MW-6	5/11/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NA	F
MW-6	8/2/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NA	F
MW-6	11/3/04	<0.50	<0.50	<0.50	<1.0	<0.50	<100.0	NA	F
Trip Blank	8/14/03	<1.0	<1.0	<1.0	<1.0	NA	NA	NA	F
Trip Blank	11/4/03	<1.0	<1.0	<1.0	<1.0	NA	NA	NA	F
Trip Blank	2/9/04	<0.50	<0.50	<0.50	<1.0	NA	NA	NA	F
Trip Blank	5/11/04	<1.0	<1.0	<1.0	<3.0	NA	NA	NA	F
Trip Blank	8/2/04	<1.0	<1.0	<1.0	<3.0	NA	NA	NA	F
Trip Blank	11/3/04	<0.50	<0.50	<0.50	<1.0	NA	NA	NA	F
Field Blank	8/14/03	1,300	1,300	147.0	5,072.0	NA	22,900.0	NA	F
Field Blank	11/4/03	<1.0	<1.0	<1.0	<1.0	NA	<100.0	NA	F
Field Blank	2/9/04	<0.50	<0.50	<0.50	<1.0	NA	<100.0	NA	F
Field Blank	5/11/04	<1.0	<1.0	<1.0	<3.0	NA	<100.0	NA	F
Field Blank	8/2/04	1,200	9,400	840	3,700	NA	29,000	NA	F
Field Blank	11/3/04	1,000	1,800	980	4,100	<10.0	21,000	NA	F
HRL(ug/L)		10	1,000	700	10,000				

Report results in ug/L. Use less than symbols to show detection limit. Indicate mobile or fixed based in the lab type column.

NA = Not Analyzed

NS = No Sampled

Table 4
Other Contaminants Detected in Water Samples
(Petroleum or Non-petroleum Derived)

Well Number	Date Sampled	1,2-DCA	EDB	Styrene	Chlorofor m	Isopropyl benzene	n-Propyl benzene	1,3,5-Trimethyl benzene	1,2,4-Trimethyl benzene	Sec-Butyl benzene	n-Butyl benzene	Naphthalene	Tert-Butyl benzene	p-isopropyl toluene	Methylene chloride
MW-1	2/9/04	<0.50	<0.50	1.2	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-1	5/11/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-1	8/2/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-1	11/3/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-2	2/9/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-2	5/11/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-2	8/2/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-2	11/3/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-3	2/9/04	<0.50	<0.50	1.2	<0.50	9.0	14	22	110	<0.50	1.3	19	<0.50	<0.50	<0.50
MW-3	5/11/04	<25	<25	<25	<25	<25	36	140	<25	<25	44	<25	<25	<25	<25
MW-3	8/2/04	<5.0	<0.5	<5.0	<5.0	6.1	<5.0	19	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0	<5.0
MW-3	11/3/04	<10	<10	<10	<10	19	<10	99	<10	<10	20	<10	<10	<10	<10
MW-4	2/9/04	<0.50	<0.50	<0.50	<0.50	2.3	7.2	3	4	2.1	4	5.7	<0.50	<0.50	<0.50
MW-4	5/11/04	<0.50	<0.50	<0.50	<0.50	2.1	6.5	3.5	12.0	5.0	6.8	8.5	<0.50	<0.50	<0.50
MW-4	8/2/04	<0.50	<0.50	<0.50	<0.50	5.5	16	0.96	41	4.9	7.7	15	0.73	0.86	<0.50
MW-4	11/3/04	<0.50	<0.50	<0.50	<0.50	6.3	18	8.7	25	4.9	8.1	13	<0.50	0.50	<0.50
MW-5	2/9/04	<25	<25	<25	<25	47	140	200	770	<25	29	260	<25	<25	<25
MW-5	5/11/04	<250	<250	<250	<250	<250	<250	<250	620	<250	<250	<250	<250	<250	<250
MW-5	8/2/04	<250	<250	<250	<250	<250	<250	<250	450	<250	<250	<250	<250	<250	<250
MW-5	11/3/04	<250	<250	<250	<250	<250	<250	<250	570	<250	<250	<250	<250	<250	5000
MW-6	2/9/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-6	5/11/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-6	8/2/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
MW-6	11/3/04	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50	<0.50
HRL (ug/L)		4	0.004		60								300		

Report results in ug/L. Indicate other contaminants (either petroleum or non-petroleum derived) detected in water samples collected from the borings, temporary wells or push probes.

Notes:

Table 5
Natural Attenuation Parameters

Monitoring Well	Sample Date	Temp. °C	pH	Dissolved Oxygen (mg/L)	Nitrate (mg/L)	(Fe II) (mg/L)	(H ₂ S, HS) (mg/L)
MW-1	NOT						
	ANAL-						
MW-2	IZED						
MW-3							
MW-4							

Describe the methods and procedures used.

Notes:

Table 6
Results of Vapor Monitoring

Location #	Date	PID reading (ppm)	Percent of the LEL
MH-8 T	2/9/04	0.0	0
MH-8 M	2/9/04	0.0	0
MH-8 B	2/9/04	0.0	0
MH-9	2/9/04	NS	NS
SSB-1	2/9/04	NS	NS
SSB-2	2/9/04	NS	NS
100 South Western Ave	2/9/04	NS	NS
110 South Western Ave	2/9/04	550.7	0
111 South Western Ave	2/9/04	NS	NS
120 South Western Ave	2/9/04	NS	NS
MH-8 T	5/11/04	0.0	0
MH-8 M	5/11/04	0.0	0
MH-8 B	5/11/04	0.0	0
MH-9 T	5/11/04	0.0	0
MH-9 M	5/11/04	0.0	0
MH-9 B	5/11/04	0.0	0
SSB-1	5/11/04	0.0	0

SSB-2	5/11/04	0.0	0
100 South Western Ave	5/11/04	0.0	0
110 South Western Ave	5/11/04	33.8	0
111 South Western Ave	5/11/04	0.0	0
120 South Western Ave	5/11/04	0.0	0
MH-8 T	8/2/04	0.0	0
MH-8 M	8/2/04	0.0	0
MH-8 B	8/2/04	0.0	0
MH-9 T	8/2/04	0.0	0
MH-9 M	8/2/04	0.0	0
MH-9 B	8/2/04	0.0	0
SSB-1	8/2/04	0.0	0
SSB-2	8/2/04	0.0	0
100 South Western Ave	8/2/04	NS	NS
110 South Western Ave	8/2/04	0.0	0
111 South Western Ave	8/2/04	0.0	0
120 South Western Ave	8/2/04	NS	NS
MH-8 T	11/3/04	0.0	0
MH-8 M	11/3/04	0.0	0
MH-8 B	11/3/04	0.0	0
MH-9 T	11/3/04	0.0	0
MH-9 M	11/3/04	0.0	0
MH-9 B	11/3/04	0.0	0
SSB-1	11/3/04	0.0	0
SSB-2	11/3/04	0.0	0
100 South Western Ave	11/3/04	NS	NS
110 South Western Ave	11/3/04	128.7	0
111 South Western Ave	11/3/04	0.0	0
120 South Western Ave	11/3/04	NS	NS

Notes:

MH = Man Hole

T = Top

SSB = Storm Sewer Basin

M = Middle

NS = No Sample

B = Bottom

MH-9, SSB-1 and SSB-2 on February 9, 2004 were not accessible due to snow and ice. The residents at 100, 111 and 120 South Western Avenue were not present when Coteau personnel were at the site on February 9, 2004. The residents at 100 and 120 South Western Avenue were not present when Coteau personnel were at the site on August 2, 2004. The residents at 100, 111 and 120 South Western Avenue were not present when Coteau personnel were at the site on November 3, 2004.

Attach Figures:

Figures - (all maps are to include a north arrow, scale and legend) *Approximate scales are not acceptable.*

- Site location map. Adapt this map from a U.S. Geological Survey 7.5 minute quadrangle and identify the name of the 7.5 minute quadrangle.
- Site map showing the locations of all ground water and vapor monitoring points.
- Updated ground water contour maps, using water level elevations from all rounds of water level measurements since the last report. Show all wells at the site, and differentiate wells constructed in different aquifers. Label ground water contours and elevations at each data point used for contouring.
- Hydrograph for all monitoring and recovery wells.
- Graph(s) showing contaminant concentrations over time for all monitoring and recovery wells.


Attach Appendices:

The appendix section of the report contains sufficient information to document all activities completed since the last report. All reproduced data must be legible.

- Copies of most recent laboratory reports for ground water analyses, including a copy of the Chain of Custody and the MDH laboratory certification number.
- Sample collection information, including procedure, equipment, and decontamination.
- Field or sampling data sheets.

<i>Web pages and phone numbers</i>	
MPCA staff	http://data.pca.state.mn.us/pca/emplsearch.html
MPCA toll free	1-800-657-3864
LUST web page	http://www.pca.state.mn.us/programs/lust_p.html
MPCA Infor. Request	http://www.pca.state.mn.us/about/inforequest.html
PetroFund Web Page	http://www.commerce.state.mn.us/mainpf.htm
PetroFund Phone	651-297-1119, or 1-800-638-0418
State Duty Officer	651-649-5451 or 1-800-422-0798

FIGURES




333 M 62.88
AD 782.25
50


TOPOGRAPHIC MAP
COPYRIGHT TOPOZONE.COM

FORMER K-C KWIK STOP BROOTEN, MINNESOTA

AREA LOCATION MAP

DATE	REVISED	COTEAU ENVIRONMENTAL 312 9TH AVE. SE, SUITE C WATERTOWN, SD 57201 (605) 886-4009
DRAWN BY:		DATE: JAN 05
		FIGURE: 1





MW-1

KEY

1

MONITOR WELL LOCATION

MW-1

**GROUND WATER ELEVATION
(FEET)**

2979

(FEET)
GROUND WATER ELEVATION
CONTOUR (APPROXIMATE)

— 89.5 —

CONTOUR APPROXIMATION


1

HATCH LOCATION

**FORMER K-C KWIK STOP
BROOTEN, MINNESOTA**

**GROUND WATER ELEVATIONS
(AUGUST 14, 2003)**

DATE	REVISED	COTEAU ENVIRONMENTAL 3930 SUNNYBROOK DR. NW ALEXANDRIA, MN 56308 (320) 846-4668
DRAWN BY:	DATE: JAN 05	FIGURE: 3A




KEY

- MW-1 MONITOR WELL LOCATION
- MW-1 GROUND WATER ELEVATION (FEET)
- 88.5 — GROUND WATER ELEVATION CONTOUR (APPROXIMATE)
- GROUND WATER FLOW DIRECTION
- MH-2 MANHOLE LOCATION

FORMER K-C KWIK STOP BROOTEN, MINNESOTA

GROUND WATER ELEVATIONS (NOVEMBER 4, 2003)

DATE	REVISED	COTEAU ENVIRONMENTAL 3930 SUNNYBROOK DR. NW ALEXANDRIA, MN 56308 (320) 846-4668
DRAWN BY:	DATE: JAN 05	FIGURE: 3B





KEY

- MW-1 MONITOR WELL LOCATION
- MW-1 GROUND WATER ELEVATION (FEET)
- 87.87 GROUND WATER ELEVATION CONTOUR (APPROXIMATE)
- 87.5 GROUND WATER FLOW DIRECTION
- MANHOLE LOCATION
- MH-2 MANHOLE LOCATION

FORMER K-C KWIK STOP BROOTEN, MINNESOTA

GROUND WATER ELEVATIONS
(FEBRUARY 9, 2004)

DATE	REVISED	COTEAU ENVIRONMENTAL 3930 SUNNYBROOK DR. NW ALEXANDRIA, MN 56308 (320) 846-4668
		DRAWN BY:
		DATE: JAN 05
		FIGURE: 3C




MONITOR WELL LOCATION
GROUND WATER ELEVATION (FEET)
GROUND WATER ELEVATION CONTOUR (APPROXIMATE)
GROUND WATER FLOW DIRECTION
MANHOLE LOCATION

FORMER K-C KWIK STOP BROOTEN, MINNESOTA

GROUND WATER ELEVATIONS (MAY 11, 2004)

DATE	REVISED	COTEAU ENVIRONMENTAL 3930 SUNNYBROOK DR. NW ALEXANDRIA, MN 56308 (320) 846-4668
		DRAWN BY:
		DATE: JAN 05
		FIGURE: 3D




KEY

- MW-1 MONITOR WELL LOCATION
- MW-1 GROUND WATER ELEVATION (FEET)
- 89.55 GROUND WATER ELEVATION CONTOUR (APPROXIMATE)
- 89.0 GROUND WATER FLOW DIRECTION
- MH-2 MANHOLE LOCATION

FORMER K-C KWIK STOP BROOTEN, MINNESOTA

GROUND WATER ELEVATIONS (AUGUST 2, 2004)

DATE	REVISED	COTEAU ENVIRONMENTAL 3930 SUNNYBROOK DR. NW ALEXANDRIA, MN 56308 (320) 846-4668
		DRAWN BY:
		DATE: JAN 05
		FIGURE: 3E



KEY

- MW-1 • MONITOR WELL LOCATION
- MW-1 • GROUND WATER ELEVATION (FEET)
- 89.0 — GROUND WATER ELEVATION CONTOUR (APPROXIMATE)
- GROUND WATER FLOW DIRECTION
- MH-2 • MANHOLE LOCATION

MONITOR WELL LOCATION
GROUND WATER ELEVATION (FEET)
GROUND WATER ELEVATION CONTOUR (APPROXIMATE)
GROUND WATER FLOW DIRECTION
MANHOLE LOCATION

FORMER K-C KWIK STOP BROOTEN, MINNESOTA

GROUND WATER ELEVATIONS (NOVEMBER 3, 2004)

DATE	REVISED	COTEAU ENVIRONMENTAL 3930 SUNNYBROOK DR. NW ALEXANDRIA, MN 56308 (320) 846-4668
		DRAWN BY:
		DATE: JAN 05
		FIGURE: 3F

FIGURE 4
KC KWIK STOP
BROOTEN, MINNESOTA
MONITOR WELL HYDROGRAPHS




FIGURE 5
KC KWIK STOP
BROOTEN, MINNESOTA
BENZENE CONCENTRATION GRAPH





FIGURE 6
KC KWIK STOP
BROOTEN, MINNESOTA
GRO CONCENTRATION GRAPH



APPENDIX I
LABORATORY ANALYTICAL REPORTS



LABORATORY REPORT

Client

Coteau Environmental
728 Janes Circle Dr. SW
Alexandria, MN 56308

Order Number

034758

Project Number

K-C Kwik Stop


Issued

Friday, August 22, 2003

Total Number of Pages

7

Approved By:



A handwritten signature in black ink, appearing to read "Bassam Youssef". Below the signature, the text "Laboratory Manager" is printed in a smaller, sans-serif font.

NELAC Accreditation #E87688

A2LA ISO/IEC 17025 Accreditation #0724.01

"Analytical Integrity" • A2LA Accreditation #0724.01 • ISO 9000
595 East Tallmadge Avenue • Akron, Ohio 44310 • Phone: 330-253-8211 • Fax: 330-253-4489
Email: summittlaboratories@sbcglobal.net



Sample Summary

Client: Coteau Environmental

Order Number: 034758

Laboratory ID	Client ID	Matrix	Sampling Date
034758-01	MW-01	Liquid	8/14/2003
034758-02	MW-02	Liquid	8/14/2003
034758-03	MW-06	Liquid	8/14/2003
034758-04	MW-04	Liquid	8/14/2003
034758-05	MW-03	Liquid	8/14/2003
034758-06	MW-05	Liquid	8/14/2003
034758-07	MW-07	Liquid	8/14/2003
034758-08	Trip Blank	Liquid	8/14/2003



Report Narrative

Client: Coteau Environmental

Order Number: 034758

No problems were encountered during analysis of this order number, except as noted.

The information contained in this analytical report is the sole property of Summit Environmental Technologies, Inc. and that of the client. It cannot be reproduced in any form without the consent of Summit Environmental Technologies, Inc. or the client for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Summit Environmental Technologies, Inc. is not responsible for use or interpretation of the data included herein.



Analytical Laboratories

4

August 22, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308

Date Collected: 8/14/2003
Date Received: 8/15/2003
Project #: K-C Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: 8021
Units: ug/L
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	034758-01	034758-02	034758-03	034758-04
	Client Sample ID:	MW-01	MW-02	MW-06	MW-04
	Detection Limit (ug/L)	1.0	1.0	1.0	1.0
	Date Analyzed:	8/20/2003	8/19/2003	8/19/2003	8/19/2003
Benzene		<1.0	<1.0	<1.0	<1.0
Toluene		<1.0	<1.0	<1.0	<1.0
Ethylbenzene		<1.0	<1.0	<1.0	<1.0
Total Xylene		<1.0	<1.0	<1.0	<1.0
% Surrogate Recovery		100.0	105.0	107.0	119.0



ENVIRONMENTAL TECHNOLOGIES, INC.

Analytical Laboratories

5

August 22, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308

Date Collected: 8/14/2003
Date Received: 8/15/2003
Project #: K-C Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: WI Mod.
Units: ug/l
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	034758-01	034758-02	034758-03	034758-04
	Client Sample ID:	MW-01	MW-02	MW-06	MW-04
	Detection Limit (ug/l)	100.0	100.0	100.0	100.0
	Date Analyzed:	8/20/2003	8/19/2003	8/19/2003	8/19/2003
TPH-GRO		<100.0	<100.0	<100.0	147.0
% Surrogate Recovery		100.0	105.0	107.0	119.0



August 22, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308

Date Collected: 8/14/2003
Date Received: 8/15/2003
Project #: K-C Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: 8021
Units: ug/L
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	034758-05	034758-06	034758-07	034758-08
	Client Sample ID:	MW-03	MW-05	MW-07	Trip Blank
	Detection Limit (ug/L)	1.0	5.0	50.0	1.0
	Date Analyzed:	8/21/2003	8/20/2003	8/20/2003	8/20/2003
Benzene		29.0	900.0	1507.0	<1.0
Toluene		22.0	719.0	4309.0	<1.0
Ethylbenzene		211.0	22.0	147.0	<1.0
Total Xylene		444.0	3075.0	5072.0	<1.0
% Surrogate Recovery		112.0	124.0	104.0	95.0



August 22, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308

Date Collected: 8/14/2003
Date Received: 8/15/2003
Project #: K-C Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: WI Mod.
Units: ug/l
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	034758-05	034758-06	034758-07
	Client Sample ID:	MW-03	MW-05	MW-07
	Detection Limit (ug/l)	100.0	100.0	100.0
	Date Analyzed:	8/21/2003	8/20/2003	8/20/2003
TPH-GRO		2171.0	21505.0	22900.0
% Surrogate Recovery		112.0	124.0	104.0



Summit Environmental Technologies, Inc.

595 East Fallmadge Avenue Akron, Ohio 44310 Tel: 330.253.8211 Fax 330.253.4480

Analysis Request/Chain of Custody

For Summit Environmental Technologies, Inc. use only

Analytical Parameters and Methods

Project Name KC Kwik Stop
Client Name Contech Environmental Capital

Patient Address _____

728 JAMES LITTLE DUE SUNDAY
ALEXANDRIA, MINN 56308 30001-1, 1441

608-882-4152 ✓
Contact Person _____
Quote No. _____

Sampled by HATC Check if Ohio VAP samples ✓

45

#	Sample Identification	Date Collected	Tissue Collected
---	-----------------------	----------------	------------------

1 MW-01
2 22

101
100
20
3

110
404

5	0.3	120
6	0.5	174

12 13
→ →
- 2
07

7210 BLANK

1978-1979

Relinquished by: J. C. Brown Date: 8/14/03 Time: 1600 Received by: D.

Requester: _____
Must be approved by lab manager

White and yellow pages should accompany samples to the laboratory. The client retains the pink page.

Client Name		Project Name	Analytical Parameters and Methods		
COTYAN ENVIRONMENTAL		KC Kuwait Stop			
Client Address		Project Address			
728 JAMES CIRCLE D.E.S.W. ALEXANDRIA, VA 22308		3200 SHERMAN IRVING			
Client Phone No.		Report to COTYAN ENVI.			
320 846-4668					
Client Fax No		Please Fax Results <input checked="" type="checkbox"/>			
605 - 882-4152		PO #			
Contact Person		Quote No			
NATE					
Sampled by		Check if Ohio VAP samples <input type="checkbox"/>			
SD4			Date Collected	Time Collected	
#	Sample Identification				

Relinquished by:	Date	Time	Received by:	Date	Time	Notes/Comments: PLEASE USE TRA & TMR BLANKS FOR BOTH SITES
<u>Green</u>	5/14/03	1600				
Received in lab by:	Date	Time	Rush Requested:	Days		
<u>Terry W. Doss</u>	5/15/03					Must be approved by lab manager

White and yellow pages should accompany samples to the laboratory. The client retains the pink page.



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

LABORATORY REPORT

Client

Coteau Environmental
728 Janes Circle Dr. SW
Alexandria, MN 56308

Order Number

036712

Project Number

KC Kwik Stop


Issued

Monday, November 10, 2003

Total Number of Pages

7

Approved By:




Bassam Youssef
Laboratory Manager

NELAC Accreditation #E87688

A2LA ISO/IEC 17025 Accreditation #0724.01

"Analytical Integrity" • A2LA Accreditation #0724.01 • ISO 9000

595 East Tallmadge Avenue • Akron, Ohio 44310 • Phone: 330-253-8211 • Fax: 330-253-4489
Email: summitlaboratories@sbcglobal.net




Sample Summary

Client: Coteau Environmental

Order Number: 036712

Laboratory ID	Client ID	Matrix	Sampling Date
036712-01	MW-01	Liquid	11/4/03
036712-02	MW-07	Liquid	11/4/03
036712-03	MW-02	Liquid	11/4/03
036712-04	MW-06	Liquid	11/4/03
036712-05	MW-04	Liquid	11/4/03
036712-06	MW-03	Liquid	11/4/03
036712-07	MW-05	Liquid	11/4/03
036712-08	Trip Blank	Liquid	11/4/03



Report Narrative

Client: Coteau Environmental

Order Number: 036712

No problems were encountered during analysis of this order number, except as noted.

The information contained in this analytical report is the sole property of Summit Environmental Technologies, Inc. and that of the client. It cannot be reproduced in any form without the consent of Summit Environmental Technologies, Inc. or the client for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Summit Environmental Technologies, Inc. is not responsible for use or interpretation of the data included herein.



SUMMIT

ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

4

November 10, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308


Date Collected: 11/4/03
Date Received: 11/5/03
Project #: KC Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: 8021
Units: ug/L
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	036712-01	036712-02	036712-03	036712-04
	Client Sample ID:	MW-01	MW-07	MW-02	MW-06
	Detection Limit (ug/L)	1.0	1.0	1.0	1.0
	Date Analyzed:	11/5/03	11/6/03	11/6/03	11/6/03
Benzene		<1.0	<1.0	<1.0	<1.0
Toluene		<1.0	<1.0	<1.0	<1.0
Ethylbenzene		<1.0	<1.0	<1.0	<1.0
Total Xylene		<1.0	<1.0	<1.0	<1.0
% Surrogate Recovery		116.0	115.0	115.0	117.0

"Analytical Integrity" • A2LA Accreditation #0724.01 • ISO 9000

595 East Tallmadge Avenue • Akron, Ohio 44310 • Phone: 330-253-8211 • Fax: 330-253-4489

Email summitlaboratories@sbcglobal.net



SUMMIT

ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

5

November 10, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308

Date Collected: 11/4/03
Date Received: 11/5/03
Project #: KC Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: WI Mod.
Units: ug/l
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	036712-01	036712-02	036712-03	036712-04
	Client Sample ID:	MW-01	MW-07	MW-02	MW-06
	Detection Limit (ug/l)	100.0	100.0	100.0	100.0
	Date Analyzed:	11/5/03	11/6/03	11/6/03	11/6/03
TPH-GRO		<100.0	<100.0	<100.0	<100.0
% Surrogate Recovery		116.0	115.0	115.0	117.0



SUMMIT
ENVIRONMENTAL TECHNOLOGIES, INC.
Analytical Laboratories

6

November 10, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308


Date Collected: 11/4/03
Date Received: 11/5/03
Project #: KC Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: 8021
Units: ug/L
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	036712-05	036712-06	036712-07	036712-08
	Client Sample ID:	MW-04	MW-03	MW-05	Trip Blank
	Detection Limit (ug/L)	1.0	1.0	50.0	1.0
	Date Analyzed:	11/6/03	11/7/03	11/7/03	11/6/03
Benzene		8.0	38.0	2313.0	<1.0
Toluene		<1.0	13.0	16671.0	<1.0
Ethylbenzene		3.0	110.0	1740.0	<1.0
Total Xylene		<1.0	175.0	8035.0	<1.0
% Surrogate Recovery		125.0	109.0	123.0	104.0

"Analytical Integrity" • A2LA Accreditation #0724.01 • ISO 9000

595 East Tallmadge Avenue • Akron, Ohio 44310 • Phone: 330-253-8211 • Fax: 330-253-4489

Email: summitlaboratories@sbcglobal.net



SUMMIT

ENVIRONMENTAL TECHNOLOGIES, INC.

Analytical Laboratories

7

November 10, 2003

Client: Coteau Environmental
Address: 728 Janes Circle Dr. SW
Alexandria, MN 56308

Date Collected: 11/4/03
Date Received: 11/5/03
Project #: KC Kwik Stop
Client ID #: See Below
Laboratory ID #: See Below
Matrix: Liquid
Method: WI Mod.
Units: ug/l
Analyst: MS
Detection Limit: See Below
Date of Analysis: See Below

	Lab Sample ID:	036712-05	036712-06	036712-07
	Client Sample ID:	MW-04	MW-03	MW-05
	Detection Limit (ug/l)	100.0	100.0	100.0
	Date Analyzed:	11/6/03	11/7/03	11/7/03
TPH-GRO		418.0	837.0	38200.0
% Surrogate Recovery		125.0	109.0	123.0

"Analytical Integrity" • A2LA Accreditation #0724.01 • ISO 9000

595 East Tallmadge Avenue • Akron, Ohio 44310 • Phone: 330-253-8211 • Fax: 330-253-4489

Email: summittlaboratories@sbcglobal.net



L E G E N D

Technical Services, Inc.

03/08/04

Mr. Nate Hunke
Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN
56308

Subject: Brooton, MN KC Kwik Stop
Legend No: 2004020260

LEGEND TECHNICAL SERVICES, INC. (LEGEND) received the following sample(s).

Matrix	Samples	Date Sampled	Date Received	Comments
Groundwater	7	02/09/04	02/18/04	Received @ 12.5 C

- * The associated batch quality assurance / quality control criteria were met with satisfaction.
- * All samples will be retained by LEGEND for 30 days from the date of this report and then discarded unless other instructions are received from the client.
- * Minnesota Laboratory Certification # 027-123-295.
- * Recoveries for naphthalene, 2,2-dichloropropane, 1,2,3-trichlorobenzene, hexachlorobutadiene, 1,2,4-trichlorobenzene, bromoform, acetone, 1,2-dibromo-3-chloropropane and tetrahydrofuran in the beginning CCAL for voc samples analyzed on 2/21/04 were below method limits. Reported results for these compounds in MW04, MW03 and MW05 may be biased low.

Prepared by,
LEGEND TECHNICAL SERVICES, INC

Chris Bremer
Laboratory Director

Karla Reps
Client Representative

This report shall not be reproduced, except in full, without the written authorization of LEGEND

INDOOR ENVIRONMENTAL QUALITY AND LABORATORY SERVICES

Legend Technical Services

Page 2 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project:	Brooton, MN	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04

GRO/8021B WATER

Analysis Date: 02/19/04 02/19/04 --

Analysis Method: WI GRO WI GRO --

Client Sample ID: MW-07 Trip Blank µg/L

Compound	2	8	RL
Benzene	<1.0	<1.0	1.0
Ethyl benzene	<1.0	<1.0	1.0
Gasoline range organics	<100	<100	1.0
Toluene	<1.0	<1.0	3.0
Total xylenes	<3.0	<3.0	--
1-Chloro-4-fluorobenzene (Surr)	96.0%	96.0%	--

Legend Technical Services

Page 3 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project:	Brooton, MN	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04

GRO/8021B WATER

Analysis Date:	02/19/04	02/19/04	02/19/04	02/19/04	02/19/04	02/19/04	02/19/04	--
Analysis Method:	WI GRO	--						
Client Sample ID:	MW-01	MW-02	MW-06	MW-04	MW-03	MW-05	Method Blank	µg/L
Compound	1	3	4	5	6	7	9	RL
Gasoline range organics	<100	<100	<100	380	2,500	33,000 D	<100	100
1-Chloro-4-fluorobenzene (Surr)	95.2%	94.4%	94.6%	100%	104%	99.6%	95.4%	--

D=Quantitation was performed on a dilution of the sample.

Legend Technical Services

Page 4 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	1
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	MW-01		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	MW-01
Analysis Method:	8021B		
Analysis Date:	02/20/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	<0.50	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	<0.50	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	<0.50	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	<0.50	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	<0.50	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	<0.50	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	<0.50	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	<1.0	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	<0.50	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	<0.50	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	<0.50	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	<0.50	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	<0.50	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	87.8	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058					
Carbon tetrachloride	<0.50	µg/L	0.50	0.025					
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

Legend Technical Services

Page 5 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	3
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	MW-02		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	MW-02
Analysis Method:	8021B		
Analysis Date:	02/20/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	<0.50	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	<0.50	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	<0.50	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	<0.50	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	<0.50	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	<0.50	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	<0.50	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	<1.0	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	<0.50	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	<0.50	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	<0.50	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	<0.50	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	<0.50	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	87.7	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058					
Carbon tetrachloride	<0.50	µg/L	0.50	0.025					
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

Legend Technical Services

Page 6 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	4
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	MW-06		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	MW-06
Analysis Method:	8021B		
Analysis Date:	02/20/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	<0.50	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	<0.50	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	<0.50	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	<0.50	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	<0.50	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	<0.50	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	<0.50	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	<1.0	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	<0.50	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	<0.50	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	<0.50	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	<0.50	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	<0.50	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	87.4	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058					
Carbon tetrachloride	<0.50	µg/L	0.50	0.025					
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

Legend Technical Services

Page 7 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	5
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	MW-04		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	MW-04
Analysis Method:	8021B		
Analysis Date:	02/21/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	3.1	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	2.3	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	4.0	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	4.0	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	7.2	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	5.7	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	1.3	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	1.1	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	3.0	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	2.1	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	<0.50	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	0.58	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	2.2	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	78.9 S5	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058	S5=Surrogate recovery was below laboratory acceptance limits.				
Carbon tetrachloride	<0.50	µg/L	0.50	0.025	This appears to be matrix related.				
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

Legend Technical Services

Page 8 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	6
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	MW-03		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	MW-03
Analysis Method:	8021B		
Analysis Date:	02/21/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	350 D	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	9.0	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	110 D	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	1.3	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	14	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	19	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	430 D	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	390 D	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	22	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	<0.50	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	1.2	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	180 D	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	4.0	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	93.0	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058					
Carbon tetrachloride	<0.50	µg/L	0.50	0.025					
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

D=Quantitation was performed on a dilution of the sample.

Legend Technical Services

Page 9 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	7
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	MW-05		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	MW-05
Analysis Method:	8021B		
Analysis Date:	02/21/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<50	µg/L	1.0	0.066	Dibromomethane	<25	µg/L	0.50	0.033
1,1,1-Trichloroethane	<25	µg/L	0.50	0.065	Dichlorodifluoromethane	<100	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<25	µg/L	0.50	0.057	Dichlorofluoromethane	<250	µg/L	5.0	0.23
1,1,2-Trichloroethane	<25	µg/L	0.50	0.052	Ethyl benzene	1,400 D	µg/L	0.50	0.064
1,1-Dichloroethane	<25	µg/L	0.50	0.057	Ethyl ether	<250	µg/L	5.0	0.26
1,1-Dichloroethene	<25	µg/L	0.50	0.061	Hexachlorobutadiene	<25	µg/L	0.50	0.049
1,1-Dichloropropene	<25	µg/L	0.50	0.052	Isopropyl benzene	47	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<25	µg/L	0.50	0.026	Methyl ethyl ketone	<250	µg/L	5.0	0.35
1,2,3-Trichloropropane	<25	µg/L	0.50	0.060	Methyl isobutyl ketone	<250	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<25	µg/L	0.50	0.022	Methyl-tert-butyl ether	<250	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	770	µg/L	0.50	0.059	Methylene chloride	<250	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<25	µg/L	0.50	0.025	n-Butyl benzene	29	µg/L	0.50	0.062
1,2-Dibromoethane	<25	µg/L	0.50	0.039	n-Propyl benzene	140	µg/L	0.50	0.070
1,2-Dichlorobenzene	<25	µg/L	0.50	0.062	Naphthalene	260	µg/L	0.50	0.045
1,2-Dichloroethane	<25	µg/L	0.50	0.054	o-Xylene	1600 D	µg/L	0.50	0.062
1,2-Dichloropropane	<25	µg/L	0.50	0.048	p,m-Xylene	4,000 D	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	200	µg/L	0.50	0.058	p-Isopropyltoluene	<25	µg/L	0.50	0.063
1,3-Dichlorobenzene	<25	µg/L	0.50	0.057	sec-Butyl benzene	<25	µg/L	0.50	0.067
1,3-Dichloropropane	<25	µg/L	0.50	0.064	Styrene	<25	µg/L	0.50	0.060
1,4-Dichlorobenzene	<25	µg/L	0.50	0.058	tert-Butyl benzene	<25	µg/L	0.50	0.063
2,2-Dichloropropane	<25	µg/L	0.50	0.075	Tetrachloroethene	<25	µg/L	0.50	0.075
2-Chlorotoluene	<25	µg/L	0.50	0.060	Tetrahydrofuran	<250	µg/L	5.0	0.28
4-Chlorotoluene	<25	µg/L	0.50	0.059	Toluene	7,800 D	µg/L	0.50	0.069
Acetone	<500	µg/L	10	2.0	trans-1,2-Dichloroethene	<25	µg/L	0.50	0.059
Allyl chloride	<250	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<25	µg/L	0.50	0.059
Benzene	1,600 D	µg/L	0.50	0.067	Trichloroethene	<25	µg/L	0.50	0.074
Bromobenzene	<25	µg/L	0.50	0.039	Trichlorofluoromethane	<50	µg/L	1.0	0.060
Bromochloromethane	<25	µg/L	0.50	0.061	Trichlorotrifluoroethane	<250	µg/L	5.0	0.16
Bromodichloromethane	<25	µg/L	0.50	0.064	Vinyl chloride	<25	µg/L	0.50	0.065
Bromoform	<25	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	92.2	%	--	--
Bromomethane	<100	µg/L	2.0	0.058					
Carbon tetrachloride	<25	µg/L	0.50	0.025	D=Quantitation was performed on a dilution of the sample.				
Chlorobenzene	<25	µg/L	0.50	0.064					
Chloroethane	<50	µg/L	1.0	0.074					
Chloroform	<25	µg/L	0.50	0.061					
Chloromethane	<100	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<25	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<25	µg/L	0.50	0.064					
Dibromochloromethane	<25	µg/L	0.50	0.055					

Legend Technical Services

Page 10 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	8
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	Trip Blank		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	Trip Blank
Analysis Method:	8021B		
Analysis Date:	02/20/04		

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	<0.50	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	<0.50	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	<0.50	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	<0.50	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	<0.50	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	<0.50	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	<0.50	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	<1.0	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	<0.50	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	<0.50	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	<0.50	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	<0.50	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	<0.50	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	87.4	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058					
Carbon tetrachloride	<0.50	µg/L	0.50	0.025					
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

Legend Technical Services

Page 11 of 11

Client Name:	Coteau Environmental	Legend Project #:	2004020260
Client Project Number:	Brooton, MN	Sample #:	9
Client Project Name:	KC Kwik Stop	Matrix:	Groundwater
Date Sampled:	02/09/04	Date Received:	02/18/04
Client Sample ID:	Method Blank		

VOC MDH LIST BY 8021B

Extraction Date:	--	Client ID:	Method Blank		
Analysis Method:	8021B				
Analysis Date:	02/20/04				

Compound	Sample Results	Units	RL	MDL	Compound	Sample Results	Units	RL	MDL
1,1,1,2-Tetrachloroethane	<1.0	µg/L	1.0	0.066	Dibromomethane	<0.50	µg/L	0.50	0.033
1,1,1-Trichloroethane	<0.50	µg/L	0.50	0.065	Dichlorodifluoromethane	<2.0	µg/L	2.0	0.063
1,1,2,2-Tetrachloroethane	<0.50	µg/L	0.50	0.057	Dichlorofluoromethane	<5.0	µg/L	5.0	0.23
1,1,2-Trichloroethane	<0.50	µg/L	0.50	0.052	Ethyl benzene	<0.50	µg/L	0.50	0.064
1,1-Dichloroethane	<0.50	µg/L	0.50	0.057	Ethyl ether	<5.0	µg/L	5.0	0.26
1,1-Dichloroethene	<0.50	µg/L	0.50	0.061	Hexachlorobutadiene	<0.50	µg/L	0.50	0.049
1,1-Dichloropropene	<0.50	µg/L	0.50	0.052	Isopropyl benzene	<0.50	µg/L	0.50	0.064
1,2,3-Trichlorobenzene	<0.50	µg/L	0.50	0.026	Methyl ethyl ketone	<5.0	µg/L	5.0	0.35
1,2,3-Trichloropropane	<0.50	µg/L	0.50	0.060	Methyl isobutyl ketone	<5.0	µg/L	5.0	0.23
1,2,4-Trichlorobenzene	<0.50	µg/L	0.50	0.022	Methyl-tert-butyl ether	<5.0	µg/L	5.0	0.24
1,2,4-Trimethyl benzene	<0.50	µg/L	0.50	0.059	Methylene chloride	<5.0	µg/L	5.0	0.44
1,2-Dibromo-3-chloropropane	<0.50	µg/L	0.50	0.025	n-Butyl benzene	<0.50	µg/L	0.50	0.062
1,2-Dibromoethane	<0.50	µg/L	0.50	0.039	n-Propyl benzene	<0.50	µg/L	0.50	0.070
1,2-Dichlorobenzene	<0.50	µg/L	0.50	0.062	Naphthalene	<0.50	µg/L	0.50	0.045
1,2-Dichloroethane	<0.50	µg/L	0.50	0.054	o-Xylene	<0.50	µg/L	0.50	0.062
1,2-Dichloropropane	<0.50	µg/L	0.50	0.048	p,m-Xylene	<1.0	µg/L	1.0	0.13
1,3,5-Trimethyl benzene	<0.50	µg/L	0.50	0.058	p-Isopropyltoluene	<0.50	µg/L	0.50	0.063
1,3-Dichlorobenzene	<0.50	µg/L	0.50	0.057	sec-Butyl benzene	<0.50	µg/L	0.50	0.067
1,3-Dichloropropane	<0.50	µg/L	0.50	0.064	Styrene	<0.50	µg/L	0.50	0.060
1,4-Dichlorobenzene	<0.50	µg/L	0.50	0.058	tert-Butyl benzene	<0.50	µg/L	0.50	0.063
2,2-Dichloropropane	<0.50	µg/L	0.50	0.075	Tetrachloroethene	<0.50	µg/L	0.50	0.075
2-Chlorotoluene	<0.50	µg/L	0.50	0.060	Tetrahydrofuran	<5.0	µg/L	5.0	0.28
4-Chlorotoluene	<0.50	µg/L	0.50	0.059	Toluene	<0.50	µg/L	0.50	0.069
Acetone	<10	µg/L	10	2.0	trans-1,2-Dichloroethene	<0.50	µg/L	0.50	0.059
Allyl chloride	<5.0	µg/L	5.0	0.27	trans-1,3-Dichloropropene	<0.50	µg/L	0.50	0.059
Benzene	<0.50	µg/L	0.50	0.067	Trichloroethene	<0.50	µg/L	0.50	0.074
Bromobenzene	<0.50	µg/L	0.50	0.039	Trichlorofluoromethane	<1.0	µg/L	1.0	0.060
Bromochloromethane	<0.50	µg/L	0.50	0.061	Trichlorotrifluoroethane	<5.0	µg/L	5.0	0.16
Bromodichloromethane	<0.50	µg/L	0.50	0.064	Vinyl chloride	<0.50	µg/L	0.50	0.065
Bromoform	<0.50	µg/L	0.50	0.038	Fluorobenzene (Surrogate)	88.9	%	--	--
Bromomethane	<2.0	µg/L	2.0	0.058					
Carbon tetrachloride	<0.50	µg/L	0.50	0.025					
Chlorobenzene	<0.50	µg/L	0.50	0.064					
Chloroethane	<1.0	µg/L	1.0	0.074					
Chloroform	<0.50	µg/L	0.50	0.061					
Chloromethane	<2.0	µg/L	2.0	0.061					
cis-1,2-Dichloroethene	<0.50	µg/L	0.50	0.055					
cis-1,3-Dichloropropene	<0.50	µg/L	0.50	0.064					
Dibromochloromethane	<0.50	µg/L	0.50	0.055					

CHAIN-OFF-CUSTODY RECORD

Please review terms and conditions on back before signing

White Copy - Original Accompaniment Shipment to Lab
Yellow Copy - Lab
Pink Copy - Customer or Field Copy

LEGEND

Technical Services, Inc.

www.legend-group.com

June 08, 2004

Mr. Nate Hunke
Coteau Environmental
728 Janes Circle Drive SW
Alexandria, MN 56308


Work Order Number: 0400636
RE: KC-Kwik Stop-Brooten, MN

Enclosed are the results of analyses for samples received by the laboratory on 05/12/04. If you have any questions concerning this report, please feel free to contact me.

All samples will be retained by LEGEND for 30 days from the date of this report and then discarded unless other arrangements are made.

Minnesota Certification # 027-123-295

Prepared by,
LEGEND TECHNICAL SERVICES, INC



Karla Reps
Client Representative



Chris Bremer
Laboratory Director

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
MW-01	0400636-01	Groundwater	05/11/04 07:45	05/12/04 16:30
MW-07	0400636-02	Groundwater	05/11/04 07:50	05/12/04 16:30
MW-02	0400636-03	Groundwater	05/11/04 08:43	05/12/04 16:30
MW-06	0400636-04	Groundwater	05/11/04 09:27	05/12/04 16:30
MW-04	0400636-05	Groundwater	05/11/04 10:32	05/12/04 16:30
MW-03	0400636-06	Groundwater	05/11/04 11:30	05/12/04 16:30
MW-05	0400636-07	Groundwater	05/11/04 12:20	05/12/04 16:30
Trip Blank	0400636-08	Groundwater	05/11/04 12:20	05/12/04 16:30

Shipping container information

Default Cooler

Temperature: 10.9

Received on ice: Yes
Received on melt water: No
Custody seals: No

Temperature blank was present
Ambient: No

Received on blue ice: No
Acceptable (IH/ISO only): No

Case Narrative:

The Continuing Calibration Verification Standard (CCVS) passed Method 8021 criteria. 1,2-Dibromo-3-chloropropane, 1,2,4-Trichlorobenzene, 1,2,3-Trichlorobenzene, n-Butylbenzene, and Naphthalene were slightly low. All compounds except Naphthalene were within limits in the associated Blank Spike. This could indicate a slightly low bias for Naphthalene.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

GRO/8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0400636-01) Groundwater	Sampled: 05/11/04 07:45	Received: 05/12/04 16:30								
Gasoline range organics	<100	100	16	ug/L	1	B4E1403	05/14/04	05/15/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	96.4			80-120 %	"	"	"	"	"	
MW-07 (0400636-02) Groundwater	Sampled: 05/11/04 07:50	Received: 05/12/04 16:30								
Benzene	<1.0	1.0	0.046	ug/L	1	B4E1403	05/14/04	05/14/04	EPA 8021B	
Ethylbenzene	<1.0	1.0	0.040	ug/L	1	"	"	"	"	
Toluene	<1.0	1.0	0.016	ug/L	1	"	"	"	"	
Xylenes (total)	<3.0	3.0	0.17	ug/L	1	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	100			80-120 %	"	"	"	"	"	
Gasoline range organics	<100	100	16	ug/L	1	"	"	"	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	100			80-120 %	"	"	"	"	"	
MW-02 (0400636-03) Groundwater	Sampled: 05/11/04 08:43	Received: 05/12/04 16:30								
Gasoline range organics	<100	100	16	ug/L	1	B4E1403	05/14/04	05/14/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	107			80-120 %	"	"	"	"	"	
MW-06 (0400636-04) Groundwater	Sampled: 05/11/04 09:27	Received: 05/12/04 16:30								
Gasoline range organics	<100	100	16	ug/L	1	B4E1403	05/14/04	05/14/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	105			80-120 %	"	"	"	"	"	
MW-04 (0400636-05) Groundwater	Sampled: 05/11/04 10:32	Received: 05/12/04 16:30								
Gasoline range organics	690	100	16	ug/L	1	B4E1403	05/14/04	05/14/04	Wisc Mod GRO	H
Surrogate: 4-Fluorochlorobenzene	107			80-120 %	"	"	"	05/14/04	"	
MW-03 (0400636-06) Groundwater	Sampled: 05/11/04 11:30	Received: 05/12/04 16:30								
Gasoline range organics	970	100	16	ug/L	1	B4E1403	05/14/04	05/14/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	102			80-120 %	"	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651 642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

GRO/8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0400636-07) Groundwater Sampled: 05/11/04 12:20 Received: 05/12/04 16:30										
Gasoline range organics	27000	2500	400	ug/L	25	B4E1403	05/14/04	05/14/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	108			80-120 %		"	"	"	"	
Trip Blank (0400636-08) Groundwater Sampled: 05/11/04 12:20 Received: 05/12/04 16:30										
Benzene	<1.0	1.0	0.046	ug/L	1	B4E1403	05/14/04	05/14/04	EPA 8021B	
Ethylbenzene	<1.0	1.0	0.040	ug/L	1	"	"	"	"	
Toluene	<1.0	1.0	0.016	ug/L	1	"	"	"	"	
Xylenes (total)	<3.0	3.0	0.17	ug/L	1	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	104			80-120 %		"	"	"	"	

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0400636-01) Groundwater Sampled: 05/11/04 07:45 Received: 05/12/04 16:30										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0400636-01) Groundwater Sampled: 05/11/04 07:45 Received: 05/12/04 16:30										
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	<0.50	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0400636-01) Groundwater Sampled: 05/11/04 07:45 Received: 05/12/04 16:30										
Trichloroethene	<0.50	0.50	0.074	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	96.9			80-120 %		"	"	"	"	
MW-02 (0400636-03) Groundwater Sampled: 05/11/04 08:43 Received: 05/12/04 16:30										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-02 (0400636-03) Groundwater Sampled: 05/11/04 08:43 Received: 05/12/04 16:30										
Benzene	<0.50	0.50	0.067	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	3.3	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	<0.50	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-02 (0400636-03) Groundwater Sampled: 05/11/04 08:43 Received: 05/12/04 16:30										
Styrene	<0.50	0.50	0.060	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	96.9			80-120 %		"	"	"	"	"
MW-06 (0400636-04) Groundwater Sampled: 05/11/04 09:27 Received: 05/12/04 16:30										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	"
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-06 (0400636-04) Groundwater Sampled: 05/11/04 09:27 Received: 05/12/04 16:30										
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
Chloromethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-06 (0400636-04) Groundwater Sampled: 05/11/04 09:27 Received: 05/12/04 16:30										
Naphthalene	<0.50	0.50	0.045	ug/L	1	B4E1819	05/17/04	05/18/04	EPA 8021B	
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	97.5			80-120 %	"	"	"	"	"	
MW-04 (0400636-05) Groundwater Sampled: 05/11/04 10:32 Received: 05/12/04 16:30										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4E2020	05/20/04	05/20/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	
1,2,4-Trimethylbenzene	12	0.50	0.059	ug/L	1	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-04 (0400636-05) Groundwater Sampled: 05/11/04 10:32 Received: 05/12/04 16:30										
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	B4E2020	05/20/04	05/20/04	EPA 8021B	
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	3.5	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"
Benzene	5.4	0.50	0.067	ug/L	1	"	"	"	"	"
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-04 (0400636-05) Groundwater Sampled: 05/11/04 10:32 Received: 05/12/04 16:30										
Ethylbenzene	8.7	0.50	0.064	ug/L	1	B4E2020	05/20/04	05/20/04	EPA 8021B	
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	2.1	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	8.5	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	6.8	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	6.5	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	4.3	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	4.8	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	5.0	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	102			80-120 %		"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0400636-06) Groundwater Sampled: 05/11/04 11:30 Received: 05/12/04 16:30										
1,1,1,2-Tetrachloroethane	<50	50	3.3	ug/L	50	B4E2020	05/20/04	05/20/04	EPA 8021B	"
1,1,1-Trichloroethane	<25	25	3.2	ug/L	50	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<25	25	2.8	ug/L	50	"	"	"	"	"
1,1,2-Trichloroethane	<25	25	2.6	ug/L	50	"	"	"	"	"
1,1-Dichloroethane	<25	25	2.8	ug/L	50	"	"	"	"	"
1,1-Dichloroethene	<25	25	3.0	ug/L	50	"	"	"	"	"
1,1-Dichloropropene	<25	25	2.6	ug/L	50	"	"	"	"	"
1,2,3-Trichlorobenzene	<25	25	1.3	ug/L	50	"	"	"	"	"
1,2,3-Trichloropropane	<25	25	3.0	ug/L	50	"	"	"	"	"
1,2,4-Trichlorobenzene	<25	25	1.1	ug/L	50	"	"	"	"	"
1,2,4-Trimethylbenzene	140	25	3.0	ug/L	50	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<25	25	1.2	ug/L	50	"	"	"	"	"
1,2-Dibromoethane (EDB)	<25	25	2.0	ug/L	50	"	"	"	"	"
1,2-Dichlorobenzene	<25	25	3.1	ug/L	50	"	"	"	"	"
1,2-Dichloroethane	<25	25	2.7	ug/L	50	"	"	"	"	"
1,2-Dichloropropane	<25	25	2.4	ug/L	50	"	"	"	"	"
1,3,5-Trimethylbenzene	36	25	2.9	ug/L	50	"	"	"	"	"
1,3-Dichlorobenzene	<25	25	2.8	ug/L	50	"	"	"	"	"
1,3-Dichloropropane	<25	25	3.2	ug/L	50	"	"	"	"	"
1,4-Dichlorobenzene	<25	25	2.9	ug/L	50	"	"	"	"	"
2,2-Dichloropropane	<25	25	3.8	ug/L	50	"	"	"	"	"
2-Chlorotoluene	<25	25	3.0	ug/L	50	"	"	"	"	"
4-Chlorotoluene	<25	25	3.0	ug/L	50	"	"	"	"	"
Acetone	<500	500	100	ug/L	50	"	"	"	"	"
Allyl chloride	<50	50	14	ug/L	50	"	"	"	"	"
Benzene	<25	25	3.4	ug/L	50	"	"	"	"	"
Bromobenzene	<25	25	2.0	ug/L	50	"	"	"	"	"
Bromochloromethane	<25	25	3.0	ug/L	50	"	"	"	"	"
Bromodichloromethane	<25	25	3.2	ug/L	50	"	"	"	"	"
Bromoform	<25	25	1.9	ug/L	50	"	"	"	"	"
Bromomethane	<100	100	2.9	ug/L	50	"	"	"	"	"
Carbon tetrachloride	<25	25	1.2	ug/L	50	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0400636-06) Groundwater Sampled: 05/11/04 11:30 Received: 05/12/04 16:30										
Chlorobenzene	<25	25	3.2	ug/L	50	B4E2020	05/20/04	05/20/04	EPA 8021B	"
Chloroethane	<50	50	3.7	ug/L	50	"	"	"	"	"
Chloroform	<25	25	3.0	ug/L	50	"	"	"	"	"
Chloromethane	<50	50	3.7	ug/L	50	"	"	"	"	"
cis-1,2-Dichloroethene	<25	25	2.8	ug/L	50	"	"	"	"	"
cis-1,3-Dichloropropene	<25	25	3.2	ug/L	50	"	"	"	"	"
Dibromochloromethane	<25	25	2.8	ug/L	50	"	"	"	"	"
Dibromomethane	<25	25	1.6	ug/L	50	"	"	"	"	"
Dichlorodifluoromethane	<100	100	3.2	ug/L	50	"	"	"	"	"
Dichlorofluoromethane	<100	100	12	ug/L	50	"	"	"	"	"
Ethyl ether	<250	250	13	ug/L	50	"	"	"	"	"
Ethylbenzene	190	25	3.2	ug/L	50	"	"	"	"	"
Hexachlorobutadiene	<25	25	2.4	ug/L	50	"	"	"	"	"
Isopropylbenzene	<25	25	3.2	ug/L	50	"	"	"	"	"
Methyl ethyl ketone	<250	250	18	ug/L	50	"	"	"	"	"
Methyl isobutyl ketone	<250	250	12	ug/L	50	"	"	"	"	"
Methyl tert-butyl ether	<25	25	12	ug/L	50	"	"	"	"	"
Methylene chloride	<250	250	22	ug/L	50	"	"	"	"	"
Naphthalene	44	25	2.2	ug/L	50	"	"	"	"	"
n-Butylbenzene	<25	25	3.1	ug/L	50	"	"	"	"	"
n-Propylbenzene	<25	25	3.5	ug/L	50	"	"	"	"	"
o-Xylene	<25	25	3.1	ug/L	50	"	"	"	"	"
p,m-Xylene	170	50	6.5	ug/L	50	"	"	"	"	"
p-Isopropyltoluene	<25	25	3.2	ug/L	50	"	"	"	"	"
sec-Butylbenzene	<25	25	3.4	ug/L	50	"	"	"	"	"
Styrene	<25	25	3.0	ug/L	50	"	"	"	"	"
tert-Butylbenzene	<25	25	3.2	ug/L	50	"	"	"	"	"
Tetrachloroethene	<25	25	3.8	ug/L	50	"	"	"	"	"
Tetrahydrofuran	<250	250	14	ug/L	50	"	"	"	"	"
Toluene	<25	25	3.4	ug/L	50	"	"	"	"	"
trans-1,2-Dichloroethene	<25	25	3.0	ug/L	50	"	"	"	"	"
trans-1,3-Dichloropropene	<25	25	3.0	ug/L	50	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0400636-06) Groundwater Sampled: 05/11/04 11:30 Received: 05/12/04 16:30										
Trichloroethene	<25	25	3.7	ug/L	50	B4E2020	05/20/04	05/20/04	EPA 8021B	
Trichlorofluoromethane	<50	50	3.0	ug/L	50	"	"	"	"	
Trichlorotrifluoroethane	<250	250	8.0	ug/L	50	"	"	"	"	
Vinyl chloride	<25	25	3.2	ug/L	50	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	100			80-120 %		"	"	"	"	
MW-05 (0400636-07) Groundwater Sampled: 05/11/04 12:20 Received: 05/12/04 16:30										
1,1,1,2-Tetrachloroethane	<500	500	33	ug/L	500	B4E2020	05/20/04	05/20/04	EPA 8021B	
1,1,1-Trichloroethane	<250	250	32	ug/L	500	"	"	"	"	
1,1,2,2-Tetrachloroethane	<250	250	28	ug/L	500	"	"	"	"	
1,1,2-Trichloroethane	<250	250	26	ug/L	500	"	"	"	"	
1,1-Dichloroethane	<250	250	28	ug/L	500	"	"	"	"	
1,1-Dichloroethene	<250	250	30	ug/L	500	"	"	"	"	
1,1-Dichloropropene	<250	250	26	ug/L	500	"	"	"	"	
1,2,3-Trichlorobenzene	<250	250	13	ug/L	500	"	"	"	"	
1,2,3-Trichloropropane	<250	250	30	ug/L	500	"	"	"	"	
1,2,4-Trichlorobenzene	<250	250	11	ug/L	500	"	"	"	"	
1,2,4-Trimethylbenzene	620	250	30	ug/L	500	"	"	"	"	
1,2-Dibromo-3-chloropropane	<250	250	12	ug/L	500	"	"	"	"	
1,2-Dibromoethane (EDB)	<250	250	20	ug/L	500	"	"	"	"	
1,2-Dichlorobenzene	<250	250	31	ug/L	500	"	"	"	"	
1,2-Dichloroethane	<250	250	27	ug/L	500	"	"	"	"	
1,2-Dichloropropane	<250	250	24	ug/L	500	"	"	"	"	
1,3,5-Trimethylbenzene	<250	250	29	ug/L	500	"	"	"	"	
1,3-Dichlorobenzene	<250	250	28	ug/L	500	"	"	"	"	
1,3-Dichloropropane	<250	250	32	ug/L	500	"	"	"	"	
1,4-Dichlorobenzene	<250	250	29	ug/L	500	"	"	"	"	
2,2-Dichloropropane	<250	250	38	ug/L	500	"	"	"	"	
2-Chlorotoluene	<250	250	30	ug/L	500	"	"	"	"	
4-Chlorotoluene	<250	250	30	ug/L	500	"	"	"	"	
Acetone	<5000	5000	1000	ug/L	500	"	"	"	"	
Allyl chloride	<500	500	140	ug/L	500	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0400636-07) Groundwater Sampled: 05/11/04 12:20 Received: 05/12/04 16:30										
Benzene	1100	250	34	ug/L	500	B4E2020	05/20/04	05/20/04	EPA 8021B	
Bromobenzene	<250	250	20	ug/L	500	"	"	"	"	"
Bromoform	<250	250	30	ug/L	500	"	"	"	"	"
Bromochloromethane	<250	250	32	ug/L	500	"	"	"	"	"
Bromodichloromethane	<250	250	19	ug/L	500	"	"	"	"	"
Bromomethane	<1000	1000	29	ug/L	500	"	"	"	"	"
Carbon tetrachloride	<250	250	12	ug/L	500	"	"	"	"	"
Chlorobenzene	<250	250	32	ug/L	500	"	"	"	"	"
Chloroethane	<500	500	37	ug/L	500	"	"	"	"	"
Chloroform	<250	250	30	ug/L	500	"	"	"	"	"
Chloromethane	<500	500	37	ug/L	500	"	"	"	"	"
cis-1,2-Dichloroethene	<250	250	28	ug/L	500	"	"	"	"	"
cis-1,3-Dichloropropene	<250	250	32	ug/L	500	"	"	"	"	"
Dibromochloromethane	<250	250	28	ug/L	500	"	"	"	"	"
Dibromomethane	<250	250	16	ug/L	500	"	"	"	"	"
Dichlorodifluoromethane	<1000	1000	32	ug/L	500	"	"	"	"	"
Dichlorofluoromethane	<1000	1000	120	ug/L	500	"	"	"	"	"
Ethyl ether	<2500	2500	130	ug/L	500	"	"	"	"	"
Ethylbenzene	1100	250	32	ug/L	500	"	"	"	"	"
Hexachlorobutadiene	<250	250	24	ug/L	500	"	"	"	"	"
Isopropylbenzene	<250	250	32	ug/L	500	"	"	"	"	"
Methyl ethyl ketone	<2500	2500	180	ug/L	500	"	"	"	"	"
Methyl isobutyl ketone	<2500	2500	120	ug/L	500	"	"	"	"	"
Methyl tert-butyl ether	<250	250	120	ug/L	500	"	"	"	"	"
Methylene chloride	<2500	2500	220	ug/L	500	"	"	"	"	"
Naphthalene	<250	250	22	ug/L	500	"	"	"	"	"
n-Butylbenzene	<250	250	31	ug/L	500	"	"	"	"	"
n-Propylbenzene	<250	250	35	ug/L	500	"	"	"	"	"
o-Xylene	1200	250	31	ug/L	500	"	"	"	"	"
p,m-Xylene	3300	500	65	ug/L	500	"	"	"	"	"
p-Isopropyltoluene	<250	250	32	ug/L	500	"	"	"	"	"
sec-Butylbenzene	<250	250	34	ug/L	500	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0400636-07) Groundwater Sampled: 05/11/04 12:20 Received: 05/12/04 16:30										
Styrene	<250	250	30	ug/L	500	B4E2020	05/20/04	05/20/04	EPA 8021B	
tert-Butylbenzene	<250	250	32	ug/L	500	"	"	"	"	"
Tetrachloroethene	<250	250	38	ug/L	500	"	"	"	"	"
Tetrahydrofuran	<2500	2500	140	ug/L	500	"	"	"	"	"
Toluene	9300	250	34	ug/L	500	"	"	"	"	"
trans-1,2-Dichloroethene	<250	250	30	ug/L	500	"	"	"	"	"
trans-1,3-Dichloropropene	<250	250	30	ug/L	500	"	"	"	"	"
Trichloroethene	<250	250	37	ug/L	500	"	"	"	"	"
Trichlorofluoromethane	<500	500	30	ug/L	500	"	"	"	"	"
Trichlorotrifluoroethane	<2500	2500	80	ug/L	500	"	"	"	"	"
Vinyl chloride	<250	250	32	ug/L	500	"	"	"	"	"
Surrogate. 4-Fluorochlorobenzene	95.0			80-120 %		"	"	"	"	"

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

GRO/8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4E1403 - EPA 5030 Water (Purge and Trap)

Blank (B4E1403-BLK1)										Prepared & Analyzed: 05/14/04
Benzene	<1.0	1.0	ug/L							
Ethylbenzene	<1.0	1.0	ug/L							
Gasoline range organics	<100	100	ug/L							
Toluene	<1.0	1.0	ug/L							
Xylenes (total)	<3.0	3.0	ug/L							
Surrogate: 4-Fluorochlorobenzene	26.9		ug/L	25.0		108	80-120			
Surrogate: 4-Fluorochlorobenzene	26.9		ug/L	25.0		108	80-120			

LCS (B4E1403-BS1)

Benzene	50.8	1.0	ug/L	50.0		102	80-120			Prepared & Analyzed: 05/14/04
Ethylbenzene	54.6	1.0	ug/L	50.0		109	80-120			
Gasoline range organics	514	100	ug/L	500		103	80-120			
Toluene	52.6	1.0	ug/L	50.0		105	80-120			
Xylenes (total)	167	3.0	ug/L	150		111	80-120			
Surrogate: 4-Fluorochlorobenzene	27.6		ug/L	25.0		110	80-120			
Surrogate: 4-Fluorochlorobenzene	27.6		ug/L	25.0		110	80-120			

LCS Dup (B4E1403-BSD1)

Benzene	52.6	1.0	ug/L	50.0		105	80-120	3.48	20	Prepared: 05/14/04 Analyzed: 05/15/04
Ethylbenzene	54.3	1.0	ug/L	50.0		109	80-120	0.551	20	
Gasoline range organics	508	100	ug/L	500		102	80-120	1.17	20	
Toluene	53.5	1.0	ug/L	50.0		107	80-120	1.70	20	
Xylenes (total)	165	3.0	ug/L	150		110	80-120	1.20	20	
Surrogate: 4-Fluorochlorobenzene	26.6		ug/L	25.0		106	80-120			
Surrogate: 4-Fluorochlorobenzene	26.6		ug/L	25.0		106	80-120			

Duplicate (B4E1403-DUP1)

Gasoline range organics	<100	100	ug/L	<100		NA	20
-------------------------	------	-----	------	------	--	----	----

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4E2020 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 05/20/04

Blank (B4E2020-BLK1)										
1,1,1,2-Tetrachloroethane	<1.0	1.0	ug/L							
1,1,1-Trichloroethane	<0.50	0.50	ug/L							
1,1,2,2-Tetrachloroethane	<0.50	0.50	ug/L							
1,1,2-Trichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethene	<0.50	0.50	ug/L							
1,1-Dichloropropene	<0.50	0.50	ug/L							
1,2,3-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,3-Trichloropropane	<0.50	0.50	ug/L							
1,2,4-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,4-Trimethylbenzene	<0.50	0.50	ug/L							
1,2-Dibromo-3-chloropropane	<0.50	0.50	ug/L							
1,2-Dibromoethane (EDB)	<0.50	0.50	ug/L							
1,2-Dichlorobenzene	<0.50	0.50	ug/L							
1,2-Dichloroethane	<0.50	0.50	ug/L							
1,2-Dichloropropene	<0.50	0.50	ug/L							
1,3,5-Trimethylbenzene	<0.50	0.50	ug/L							
1,3-Dichlorobenzene	<0.50	0.50	ug/L							
1,3-Dichloropropane	<0.50	0.50	ug/L							
1,4-Dichlorobenzene	<0.50	0.50	ug/L							
2,2-Dichloropropane	<0.50	0.50	ug/L							
2-Chlorotoluene	<0.50	0.50	ug/L							
4-Chlorotoluene	<0.50	0.50	ug/L							
Acetone	<10	10	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4E2020 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 05/20/04

Blank (B4E2020-BLK1)										
Allyl chloride	<1.0	1.0	ug/L							
Benzene	<0.50	0.50	ug/L							
Bromobenzene	<0.50	0.50	ug/L							
Bromochloromethane	<0.50	0.50	ug/L							
Bromodichloromethane	<0.50	0.50	ug/L							
Bromoform	<0.50	0.50	ug/L							
Bromomethane	<2.0	2.0	ug/L							
Carbon tetrachloride	<0.50	0.50	ug/L							
Chlorobenzene	<0.50	0.50	ug/L							
Chloroethane	<1.0	1.0	ug/L							
Chloroform	<0.50	0.50	ug/L							
Chloromethane	<1.0	1.0	ug/L							
cis-1,2-Dichloroethene	<0.50	0.50	ug/L							
cis-1,3-Dichloropropene	<0.50	0.50	ug/L							
Dibromochloromethane	<0.50	0.50	ug/L							
Dibromomethane	<0.50	0.50	ug/L							
Dichlorodifluoromethane	<2.0	2.0	ug/L							
Dichlorofluoromethane	<2.0	2.0	ug/L							
Ethyl ether	<5.0	5.0	ug/L							
Ethylbenzene	<0.50	0.50	ug/L							
Hexachlorobutadiene	<0.50	0.50	ug/L							
Isopropylbenzene	<0.50	0.50	ug/L							
Methyl ethyl ketone	<5.0	5.0	ug/L							
Methyl isobutyl ketone	<5.0	5.0	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4E2020 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 05/20/04

Blank (B4E2020-BLK1)										
Methyl tert-butyl ether	<0.50	0.50	ug/L							
Methylene chloride	<5.0	5.0	ug/L							
Naphthalene	<0.50	0.50	ug/L							
n-Butylbenzene	<0.50	0.50	ug/L							
n-Propylbenzene	<0.50	0.50	ug/L							
o-Xylene	<0.50	0.50	ug/L							
p,m-Xylene	<1.0	1.0	ug/L							
p-Isopropyltoluene	<0.50	0.50	ug/L							
sec-Butylbenzene	<0.50	0.50	ug/L							
Styrene	<0.50	0.50	ug/L							
tert-Butylbenzene	<0.50	0.50	ug/L							
Tetrachloroethene	<0.50	0.50	ug/L							
Tetrahydrofuran	<5.0	5.0	ug/L							
Toluene	<0.50	0.50	ug/L							
trans-1,2-Dichloroethene	<0.50	0.50	ug/L							
trans-1,3-Dichloropropene	<0.50	0.50	ug/L							
Trichloroethene	<0.50	0.50	ug/L							
Trichlorofluoromethane	<1.0	1.0	ug/L							
Trichlorotrifluoroethane	<5.0	5.0	ug/L							
Vinyl chloride	<0.50	0.50	ug/L							
Surrogate: 4-Fluorochlorobenzene	9.53	ug/L	10.0		95.3	80-120				

LCS (B4E2020-BS1) Prepared & Analyzed: 05/20/04

1,1-Dichloroethene	9.97	ug/L	10.0	99.7	75-120
Trichloroethene	9.95	ug/L	10.0	99.5	78.2-123

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4E2020 - EPA 5030 Water (Purge and Trap)

LCS (B4E2020-BS1) Surrogate: 4-Fluorochlorobenzene	9.09	ug/L	10.0	<	90.9	80-120	Prepared & Analyzed: 05/20/04			
Matrix Spike (B4E2020-MS1) 1,1-Dichloroethene	10.1	ug/L	10.0	<	101	75-120	Source: 0400636-01 Prepared & Analyzed: 05/20/04			
Trichloroethene	9.78	ug/L	10.0	<	97.8	80-120				
Surrogate: 4-Fluorochlorobenzene	8.97	ug/L	10.0	<	89.7	80-120				
Matrix Spike Dup (B4E2020-MSD1) 1,1-Dichloroethene	10.3	ug/L	10.0	<	103	75-120	1.96	20	Source: 0400636-01 Prepared: 05/20/04 Analyzed: 05/21/04	
Trichloroethene	9.47	ug/L	10.0	<	94.7	80-120	3.22	20		
Surrogate: 4-Fluorochlorobenzene	9.00	ug/L	10.0	<	90.0	80-120				

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
June 08, 2004

Notes and Definitions

- H Results in the Gasoline Range are primarily due to overlap from a heavier fuel hydrocarbon product.
- < Less than value listed
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- NA Not applicable. The %RPD is not calculated from values less than the reporting limit.

775 Vandalia Street, St. Paul, MN 55114 - Telephone: 651-642-1150, Fax: 651-642-1239
LEGEND TECHNICAL SERVICES, INC.
CHAIN-OF-CUSTODY RECORD

Client Name: CORTEAU ENVIRONMENTAL		Bill To: SAME		Analysis																																																																																																										
Address: 728 JAMES STREET NW ALEXANDRIA, MN 56308		Address: PO #:																																																																																																												
Attn: MATT OR SCOTT		Phone 320-846-4668 Fax: 605-882-4152																																																																																																												
Project Name: KC Kwik Stop Project #: BRODIE, MN																																																																																																														
<table border="1"> <thead> <tr> <th rowspan="2">Item No.</th> <th rowspan="2">Field ID No</th> <th colspan="2">Sample Description</th> <th rowspan="2">Collection Date</th> <th rowspan="2">Sample Matrix</th> <th rowspan="2">Lab ID No.</th> <th colspan="3">Analysis</th> </tr> <tr> <th>Date</th> <th>Time</th> <th> </th> <th> </th> <th> </th> </tr> </thead> <tbody> <tr> <td>1</td> <td>MW-01</td> <td>5/11/04</td> <td>0745</td> <td>-1</td> <td>6</td> <td>✓</td> <td>✓</td> <td>✓</td> </tr> <tr> <td>2</td> <td>07</td> <td></td> <td></td> <td>0750</td> <td>-2</td> <td>3</td> <td>✓</td> <td>✓</td> </tr> <tr> <td>3</td> <td>02</td> <td></td> <td></td> <td></td> <td>0843</td> <td>-3</td> <td>6</td> <td>✓</td> </tr> <tr> <td>4</td> <td>06</td> <td></td> <td></td> <td></td> <td>0927</td> <td>-4</td> <td>6</td> <td>✓</td> </tr> <tr> <td>5</td> <td>04</td> <td></td> <td></td> <td></td> <td>1032</td> <td>-5</td> <td>6</td> <td>✓</td> </tr> <tr> <td>6</td> <td>03</td> <td></td> <td></td> <td></td> <td>1130</td> <td>-6</td> <td>6</td> <td>✓</td> </tr> <tr> <td>7</td> <td>05</td> <td></td> <td></td> <td></td> <td>1220</td> <td>-7</td> <td>6</td> <td>✓</td> </tr> <tr> <td>8</td> <td>TRIP 3MATE</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td>✓</td> <td></td> </tr> <tr> <td>9</td> <td>TRIP 3MATE</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> </tr> <tr> <td>10</td> <td>EG</td> <td></td> <td></td> <td></td> <td></td> <td>1</td> <td></td> <td></td> </tr> </tbody> </table>						Item No.	Field ID No	Sample Description		Collection Date	Sample Matrix	Lab ID No.	Analysis			Date	Time				1	MW-01	5/11/04	0745	-1	6	✓	✓	✓	2	07			0750	-2	3	✓	✓	3	02				0843	-3	6	✓	4	06				0927	-4	6	✓	5	04				1032	-5	6	✓	6	03				1130	-6	6	✓	7	05				1220	-7	6	✓	8	TRIP 3MATE					1	✓		9	TRIP 3MATE					1			10	EG					1		
Item No.	Field ID No	Sample Description		Collection Date	Sample Matrix			Lab ID No.	Analysis																																																																																																					
		Date	Time																																																																																																											
1	MW-01	5/11/04	0745	-1	6	✓	✓	✓																																																																																																						
2	07			0750	-2	3	✓	✓																																																																																																						
3	02				0843	-3	6	✓																																																																																																						
4	06				0927	-4	6	✓																																																																																																						
5	04				1032	-5	6	✓																																																																																																						
6	03				1130	-6	6	✓																																																																																																						
7	05				1220	-7	6	✓																																																																																																						
8	TRIP 3MATE					1	✓																																																																																																							
9	TRIP 3MATE					1																																																																																																								
10	EG					1																																																																																																								
Sample Collector (please print) SCOTT HURKET		Item No 8200		Analysis																																																																																																										
Comments: 		Relinquished By: SCOTT HURKET		Analysis																																																																																																										
		Date: 5/11/04 Time: 1700		Analysis																																																																																																										
		Received By Lab: By Legend		Analysis																																																																																																										
		Date: 5/12/04 Time: 16:30		Analysis																																																																																																										

Date : 14-MAY-2004 21:07

Client ID:


Sample Info: 0400636-05

Column phase:

Instrument: PID2.i
Operator: YTP
Column diameter: 2.00

\\legendtarget\\targetdata\\chem\\PID2.i\\may14.b\\012.d

GRO MW-04



LEGEND

Technical Services, Inc.

www.legend-group.com

775 Vandalia Street
St. Paul, MN 55114
Tel: 651.642.1150
Fax: 651.642.1239

August 17, 2004

Mr. Nate Hunke
Coteau Environmental
728 Janes Circle Drive SW
Alexandria, MN 56308


Work Order Number: 0402140
RE: KC-Kwik Stop-Brooten, MN

Enclosed are the results of analyses for samples received by the laboratory on 08/04/04. If you have any questions concerning this report, please feel free to contact me.

All samples will be retained by LEGEND for 30 days from the date of this report and then discarded unless other arrangements are made.

Minnesota Certification # 027-123-295

Prepared by,
LEGEND TECHNICAL SERVICES, INC



Karla Reps
Client Representative



Chris Bremer
Laboratory Director

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
MW-01	0402140-01	Groundwater	08/02/04 09:03	08/04/04 16:45
MW-02	0402140-02	Groundwater	08/02/04 09:50	08/04/04 16:45
MW-06	0402140-03	Groundwater	08/02/04 10:42	08/04/04 16:45
MW-04	0402140-04	Groundwater	08/02/04 11:38	08/04/04 16:45
MW-03	0402140-05	Groundwater	08/02/04 12:25	08/04/04 16:45
MW-05	0402140-06	Groundwater	08/02/04 13:35	08/04/04 16:45
MW-07	0402140-07	Groundwater	08/02/04 13:40	08/04/04 16:45
Trip Blank	0402140-08	Groundwater	08/02/04 00:00	08/04/04 16:45

Shipping container information

Default Cooler

Temperature: 10.6

Received on ice: Yes

Received on melt water: No

Custody seals: No

Temperature blank was present

Ambient: No

Received on blue ice: No

Acceptable (IH/ISO only): No

Case Narrative:

The 8021 continuing calibration verification standard (CCVS) met method criteria. Methylene chloride, acetone and hexachlorobutadiene were slightly high in the CCVS. None of these compounds were reported in this project, therefore there is no data bias. Dichlorodifluoromethane, chloromethane, bromomethane, bromodichloromethane, 1,2-dibromoethane, bromoform, bromobenzene, and naphthalene were slightly low in the CCVS. Naphthalene was also slightly low in the associated spikes, which may indicate a low bias for this compound.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

GRO/8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0402140-01) Groundwater Sampled: 08/02/04 09:03 Received: 08/04/04 16:45										
Gasoline range organics	<100	100	16	ug/L	1	B4H0602	08/06/04	08/06/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	95.2			80-120 %		"	"	"	"	
MW-02 (0402140-02) Groundwater Sampled: 08/02/04 09:50 Received: 08/04/04 16:45										
Gasoline range organics	<100	100	16	ug/L	1	B4H0602	08/06/04	08/06/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	99.6			80-120 %		"	"	"	"	
MW-06 (0402140-03) Groundwater Sampled: 08/02/04 10:42 Received: 08/04/04 16:45										
Gasoline range organics	<100	100	16	ug/L	1	B4H0602	08/06/04	08/06/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	92.4			80-120 %		"	"	"	"	
MW-04 (0402140-04) Groundwater Sampled: 08/02/04 11:38 Received: 08/04/04 16:45										
Gasoline range organics	710	100	16	ug/L	1	B4H0602	08/06/04	08/06/04	Wisc Mod GRO	H
Surrogate: 4-Fluorochlorobenzene	100			80-120 %		"	"	"	"	
MW-03 (0402140-05) Groundwater Sampled: 08/02/04 12:25 Received: 08/04/04 16:45										
Gasoline range organics	260	100	16	ug/L	1	B4H0602	08/06/04	08/06/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	96.8			80-120 %		"	"	"	"	
MW-05 (0402140-06) Groundwater Sampled: 08/02/04 13:35 Received: 08/04/04 16:45										
Gasoline range organics	26000	5000	800	ug/L	50	B4H0602	08/06/04	08/09/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	99.2			80-120 %		"	"	08/06/04	"	
MW-07 (0402140-07) Groundwater Sampled: 08/02/04 13:40 Received: 08/04/04 16:45										
Benzene	1200	5.0	0.23	ug/L	5	B4H0602	08/06/04	08/06/04	EPA 8021B	
Ethylbenzene	840	5.0	0.20	ug/L	5	"	"	"	"	
Toluene	9300	50	0.80	ug/L	50	"	"	08/09/04	"	
Xylenes (total)	3700	15	0.85	ug/L	5	"	"	08/06/04	"	
Surrogate: 4-Fluorochlorobenzene	102			80-120 %		"	"	"	"	
Gasoline range organics	29000	5000	800	ug/L	50	"	"	08/09/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	102			80-120 %		"	"	08/06/04	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642 1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

GRO/8021B LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
Trip Blank (0402140-08) Groundwater Sampled: 08/02/04 00:00 Received: 08/04/04 16:45										
Benzene	<1.0	1.0	0.046	ug/L	1	B4H0602	08/06/04	08/06/04	EPA 8021B	"
Ethylbenzene	<1.0	1.0	0.040	ug/L	1	"	"	"	"	"
Toluene	<1.0	1.0	0.016	ug/L	1	"	"	"	"	"
Xylenes (total)	<3.0	3.0	0.17	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	92.8			80-120 %						

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0402140-01) Groundwater Sampled: 08/02/04 09:03 Received: 08/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4H0910	08/09/04	08/09/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D**Technical Services, Inc.**775 Vandalia Street
St Paul, MN 55114
651.642.1150Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate HunkeDate Reported:
August 17, 2004**VOC GC 8021B**
LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0402140-01) Groundwater Sampled: 08/02/04 09:03 Received: 08/04/04 16:45										
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	B4H0910	08/09/04	08/09/04	EPA 8021B	
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	<0.50	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0402140-01) Groundwater Sampled: 08/02/04 09:03 Received: 08/04/04 16:45										
Trichloroethene	<0.50	0.50	0.074	ug/L	1	B4H0910	08/09/04	08/09/04	EPA 8021B	
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	100			75-120 %		"	"	"	"	
MW-02 (0402140-02) Groundwater Sampled: 08/02/04 09:50 Received: 08/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651 642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-02 (0402140-02) Groundwater Sampled: 08/02/04 09:50 Received: 08/04/04 16:45										
Benzene	<0.50	0.50	0.067	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	<0.50	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-02 (0402140-02) Groundwater Sampled: 08/02/04 09:50 Received: 08/04/04 16:45										
Styrene	<0.50	0.50	0.060	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
tert-Butylbenzene	0.62	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	98.8			75-120 %		"	"	"	"	"
MW-06 (0402140-03) Groundwater Sampled: 08/02/04 10:42 Received: 08/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651 642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-06 (0402140-03) Groundwater Sampled: 08/02/04 10:42 Received: 08/04/04 16:45										
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651 642 1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-06 (0402140-03) Groundwater Sampled: 08/02/04 10:42 Received: 08/04/04 16:45										
Naphthalene	<0.50	0.50	0.045	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotfluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	99.3			75-120 %		"	"	"	"	"
MW-04 (0402140-04) Groundwater Sampled: 08/02/04 11:38 Received: 08/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	41	2.5	0.30	ug/L	5			08/11/04	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-04 (0402140-04) Groundwater Sampled: 08/02/04 11:38 Received: 08/04/04 16:45										
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	0.96	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-04 (0402140-04) Groundwater Sampled: 08/02/04 11:38 Received: 08/04/04 16:45										
Ethylbenzene	5.9	0.50	0.064	ug/L	1	B4H0910	08/09/04	08/10/04	EPA 8021B	
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	5.5	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	15	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	7.7	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	16	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	7.1	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	3.2	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	0.86	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	4.9	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	0.73	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	99.8			75-120 %		"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0402140-05) Groundwater Sampled: 08/02/04 12:25 Received: 08/04/04 16:45										
1,1,1,2-Tetrachloroethane	<10	10	0.66	ug/L	10	B4H0910	08/09/04	08/11/04	EPA 8021B	
1,1,1-Trichloroethane	<5.0	5.0	0.65	ug/L	10	"	"	"	"	
1,1,2,2-Tetrachloroethane	<5.0	5.0	0.57	ug/L	10	"	"	"	"	
1,1,2-Trichloroethane	<5.0	5.0	0.52	ug/L	10	"	"	"	"	
1,1-Dichloroethane	<5.0	5.0	0.57	ug/L	10	"	"	"	"	
1,1-Dichloroethene	<5.0	5.0	0.61	ug/L	10	"	"	"	"	
1,1-Dichloropropene	<5.0	5.0	0.52	ug/L	10	"	"	"	"	
1,2,3-Trichlorobenzene	<5.0	5.0	0.26	ug/L	10	"	"	"	"	
1,2,3-Trichloropropane	<5.0	5.0	0.60	ug/L	10	"	"	"	"	
1,2,4-Trichlorobenzene	<5.0	5.0	0.22	ug/L	10	"	"	"	"	
1,2,4-Trimethylbenzene	19	5.0	0.59	ug/L	10	"	"	"	"	
1,2-Dibromo-3-chloropropane	<5.0	5.0	0.25	ug/L	10	"	"	"	"	
1,2-Dibromoethane (EDB)	<5.0	5.0	0.39	ug/L	10	"	"	"	"	
1,2-Dichlorobenzene	<5.0	5.0	0.62	ug/L	10	"	"	"	"	
1,2-Dichloroethane	<5.0	5.0	0.54	ug/L	10	"	"	"	"	
1,2-Dichloropropane	<5.0	5.0	0.48	ug/L	10	"	"	"	"	
1,3,5-Trimethylbenzene	<5.0	5.0	0.58	ug/L	10	"	"	"	"	
1,3-Dichlorobenzene	<5.0	5.0	0.57	ug/L	10	"	"	"	"	
1,3-Dichloropropane	<5.0	5.0	0.64	ug/L	10	"	"	"	"	
1,4-Dichlorobenzene	<5.0	5.0	0.58	ug/L	10	"	"	"	"	
2,2-Dichloropropane	<5.0	5.0	0.75	ug/L	10	"	"	"	"	
2-Chlorotoluene	<5.0	5.0	0.60	ug/L	10	"	"	"	"	
4-Chlorotoluene	<5.0	5.0	0.59	ug/L	10	"	"	"	"	
Acetone	<100	100	20	ug/L	10	"	"	"	"	
Allyl chloride	<10	10	2.7	ug/L	10	"	"	"	"	
Benzene	<5.0	5.0	0.67	ug/L	10	"	"	"	"	
Bromobenzene	<5.0	5.0	0.39	ug/L	10	"	"	"	"	
Bromochloromethane	<5.0	5.0	0.61	ug/L	10	"	"	"	"	
Bromodichloromethane	<5.0	5.0	0.64	ug/L	10	"	"	"	"	
Bromoform	<5.0	5.0	0.38	ug/L	10	"	"	"	"	
Bromomethane	<20	20	0.58	ug/L	10	"	"	"	"	
Carbon tetrachloride	<5.0	5.0	0.25	ug/L	10	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0402140-05) Groundwater Sampled: 08/02/04 12:25 Received: 08/04/04 16:45										
Chlorobenzene	<5.0	5.0	0.64	ug/L	10	B4H0910	08/09/04	08/11/04	EPA 8021B	
Chloroethane	<10	10	0.74	ug/L	10	"	"	"	"	
Chloroform	<5.0	5.0	0.61	ug/L	10	"	"	"	"	
Chloromethane	<20	20	0.74	ug/L	10	"	"	"	"	
cis-1,2-Dichloroethene	<5.0	5.0	0.55	ug/L	10	"	"	"	"	
cis-1,3-Dichloropropene	<5.0	5.0	0.64	ug/L	10	"	"	"	"	
Dibromochloromethane	<5.0	5.0	0.55	ug/L	10	"	"	"	"	
Dibromomethane	<5.0	5.0	0.33	ug/L	10	"	"	"	"	
Dichlorodifluoromethane	<20	20	0.63	ug/L	10	"	"	"	"	
Dichlorofluoromethane	<20	20	2.3	ug/L	10	"	"	"	"	
Ethyl ether	<50	50	2.6	ug/L	10	"	"	"	"	
Ethylbenzene	51	5.0	0.64	ug/L	10	"	"	"	"	
Hexachlorobutadiene	<5.0	5.0	0.49	ug/L	10	"	"	"	"	
Isopropylbenzene	<5.0	5.0	0.64	ug/L	10	"	"	"	"	
Methyl ethyl ketone	<50	50	3.5	ug/L	10	"	"	"	"	
Methyl isobutyl ketone	<50	50	2.3	ug/L	10	"	"	"	"	
Methyl tert-butyl ether	<5.0	5.0	2.4	ug/L	10	"	"	"	"	
Methylene chloride	<50	50	4.4	ug/L	10	"	"	"	"	
Naphthalene	<5.0	5.0	0.45	ug/L	10	"	"	"	"	
n-Butylbenzene	<5.0	5.0	0.62	ug/L	10	"	"	"	"	
n-Propylbenzene	6.1	5.0	0.70	ug/L	10	"	"	"	"	
o-Xylene	<5.0	5.0	0.62	ug/L	10	"	"	"	"	
p,m-Xylene	<10	10	1.3	ug/L	10	"	"	"	"	
p-Isopropyltoluene	<5.0	5.0	0.63	ug/L	10	"	"	"	"	
sec-Butylbenzene	<5.0	5.0	0.67	ug/L	10	"	"	"	"	
Styrene	<5.0	5.0	0.60	ug/L	10	"	"	"	"	
tert-Butylbenzene	<5.0	5.0	0.63	ug/L	10	"	"	"	"	
Tetrachloroethene	<5.0	5.0	0.75	ug/L	10	"	"	"	"	
Tetrahydrofuran	<50	50	2.8	ug/L	10	"	"	"	"	
Toluene	<5.0	5.0	0.69	ug/L	10	"	"	"	"	
trans-1,2-Dichloroethene	<5.0	5.0	0.59	ug/L	10	"	"	"	"	
trans-1,3-Dichloropropene	<5.0	5.0	0.59	ug/L	10	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642 1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0402140-05) Groundwater Sampled: 08/02/04 12:25 Received: 08/04/04 16:45										
Trichloroethene	<5.0	5.0	0.74	ug/L	10	B4H0910	08/09/04	08/11/04	EPA 8021B	
Trichlorofluoromethane	<10	10	0.60	ug/L	10	"	"	"	"	
Trichlorotrifluoroethane	<50	50	1.6	ug/L	10	"	"	"	"	
Vinyl chloride	<5.0	5.0	0.65	ug/L	10	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	99.4			75-120 %		"	"	"	"	
MW-05 (0402140-06) Groundwater Sampled: 08/02/04 13:35 Received: 08/04/04 16:45										
1,1,1,2-Tetrachloroethane	<500	500	33	ug/L	500	B4H0910	08/09/04	08/10/04	EPA 8021B	
1,1,1-Trichloroethane	<250	250	32	ug/L	500	"	"	"	"	
1,1,2,2-Tetrachloroethane	<250	250	28	ug/L	500	"	"	"	"	
1,1,2-Trichloroethane	<250	250	26	ug/L	500	"	"	"	"	
1,1-Dichloroethane	<250	250	28	ug/L	500	"	"	"	"	
1,1-Dichloroethene	<250	250	30	ug/L	500	"	"	"	"	
1,1-Dichloropropene	<250	250	26	ug/L	500	"	"	"	"	
1,2,3-Trichlorobenzene	<250	250	13	ug/L	500	"	"	"	"	
1,2,3-Trichloropropane	<250	250	30	ug/L	500	"	"	"	"	
1,2,4-Trichlorobenzene	<250	250	11	ug/L	500	"	"	"	"	
1,2,4-Trimethylbenzene	450	250	30	ug/L	500	"	"	"	"	
1,2-Dibromo-3-chloropropane	<250	250	12	ug/L	500	"	"	"	"	
1,2-Dibromoethane (EDB)	<250	250	20	ug/L	500	"	"	"	"	
1,2-Dichlorobenzene	<250	250	31	ug/L	500	"	"	"	"	
1,2-Dichloroethane	<250	250	27	ug/L	500	"	"	"	"	
1,2-Dichloropropane	<250	250	24	ug/L	500	"	"	"	"	
1,3,5-Trimethylbenzene	<250	250	29	ug/L	500	"	"	"	"	
1,3-Dichlorobenzene	<250	250	28	ug/L	500	"	"	"	"	
1,3-Dichloropropane	<250	250	32	ug/L	500	"	"	"	"	
1,4-Dichlorobenzene	<250	250	29	ug/L	500	"	"	"	"	
2,2-Dichloropropane	<250	250	38	ug/L	500	"	"	"	"	
2-Chlorotoluene	<250	250	30	ug/L	500	"	"	"	"	
4-Chlorotoluene	<250	250	30	ug/L	500	"	"	"	"	
Acetone	<5000	5000	1000	ug/L	500	"	"	"	"	
Allyl chloride	<500	500	140	ug/L	500	"	"	"	"	

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0402140-06) Groundwater Sampled: 08/02/04 13:35 Received: 08/04/04 16:45										
Benzene	1300	250	34	ug/L	500	B4H0910	08/09/04	08/10/04	EPA 8021B	
Bromobenzene	<250	250	20	ug/L	500	"	"	"	"	
Bromochloromethane	<250	250	30	ug/L	500	"	"	"	"	
Bromodichloromethane	<250	250	32	ug/L	500	"	"	"	"	
Bromoform	<250	250	19	ug/L	500	"	"	"	"	
Bromomethane	<1000	1000	29	ug/L	500	"	"	"	"	
Carbon tetrachloride	<250	250	12	ug/L	500	"	"	"	"	
Chlorobenzene	<250	250	32	ug/L	500	"	"	"	"	
Chloroethane	<500	500	37	ug/L	500	"	"	"	"	
Chloroform	<250	250	30	ug/L	500	"	"	"	"	
Chloromethane	<1000	1000	37	ug/L	500	"	"	"	"	
cis-1,2-Dichloroethene	<250	250	28	ug/L	500	"	"	"	"	
cis-1,3-Dichloropropene	<250	250	32	ug/L	500	"	"	"	"	
Dibromochloromethane	<250	250	28	ug/L	500	"	"	"	"	
Dibromomethane	<250	250	16	ug/L	500	"	"	"	"	
Dichlorodifluoromethane	<1000	1000	32	ug/L	500	"	"	"	"	
Dichlorofluoromethane	<1000	1000	120	ug/L	500	"	"	"	"	
Ethyl ether	<2500	2500	130	ug/L	500	"	"	"	"	
Ethylbenzene	870	250	32	ug/L	500	"	"	"	"	
Hexachlorobutadiene	<250	250	24	ug/L	500	"	"	"	"	
Isopropylbenzene	<250	250	32	ug/L	500	"	"	"	"	
Methyl ethyl ketone	<2500	2500	180	ug/L	500	"	"	"	"	
Methyl isobutyl ketone	<2500	2500	120	ug/L	500	"	"	"	"	
Methyl tert-butyl ether	<250	250	120	ug/L	500	"	"	"	"	
Methylene chloride	<2500	2500	220	ug/L	500	"	"	"	"	
Naphthalene	<250	250	22	ug/L	500	"	"	"	"	
n-Butylbenzene	<250	250	31	ug/L	500	"	"	"	"	
n-Propylbenzene	<250	250	35	ug/L	500	"	"	"	"	
o-Xylene	1100	250	31	ug/L	500	"	"	"	"	
p,m-Xylene	2700	500	65	ug/L	500	"	"	"	"	
p-Isopropyltoluene	<250	250	32	ug/L	500	"	"	"	"	
sec-Butylbenzene	<250	250	34	ug/L	500	"	"	"	"	

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0402140-06) Groundwater Sampled: 08/02/04 13:35 Received: 08/04/04 16:45										
Styrene	<250	250	30	ug/L	500	B4H0910	08/09/04	08/10/04	EPA 8021B	
tert-Butylbenzene	<250	250	32	ug/L	500	"	"	"	"	"
Tetrachloroethene	<250	250	38	ug/L	500	"	"	"	"	"
Tetrahydrofuran	<2500	2500	140	ug/L	500	"	"	"	"	"
Toluene	8800	250	34	ug/L	500	"	"	"	"	"
trans-1,2-Dichloroethene	<250	250	30	ug/L	500	"	"	"	"	"
trans-1,3-Dichloropropene	<250	250	30	ug/L	500	"	"	"	"	"
Trichloroethene	<250	250	37	ug/L	500	"	"	"	"	"
Trichlorofluoromethane	<500	500	30	ug/L	500	"	"	"	"	"
Trichlorotrifluoroethane	<2500	2500	80	ug/L	500	"	"	"	"	"
Vinyl chloride	<250	250	32	ug/L	500	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	100			75-120 %		"	"	"	"	"

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

GRO/8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4H0602 - EPA 5030 Water (Purge and Trap)

Blank (B4H0602-BLK1)										Prepared & Analyzed: 08/06/04
Benzene	<1.0	1.0	ug/L							
Ethylbenzene	<1.0	1.0	ug/L							
Gasoline range organics	<100	100	ug/L							
Toluene	<1.0	1.0	ug/L							
Xylenes (total)	<3.0	3.0	ug/L							
Surrogate: 4-Fluorochlorobenzene	22.5		ug/L	25.0		90.0	80-120			
Surrogate 4-Fluorochlorobenzene	22.5		ug/L	25.0		90.0	80-120			

LCS (B4H0602-BS1)

										Prepared & Analyzed: 08/06/04
Benzene	90.8	1.0	ug/L	100		90.8	80-120			
Ethylbenzene	96.0	1.0	ug/L	100		96.0	80-120			
Gasoline range organics	1070	100	ug/L	1000		107	80-120			
Toluene	91.9	1.0	ug/L	100		91.9	80-120			
Xylenes (total)	281	3.0	ug/L	300		93.7	80-120			
Surrogate 4-Fluorochlorobenzene	24.0		ug/L	25.0		96.0	80-120			
Surrogate 4-Fluorochlorobenzene	24.0		ug/L	25.0		96.0	80-120			

LCS Dup (B4H0602-BSD1)

										Prepared: 08/06/04 Analyzed: 08/07/04
Benzene	89.6	1.0	ug/L	100		89.6	80-120	1.33	20	
Ethylbenzene	93.5	1.0	ug/L	100		93.5	80-120	2.64	20	
Gasoline range organics	1080	100	ug/L	1000		108	80-120	0.930	20	
Toluene	89.5	1.0	ug/L	100		89.5	80-120	2.65	20	
Xylenes (total)	275	3.0	ug/L	300		91.7	80-120	2.16	20	
Surrogate 4-Fluorochlorobenzene	24.0		ug/L	25.0		96.0	80-120			
Surrogate 4-Fluorochlorobenzene	24.0		ug/L	25.0		96.0	80-120			

Duplicate (B4H0602-DUP1)

Gasoline range organics					Source: 0402140-01					Prepared: 08/06/04 Analyzed: 08/07/04
	<100	100	ug/L			<100				NA 20

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

GRO/8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4H0602 - EPA 5030 Water (Purge and Trap)										
Duplicate (B4H0602-DUP1) Source: 0402140-01 Prepared: 08/06/04 Analyzed: 08/07/04										
Surrogate: 4-Fluorochlorobenzene	22.5		ug/L		25.0		90.0	80-120		
Surrogate: 4-Fluorochlorobenzene	22.5		ug/L		25.0		90.0	80-120		
Matrix Spike (B4H0602-MS1) Source: 0402140-01 Prepared: 08/06/04 Analyzed: 08/07/04										
Benzene	89.8	1.0	ug/L	100	<1.0	89.6	80-120			
Ethylbenzene	93.7	1.0	ug/L	100	<1.0	93.3	80-120			
Toluene	89.0	1.0	ug/L	100	<1.0	89.0	80-120			
Xylenes (total)	273	3.0	ug/L	300	<3.0	91.0	80-120			
Surrogate: 4-Fluorochlorobenzene	24.4		ug/L		25.0		97.6	80-120		
Surrogate: 4-Fluorochlorobenzene	24.4		ug/L		25.0		97.6	80-120		

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4H0910 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 08/09/04

Blank (B4H0910-BLK1)

1,1,1,2-Tetrachloroethane	<1.0	1.0	ug/L							
1,1,1-Trichloroethane	<0.50	0.50	ug/L							
1,1,2,2-Tetrachloroethane	<0.50	0.50	ug/L							
1,1,2-Trichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethene	<0.50	0.50	ug/L							
1,1-Dichloropropene	<0.50	0.50	ug/L							
1,2,3-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,3-Trichloropropane	<0.50	0.50	ug/L							
1,2,4-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,4-Trimethylbenzene	<0.50	0.50	ug/L							
1,2-Dibromo-3-chloropropane	<0.50	0.50	ug/L							
1,2-Dibromoethane (EDB)	<0.50	0.50	ug/L							
1,2-Dichlorobenzene	<0.50	0.50	ug/L							
1,2-Dichloroethane	<0.50	0.50	ug/L							
1,2-Dichloropropane	<0.50	0.50	ug/L							
1,3,5-Trimethylbenzene	<0.50	0.50	ug/L							
1,3-Dichlorobenzene	<0.50	0.50	ug/L							
1,3-Dichloropropane	<0.50	0.50	ug/L							
1,4-Dichlorobenzene	<0.50	0.50	ug/L							
2,2-Dichloropropane	<0.50	0.50	ug/L							
2-Chlorotoluene	<0.50	0.50	ug/L							
4-Chlorotoluene	<0.50	0.50	ug/L							
Acetone	<10	10	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4H0910 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 08/09/04

Blank (B4H0910-BLK1)

Allyl chloride	<1.0	1.0	ug/L							
Benzene	<0.50	0.50	ug/L							
Bromobenzene	<0.50	0.50	ug/L							
Bromochloromethane	<0.50	0.50	ug/L							
Bromodichloromethane	<0.50	0.50	ug/L							
Bromoform	<0.50	0.50	ug/L							
Bromomethane	<2.0	2.0	ug/L							
Carbon tetrachloride	<0.50	0.50	ug/L							
Chlorobenzene	<0.50	0.50	ug/L							
Chloroethane	<1.0	1.0	ug/L							
Chloroform	<0.50	0.50	ug/L							
Chloromethane	<2.0	2.0	ug/L							
cis-1,2-Dichloroethene	<0.50	0.50	ug/L							
cis-1,3-Dichloropropene	<0.50	0.50	ug/L							
Dibromochloromethane	<0.50	0.50	ug/L							
Dibromomethane	<0.50	0.50	ug/L							
Dichlorodifluoromethane	<2.0	2.0	ug/L							
Dichlorofluoromethane	<2.0	2.0	ug/L							
Ethyl ether	<5.0	5.0	ug/L							
Ethylbenzene	<0.50	0.50	ug/L							
Hexachlorobutadiene	<0.50	0.50	ug/L							
Isopropylbenzene	<0.50	0.50	ug/L							
Methyl ethyl ketone	<5.0	5.0	ug/L							
Methyl isobutyl ketone	<5.0	5.0	ug/L							

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4H0910 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 08/09/04

Blank (B4H0910-BLK1)										
Methyl tert-butyl ether	<0.50	0.50	ug/L							
Methylene chloride	<5.0	5.0	ug/L							
Naphthalene	<0.50	0.50	ug/L							
n-Butylbenzene	<0.50	0.50	ug/L							
n-Propylbenzene	<0.50	0.50	ug/L							
o-Xylene	<0.50	0.50	ug/L							
p,m-Xylene	<1.0	1.0	ug/L							
p-Isopropyltoluene	<0.50	0.50	ug/L							
sec-Butylbenzene	<0.50	0.50	ug/L							
Styrene	<0.50	0.50	ug/L							
tert-Butylbenzene	<0.50	0.50	ug/L							
Tetrachloroethene	<0.50	0.50	ug/L							
Tetrahydrofuran	<5.0	5.0	ug/L							
Toluene	<0.50	0.50	ug/L							
trans-1,2-Dichloroethene	<0.50	0.50	ug/L							
trans-1,3-Dichloropropene	<0.50	0.50	ug/L							
Trichloroethene	<0.50	0.50	ug/L							
Trichlorofluoromethane	<1.0	1.0	ug/L							
Trichlorotrifluoroethane	<5.0	5.0	ug/L							
Vinyl chloride	<0.50	0.50	ug/L							
Surrogate: 4-Fluorochlorobenzene	9.48	ug/L		10.0		94.8	75-120			

Prepared: 08/09/04 Analyzed: 08/10/04

Blank (B4H0910-BLK2)										
1,1,1,2-Tetrachloroethane	<1.0	1.0	ug/L							
1,1,1-Trichloroethane	<0.50	0.50	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4H0910 - EPA 5030 Water (Purge and Trap)										
Blank (B4H0910-BLK2)										Prepared: 08/09/04 Analyzed: 08/10/04
1,1,2,2-Tetrachloroethane	<0.50	0.50	ug/L							
1,1,2-Trichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethene	<0.50	0.50	ug/L							
1,1-Dichloropropene	<0.50	0.50	ug/L							
1,2,3-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,3-Trichloropropane	<0.50	0.50	ug/L							
1,2,4-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,4-Trimethylbenzene	<0.50	0.50	ug/L							
1,2-Dibromo-3-chloropropane	<0.50	0.50	ug/L							
1,2-Dibromoethane (EDB)	<0.50	0.50	ug/L							
1,2-Dichlorobenzene	<0.50	0.50	ug/L							
1,2-Dichloroethane	<0.50	0.50	ug/L							
1,2-Dichloropropane	<0.50	0.50	ug/L							
1,3,5-Trimethylbenzene	<0.50	0.50	ug/L							
1,3-Dichlorobenzene	<0.50	0.50	ug/L							
1,3-Dichloropropane	<0.50	0.50	ug/L							
1,4-Dichlorobenzene	<0.50	0.50	ug/L							
2,2-Dichloropropane	<0.50	0.50	ug/L							
2-Chlorotoluene	<0.50	0.50	ug/L							
4-Chlorotoluene	<0.50	0.50	ug/L							
Acetone	<10	10	ug/L							
Allyl chloride	<1.0	1.0	ug/L							
Benzene	<0.50	0.50	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642 1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4H0910 - EPA 5030 Water (Purge and Trap)

Prepared: 08/09/04 Analyzed: 08/10/04

Blank (B4H0910-BLK2)										
Bromobenzene	<0.50	0.50	ug/L							
Bromochloromethane	<0.50	0.50	ug/L							
Bromodichloromethane	<0.50	0.50	ug/L							
Bromoform	<0.50	0.50	ug/L							
Bromomethane	<2.0	2.0	ug/L							
Carbon tetrachloride	<0.50	0.50	ug/L							
Chlorobenzene	<0.50	0.50	ug/L							
Chloroethane	<1.0	1.0	ug/L							
Chloroform	<0.50	0.50	ug/L							
Chloromethane	<2.0	2.0	ug/L							
cis-1,2-Dichloroethene	<0.50	0.50	ug/L							
cis-1,3-Dichloropropene	<0.50	0.50	ug/L							
Dibromochloromethane	<0.50	0.50	ug/L							
Dibromomethane	<0.50	0.50	ug/L							
Dichlorodifluoromethane	<2.0	2.0	ug/L							
Dichlorofluoromethane	<2.0	2.0	ug/L							
Ethyl ether	<5.0	5.0	ug/L							
Ethylbenzene	<0.50	0.50	ug/L							
Hexachlorobutadiene	<0.50	0.50	ug/L							
Isopropylbenzene	<0.50	0.50	ug/L							
Methyl ethyl ketone	<5.0	5.0	ug/L							
Methyl isobutyl ketone	<5.0	5.0	ug/L							
Methyl tert-butyl ether	<0.50	0.50	ug/L							
Methylene chloride	<5.0	5.0	ug/L							

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4H0910 - EPA 5030 Water (Purge and Trap)										
Blank (B4H0910-BLK2) Prepared: 08/09/04 Analyzed: 08/10/04										
Naphthalene	<0.50	0.50	ug/L							
n-Butylbenzene	<0.50	0.50	ug/L							
n-Propylbenzene	<0.50	0.50	ug/L							
o-Xylene	<0.50	0.50	ug/L							
p,m-Xylene	<1.0	1.0	ug/L							
p-Isopropyltoluene	<0.50	0.50	ug/L							
sec-Butylbenzene	<0.50	0.50	ug/L							
Styrene	<0.50	0.50	ug/L							
tert-Butylbenzene	<0.50	0.50	ug/L							
Tetrachloroethene	<0.50	0.50	ug/L							
Tetrahydrofuran	<5.0	5.0	ug/L							
Toluene	<0.50	0.50	ug/L							
trans-1,2-Dichloroethene	<0.50	0.50	ug/L							
trans-1,3-Dichloropropene	<0.50	0.50	ug/L							
Trichloroethene	<0.50	0.50	ug/L							
Trichlorofluoromethane	<1.0	1.0	ug/L							
Trichlorotrifluoroethane	<5.0	5.0	ug/L							
Vinyl chloride	<0.50	0.50	ug/L							
Surrogate: 4-Fluorochlorobenzene	10.1	ug/L	10.0		101	75-120				

LCS (B4H0910-BS1) Prepared: 08/09/04 Analyzed: 08/10/04

1,1-Dichloroethene	9.15	ug/L	10.0	91.5	75-125
Benzene	9.55	ug/L	10.0	95.5	75-125
Chlorobenzene	9.74	ug/L	10.0	97.4	75-125
Toluene	9.56	ug/L	10.0	95.6	75-125

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:

**VOC GC 8021B - Quality Control
LEGEND Technical Services, Inc**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4H0910 - EPA 5030 Water (Purge and Trap)										
LCS (B4H0910-BS1)									Prepared: 08/09/04	Analyzed: 08/10/04
Trichloroethene	9.65		ug/L	10.0		96.5	75-125			
Surrogate: 4-Fluorochlorobenzene	8.75		ug/L	10.0		87.5	75-120			
LCS (B4H0910-BS2)									Prepared: 08/09/04	Analyzed: 08/10/04
1,1-Dichloroethene	8.71		ug/L	10.0		87.1	75-125			
Benzene	9.58		ug/L	10.0		95.8	75-125			
Chlorobenzene	9.59		ug/L	10.0		95.9	75-125			
Toluene	9.56		ug/L	10.0		95.6	75-125			
Trichloroethene	9.63		ug/L	10.0		96.3	75-125			
Surrogate: 4-Fluorochlorobenzene	8.68		ug/L	10.0		86.8	75-120			
Matrix Spike (B4H0910-MS1)									Source: 0402140-01	Prepared: 08/09/04
1,1-Dichloroethene	9.76		ug/L	10.0	<	97.6	75-125			Analyzed: 08/10/04
Benzene	9.65		ug/L	10.0	<	96.5	75-125			
Chlorobenzene	9.64		ug/L	10.0	<	96.4	75-125			
Toluene	9.40		ug/L	10.0	<	94.0	75-125			
Trichloroethene	9.88		ug/L	10.0	<	98.8	75-125			
Surrogate: 4-Fluorochlorobenzene	8.74		ug/L	10.0		87.4	75-120			
Matrix Spike (B4H0910-MS2)									Source: 0402112-01	Prepared: 08/09/04
1,1-Dichloroethene	9.40		ug/L	10.0	<	94.0	75-125			Analyzed: 08/10/04
Benzene	9.68		ug/L	10.0	<	96.8	75-125			
Chlorobenzene	9.62		ug/L	10.0	<	96.2	75-125			
Toluene	9.43		ug/L	10.0	<	94.3	75-125			
Trichloroethene	9.58		ug/L	10.0	<	95.8	75-125			
Surrogate: 4-Fluorochlorobenzene	8.66		ug/L	10.0		86.6	75-120			
Matrix Spike Dup (B4H0910-MSD1)									Source: 0402140-01	Prepared: 08/09/04
										Analyzed: 08/10/04

LEGEND Technical Services, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D**Technical Services, Inc.**775 Vandalia Street
St Paul, MN 55114
651.642.1150Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate HunkeDate Reported:
August 17, 2004**VOC GC 8021B - Quality Control**
LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4H0910 - EPA 5030 Water (Purge and Trap)										
Matrix Spike Dup (B4H0910-MSD1) Source: 0402140-01 Prepared: 08/09/04 Analyzed: 08/10/04										
1,1-Dichloroethene	9.70	ug/L	10.0	<	97.0	75-125	0.617	20		
Benzene	9.64	ug/L	10.0	<	96.4	75-125	0.104	20		
Chlorobenzene	9.60	ug/L	10.0	<	96.0	75-125	0.416	20		
Toluene	9.37	ug/L	10.0	<	93.7	75-125	0.320	20		
Trichloroethene	9.87	ug/L	10.0	<	98.7	75-125	0.101	20		
Surrogate: 4-Fluorochlorobenzene	8.65	ug/L	10.0		86.5	75-120				
Matrix Spike Dup (B4H0910-MSD2) Source: 0402112-01 Prepared: 08/09/04 Analyzed: 08/10/04										
1,1-Dichloroethene	9.20	ug/L	10.0	<	92.0	75-125	2.15	20		
Benzene	9.69	ug/L	10.0	<	96.9	75-125	0.103	20		
Chlorobenzene	9.62	ug/L	10.0	<	96.2	75-125	0.00	20		
Toluene	9.40	ug/L	10.0	<	94.0	75-125	0.319	20		
Trichloroethene	9.16	ug/L	10.0	<	91.6	75-125	4.48	20		
Surrogate: 4-Fluorochlorobenzene	8.67	ug/L	10.0		86.7	75-120				

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Nate Hunke

Date Reported:
August 17, 2004

Notes and Definitions

- H Results in the Gasoline Range are primarily due to overlap from a heavier fuel hydrocarbon product.
- < Less than value listed
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- NA Not applicable. The %RPD is not calculated from values less than the reporting limit.

Data File: \\legendtarget\\targetdata\\chem\\PID3.i\\aug06.b\\005.d

Date : 06-AUG-2004 14:19

Client ID:

Sample Info: 0402140-04

Instrument: PID3.i

Operator: YTP

Column diameter: 2.00

Column phase:

1.2-

1.1-

1.0-

0.9-

0.8-

0.7-

0.6-

0.5-

0.4-

0.3-


0.2-

0.1-

0.0-

GRO in ur-04

\\legendtarget\\targetdata\\chem\\PID3.i\\aug06.b\\005.d



LEGEND TECHNICAL SERVICES, INC.

775 Vandalia Street, St. Paul, MN 55114 - Telephone: 651-642-1150, Fax: 651-642-1239

CHAIN-OF-CUSTODY RECORD

Client Name:		Bill To:	Sample	LEGEND Project #: 1402140		Analysis	
Address:				Turnaround Time:			
<u>COTMAN ENVIRONMENTAL</u> 728 JAMES CIRCLE DR ALEXANDRIA, MD 20308				<input checked="" type="checkbox"/> Normal	<input type="checkbox"/> RUSH Date _____		
Attn:	<u>NATE OR SCOTT</u>	PO #:		Condition Received:			
Phone:	<u>301-846-4668</u>	Fax:	<u>605-882-4152</u>	<input type="checkbox"/> Received at <u>10.6</u> °C			
Project Name:	<u>KC Keweenaw Stream</u>	Project #:	<u>B200701, mnl</u>	<input checked="" type="checkbox"/> Received on ice			
				<input type="checkbox"/> Received ambient			
				<input type="checkbox"/> No temp blank			
				<input type="checkbox"/> Acceptable			
				Collection Date	Time	Sample Matrix	Lab ID No.
Item No.	Field ID No.	Sample Description					
1	MW2-01	water		8/26/4	0903	water	-1
2	02			0950		-2	6 ✓ ✓
3	06			1042		-3	6 ✓ ✓
4	04			1138		-4	6 ✓ ✓
5	03			1225		-5	6 ✓ ✓
6	05			1335		-6	6 ✓ ✓
7	07			1340		-7	3 ✓ ✓
8	TRP BLANK					-8	1 ✓
9	TEMP BLANK						1
10							
Comments:		Sample Collector (please print): <u>SCOTT HUNKET</u>	Item No	Relinquished By <u>Janet</u>	Date: <u>8/3/04</u>	Time: <u>0800</u>	Accepted By: <u>Ray Taylor</u>
		Item No	Relinquished By	Date:	Time:	Date: <u>8/4/04</u>	Time: <u>16:45</u>

PLEASE REVIEW TERMS AND CONDITIONS ON BACK BEFORE SIGNING
 White Copy - Original Accompanies Shipment to Lab Yellow Copy - Lab Pink Copy - Customer or Field Copy

L E G E N D

Technical Services, Inc.

www.legend-group.com

775 Vandalia Street
St. Paul, MN 55114
Tel: 651.642.1150
Fax: 651.642.1239

November 19, 2004

Mr. Scott Hunke
Coteau Environmental
728 Janes Circle Drive SW
Alexandria, MN 56308

Work Order Number: 0403756
RE: KC-Kwik Stop-Brooten, MN

Enclosed are the results of analyses for samples received by the laboratory on 11/04/04. If you have any questions concerning this report, please feel free to contact me.

All samples will be retained by LEGEND for 30 days from the date of this report and then discarded unless other arrangements are made.

Minnesota Certification # 027-123-295

Prepared by,
LEGEND TECHNICAL SERVICES, INC



Karla Reps
Client Representative



Chris Bremer
Laboratory Director

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
MW-01	0403756-01	Groundwater	11/03/04 07:54	11/04/04 16:45
MW-02	0403756-02	Groundwater	11/03/04 08:46	11/04/04 16:45
MW-06	0403756-03	Groundwater	11/03/04 09:42	11/04/04 16:45
MW-04	0403756-04	Groundwater	11/03/04 10:38	11/04/04 16:45
MW-03	0403756-05	Groundwater	11/03/04 11:40	11/04/04 16:45
MW-05	0403756-06	Groundwater	11/03/04 12:32	11/04/04 16:45
MW-07	0403756-07	Groundwater	11/03/04 12:37	11/04/04 16:45
Trip Blank	0403756-08	Groundwater	05/04/04 00:00	11/04/04 16:45

Shipping container information

Default Cooler

Temperature: 4.5

Received on ice: Yes
Received on melt water: No
Custody seals: No

Temperature blank was present
Ambient: No

Received on blue ice: No
Acceptable (IH/ISO only): No

Case Narrative:

The 8021 continuing calibration verification standard (CCVS) met method criteria. Chloromethane and methylene chloride were slightly high in the CCVS. Chloromethane was not recovered in this project, therefore, there is no data bias. Methylene chloride results may be biased high in sample 0403756-06.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental 728 Janes Circle Drive SW Alexandria MN, 56308	Project: KC-Kwik Stop-Brooten, MN Project Number: KC Kwik Stop-Brooten, MN Project Manager: Mr. Scott Hunke	Date Reported: November 19, 2004
---	---	-------------------------------------

GRO/8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Reporting Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0403756-01) Groundwater	Sampled: 11/03/04 07:54	Received: 11/04/04 16:45								
Gasoline range organics	<100	100	29	ug/L	1	B4K1003	11/10/04	11/10/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	90.8			80-120 %		"	"	"	"	"
MW-02 (0403756-02) Groundwater	Sampled: 11/03/04 08:46	Received: 11/04/04 16:45								
Gasoline range organics	<100	100	29	ug/L	1	B4K1003	11/10/04	11/10/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	91.6			80-120 %		"	"	"	"	"
MW-06 (0403756-03) Groundwater	Sampled: 11/03/04 09:42	Received: 11/04/04 16:45								
Gasoline range organics	<100	100	29	ug/L	1	B4K1108	11/11/04	11/11/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	81.2			80-120 %		"	"	"	"	"
MW-04 (0403756-04) Groundwater	Sampled: 11/03/04 10:38	Received: 11/04/04 16:45								
Gasoline range organics	640	100	29	ug/L	1	B4K1002	11/10/04	11/10/04	Wisc Mod GRO	H
Surrogate: 4-Fluorochlorobenzene	106			80-120 %		"	"	"	"	"
MW-03 (0403756-05) Groundwater	Sampled: 11/03/04 11:40	Received: 11/04/04 16:45								
Gasoline range organics	740	100	29	ug/L	1	B4K1002	11/10/04	11/11/04	Wisc Mod GRO	H
Surrogate: 4-Fluorochlorobenzene	97.6			80-120 %		"	"	"	"	"
MW-05 (0403756-06) Groundwater	Sampled: 11/03/04 12:32	Received: 11/04/04 16:45								
Gasoline range organics	19000	1000	290	ug/L	10	B4K1002	11/10/04	11/11/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	104			80-120 %		"	"	"	"	"
MW-07 (0403756-07) Groundwater	Sampled: 11/03/04 12:37	Received: 11/04/04 16:45								
Gasoline range organics	21000	2500	720	ug/L	25	B4K1108	11/11/04	11/11/04	Wisc Mod GRO	
Surrogate: 4-Fluorochlorobenzene	103			80-120 %		"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0403756-01) Groundwater Sampled: 11/03/04 07:54 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	"
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0403756-01) Groundwater Sampled: 11/03/04 07:54 Received: 11/04/04 16:45										
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	<0.50	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-01 (0403756-01) Groundwater Sampled: 11/03/04 07:54 Received: 11/04/04 16:45										
Trichloroethene	<0.50	0.50	0.074	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	110			75-120 %						
MW-02 (0403756-02) Groundwater Sampled: 11/03/04 08:46 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-02 (0403756-02) Groundwater Sampled: 11/03/04 08:46 Received: 11/04/04 16:45										
Benzene	<0.50	0.50	0.067	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	<0.50	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

L E G E N D

Technical Services, Inc.

 775 Vandalia Street
 St Paul, MN 55114
 651.642.1150

 Coteau Environmental
 728 Janes Circle Drive SW
 Alexandria MN, 56308

 Project: KC-Kwik Stop-Brooten, MN
 Project Number: KC Kwik Stop-Brooten, MN
 Project Manager: Mr. Scott Hunke

 Date Reported:
 November 19, 2004

VOC GC 8021B
LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-02 (0403756-02) Groundwater Sampled: 11/03/04 08:46 Received: 11/04/04 16:45										
Styrene	<0.50	0.50	0.060	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	114			75-120 %		"	"	"	"	"
MW-06 (0403756-03) Groundwater Sampled: 11/03/04 09:42 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-06 (0403756-03) Groundwater Sampled: 11/03/04 09:42 Received: 11/04/04 16:45										
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"
Benzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	<5.0	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-06 (0403756-03) Groundwater Sampled: 11/03/04 09:42 Received: 11/04/04 16:45										
Naphthalene	<0.50	0.50	0.045	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
n-Butylbenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	<0.50	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	<0.50	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	118			75-120 %		"	"	"	"	"
MW-04 (0403756-04) Groundwater Sampled: 11/03/04 10:38 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<1.0	1.0	0.066	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
1,1,1-Trichloroethane	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1,2-Trichloroethane	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,1-Dichloroethane	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,1-Dichloroethene	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
1,1-Dichloropropene	<0.50	0.50	0.052	ug/L	1	"	"	"	"	"
1,2,3-Trichlorobenzene	<0.50	0.50	0.026	ug/L	1	"	"	"	"	"
1,2,3-Trichloropropane	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
1,2,4-Trichlorobenzene	<0.50	0.50	0.022	ug/L	1	"	"	"	"	"
1,2,4-Trimethylbenzene	25	0.50	0.059	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-04 (0403756-04) Groundwater Sampled: 11/03/04 10:38 Received: 11/04/04 16:45										
1,2-Dibromo-3-chloropropane	<0.50	0.50	0.025	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
1,2-Dibromoethane (EDB)	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
1,2-Dichlorobenzene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	"
1,2-Dichloroethane	<0.50	0.50	0.054	ug/L	1	"	"	"	"	"
1,2-Dichloropropane	<0.50	0.50	0.048	ug/L	1	"	"	"	"	"
1,3,5-Trimethylbenzene	8.7	0.50	0.058	ug/L	1	"	"	"	"	"
1,3-Dichlorobenzene	<0.50	0.50	0.057	ug/L	1	"	"	"	"	"
1,3-Dichloropropane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
1,4-Dichlorobenzene	<0.50	0.50	0.058	ug/L	1	"	"	"	"	"
2,2-Dichloropropane	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
2-Chlorotoluene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
4-Chlorotoluene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Acetone	<10	10	2.0	ug/L	1	"	"	"	"	"
Allyl chloride	<1.0	1.0	0.27	ug/L	1	"	"	"	"	"
Benzene	2.9	0.50	0.067	ug/L	1	"	"	"	"	"
Bromobenzene	<0.50	0.50	0.039	ug/L	1	"	"	"	"	"
Bromochloromethane	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Bromodichloromethane	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Bromoform	<0.50	0.50	0.038	ug/L	1	"	"	"	"	"
Bromomethane	<2.0	2.0	0.058	ug/L	1	"	"	"	"	"
Carbon tetrachloride	<0.50	0.50	0.025	ug/L	1	"	"	"	"	"
Chlorobenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Chloroethane	<1.0	1.0	0.074	ug/L	1	"	"	"	"	"
Chloroform	<0.50	0.50	0.061	ug/L	1	"	"	"	"	"
Chloromethane	<2.0	2.0	0.074	ug/L	1	"	"	"	"	"
cis-1,2-Dichloroethene	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
cis-1,3-Dichloropropene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	"
Dibromochloromethane	<0.50	0.50	0.055	ug/L	1	"	"	"	"	"
Dibromomethane	<0.50	0.50	0.033	ug/L	1	"	"	"	"	"
Dichlorodifluoromethane	<2.0	2.0	0.063	ug/L	1	"	"	"	"	"
Dichlorofluoromethane	<2.0	2.0	0.23	ug/L	1	"	"	"	"	"
Ethyl ether	<5.0	5.0	0.26	ug/L	1	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-04 (0403756-04) Groundwater Sampled: 11/03/04 10:38 Received: 11/04/04 16:45										
Ethylbenzene	18	0.50	0.064	ug/L	1	B4K0907	11/09/04	11/09/04	EPA 8021B	
Hexachlorobutadiene	<0.50	0.50	0.049	ug/L	1	"	"	"	"	"
Isopropylbenzene	6.3	0.50	0.064	ug/L	1	"	"	"	"	"
Methyl ethyl ketone	5.4	5.0	0.35	ug/L	1	"	"	"	"	"
Methyl isobutyl ketone	<5.0	5.0	0.23	ug/L	1	"	"	"	"	"
Methyl tert-butyl ether	<0.50	0.50	0.24	ug/L	1	"	"	"	"	"
Methylene chloride	<5.0	5.0	0.44	ug/L	1	"	"	"	"	"
Naphthalene	13	0.50	0.045	ug/L	1	"	"	"	"	"
n-Butylbenzene	8.1	0.50	0.062	ug/L	1	"	"	"	"	"
n-Propylbenzene	18	0.50	0.070	ug/L	1	"	"	"	"	"
o-Xylene	3.6	0.50	0.062	ug/L	1	"	"	"	"	"
p,m-Xylene	2.4	1.0	0.13	ug/L	1	"	"	"	"	"
p-Isopropyltoluene	0.50	0.50	0.063	ug/L	1	"	"	"	"	"
sec-Butylbenzene	4.9	0.50	0.067	ug/L	1	"	"	"	"	"
Styrene	<0.50	0.50	0.060	ug/L	1	"	"	"	"	"
tert-Butylbenzene	<0.50	0.50	0.063	ug/L	1	"	"	"	"	"
Tetrachloroethene	<0.50	0.50	0.075	ug/L	1	"	"	"	"	"
Tetrahydrofuran	<5.0	5.0	0.28	ug/L	1	"	"	"	"	"
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	"
trans-1,2-Dichloroethene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
trans-1,3-Dichloropropene	<0.50	0.50	0.059	ug/L	1	"	"	"	"	"
Trichloroethene	<0.50	0.50	0.074	ug/L	1	"	"	"	"	"
Trichlorofluoromethane	<1.0	1.0	0.060	ug/L	1	"	"	"	"	"
Trichlorotrifluoroethane	<5.0	5.0	0.16	ug/L	1	"	"	"	"	"
Vinyl chloride	<0.50	0.50	0.065	ug/L	1	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	113			75-120 %		"	"	"	"	"

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0403756-05) Groundwater Sampled: 11/03/04 11:40 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<20	20	1.3	ug/L	20	B4K0908	11/09/04	11/10/04	EPA 8021B	
1,1,1-Trichloroethane	<10	10	1.3	ug/L	20	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<10	10	1.1	ug/L	20	"	"	"	"	"
1,1,2-Trichloroethane	<10	10	1.0	ug/L	20	"	"	"	"	"
1,1-Dichloroethane	<10	10	1.1	ug/L	20	"	"	"	"	"
1,1-Dichloroethene	<10	10	1.2	ug/L	20	"	"	"	"	"
1,1-Dichloropropene	<10	10	1.0	ug/L	20	"	"	"	"	"
1,2,3-Trichlorobenzene	<10	10	0.52	ug/L	20	"	"	"	"	"
1,2,3-Trichloropropane	<10	10	1.2	ug/L	20	"	"	"	"	"
1,2,4-Trichlorobenzene	<10	10	0.44	ug/L	20	"	"	"	"	"
1,2,4-Trimethylbenzene	99	10	1.2	ug/L	20	"	"	"	"	"
1,2-Dibromo-3-chloropropane	<10	10	0.50	ug/L	20	"	"	"	"	"
1,2-Dibromoethane (EDB)	<10	10	0.78	ug/L	20	"	"	"	"	"
1,2-Dichlorobenzene	<10	10	1.2	ug/L	20	"	"	"	"	"
1,2-Dichloroethane	<10	10	1.1	ug/L	20	"	"	"	"	"
1,2-Dichloropropene	<10	10	0.96	ug/L	20	"	"	"	"	"
1,3,5-Trimethylbenzene	<10	10	1.2	ug/L	20	"	"	"	"	"
1,3-Dichlorobenzene	<10	10	1.1	ug/L	20	"	"	"	"	"
1,3-Dichloropropane	<10	10	1.3	ug/L	20	"	"	"	"	"
1,4-Dichlorobenzene	<10	10	1.2	ug/L	20	"	"	"	"	"
2,2-Dichloropropane	<10	10	1.5	ug/L	20	"	"	"	"	"
2-Chlorotoluene	<10	10	1.2	ug/L	20	"	"	"	"	"
4-Chlorotoluene	<10	10	1.2	ug/L	20	"	"	"	"	"
Acetone	<200	200	40	ug/L	20	"	"	"	"	"
Allyl chloride	<20	20	5.4	ug/L	20	"	"	"	"	"
Benzene	<10	10	1.3	ug/L	20	"	"	"	"	"
Bromobenzene	<10	10	0.78	ug/L	20	"	"	"	"	"
Bromochloromethane	<10	10	1.2	ug/L	20	"	"	"	"	"
Bromodichloromethane	<10	10	1.3	ug/L	20	"	"	"	"	"
Bromoform	<10	10	0.76	ug/L	20	"	"	"	"	"
Bromomethane	<40	40	1.2	ug/L	20	"	"	"	"	"
Carbon tetrachloride	<10	10	0.50	ug/L	20	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0403756-05) Groundwater Sampled: 11/03/04 11:40 Received: 11/04/04 16:45										
Chlorobenzene	<10	10	1.3	ug/L	20	B4K0908	11/09/04	11/10/04	EPA 8021B	
Chloroethane	<20	20	1.5	ug/L	20	"	"	"	"	"
Chloroform	<10	10	1.2	ug/L	20	"	"	"	"	"
Chloromethane	<40	40	1.5	ug/L	20	"	"	"	"	"
cis-1,2-Dichloroethene	<10	10	1.1	ug/L	20	"	"	"	"	"
cis-1,3-Dichloropropene	<10	10	1.3	ug/L	20	"	"	"	"	"
Dibromochloromethane	<10	10	1.1	ug/L	20	"	"	"	"	"
Dibromomethane	<10	10	0.66	ug/L	20	"	"	"	"	"
Dichlorodifluoromethane	<40	40	1.3	ug/L	20	"	"	"	"	"
Dichlorofluoromethane	<40	40	4.6	ug/L	20	"	"	"	"	"
Ethyl ether	<100	100	5.2	ug/L	20	"	"	"	"	"
Ethylbenzene	210	10	1.3	ug/L	20	"	"	"	"	"
Hexachlorobutadiene	<10	10	0.98	ug/L	20	"	"	"	"	"
Isopropylbenzene	<10	10	1.3	ug/L	20	"	"	"	"	"
Methyl ethyl ketone	<100	100	7.0	ug/L	20	"	"	"	"	"
Methyl isobutyl ketone	<100	100	4.6	ug/L	20	"	"	"	"	"
Methyl tert-butyl ether	<10	10	4.8	ug/L	20	"	"	"	"	"
Methylene chloride	<100	100	8.8	ug/L	20	"	"	"	"	"
Naphthalene	20	10	0.90	ug/L	20	"	"	"	"	"
n-Butylbenzene	<10	10	1.2	ug/L	20	"	"	"	"	"
n-Propylbenzene	19	10	1.4	ug/L	20	"	"	"	"	"
o-Xylene	24	10	1.2	ug/L	20	"	"	"	"	"
p,m-Xylene	100	20	2.6	ug/L	20	"	"	"	"	"
p-Isopropyltoluene	<10	10	1.3	ug/L	20	"	"	"	"	"
sec-Butylbenzene	<10	10	1.3	ug/L	20	"	"	"	"	"
Styrene	<10	10	1.2	ug/L	20	"	"	"	"	"
tert-Butylbenzene	<10	10	1.3	ug/L	20	"	"	"	"	"
Tetrachloroethene	<10	10	1.5	ug/L	20	"	"	"	"	"
Tetrahydrofuran	<100	100	5.6	ug/L	20	"	"	"	"	"
Toluene	12	10	1.4	ug/L	20	"	"	"	"	"
trans-1,2-Dichloroethene	<10	10	1.2	ug/L	20	"	"	"	"	"
trans-1,3-Dichloropropene	<10	10	1.2	ug/L	20	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-03 (0403756-05) Groundwater Sampled: 11/03/04 11:40 Received: 11/04/04 16:45										
Trichloroethene	<10	10	1.5	ug/L	20	B4K0908	11/09/04	11/10/04	EPA 8021B	
Trichlorofluoromethane	<20	20	1.2	ug/L	20	"	"	"	"	
Trichlorotrifluoroethane	<100	100	3.2	ug/L	20	"	"	"	"	
Vinyl chloride	<10	10	1.3	ug/L	20	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	113			75-120 %		"	"	"	"	
MW-05 (0403756-06) Groundwater Sampled: 11/03/04 12:32 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<500	500	33	ug/L	500	B4K0907	11/09/04	11/09/04	EPA 8021B	
1,1,1-Trichloroethane	<250	250	32	ug/L	500	"	"	"	"	
1,1,2,2-Tetrachloroethane	<250	250	28	ug/L	500	"	"	"	"	
1,1,2-Trichloroethane	<250	250	26	ug/L	500	"	"	"	"	
1,1-Dichloroethane	<250	250	28	ug/L	500	"	"	"	"	
1,1-Dichloroethene	<250	250	30	ug/L	500	"	"	"	"	
1,1-Dichloropropene	<250	250	26	ug/L	500	"	"	"	"	
1,2,3-Trichlorobenzene	<250	250	13	ug/L	500	"	"	"	"	
1,2,3-Trichloropropane	<250	250	30	ug/L	500	"	"	"	"	
1,2,4-Trichlorobenzene	<250	250	11	ug/L	500	"	"	"	"	
1,2,4-Trimethylbenzene	570	250	30	ug/L	500	"	"	"	"	
1,2-Dibromo-3-chloropropane	<250	250	12	ug/L	500	"	"	"	"	
1,2-Dibromoethane (EDB)	<250	250	20	ug/L	500	"	"	"	"	
1,2-Dichlorobenzene	<250	250	31	ug/L	500	"	"	"	"	
1,2-Dichloroethane	<250	250	27	ug/L	500	"	"	"	"	
1,2-Dichloropropane	<250	250	24	ug/L	500	"	"	"	"	
1,3,5-Trimethylbenzene	<250	250	29	ug/L	500	"	"	"	"	
1,3-Dichlorobenzene	<250	250	28	ug/L	500	"	"	"	"	
1,3-Dichloropropane	<250	250	32	ug/L	500	"	"	"	"	
1,4-Dichlorobenzene	<250	250	29	ug/L	500	"	"	"	"	
2,2-Dichloropropane	<250	250	38	ug/L	500	"	"	"	"	
2-Chlorotoluene	<250	250	30	ug/L	500	"	"	"	"	
4-Chlorotoluene	<250	250	30	ug/L	500	"	"	"	"	
Acetone	<5000	5000	1000	ug/L	500	"	"	"	"	
Allyl chloride	<500	500	140	ug/L	500	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0403756-06) Groundwater Sampled: 11/03/04 12:32 Received: 11/04/04 16:45										
Benzene	860	250	34	ug/L	500	B4K0907	11/09/04	11/09/04	EPA 8021B	
Bromobenzene	<250	250	20	ug/L	500	"	"	"	"	"
Bromoform	<250	250	30	ug/L	500	"	"	"	"	"
Bromochloromethane	<250	250	32	ug/L	500	"	"	"	"	"
Bromodichloromethane	<250	250	19	ug/L	500	"	"	"	"	"
Bromomethane	<1000	1000	29	ug/L	500	"	"	"	"	"
Carbon tetrachloride	<250	250	12	ug/L	500	"	"	"	"	"
Chlorobenzene	<250	250	32	ug/L	500	"	"	"	"	"
Chloroethane	<500	500	37	ug/L	500	"	"	"	"	"
Chloroform	<250	250	30	ug/L	500	"	"	"	"	"
Chloromethane	<1000	1000	37	ug/L	500	"	"	"	"	"
cis-1,2-Dichloroethene	<250	250	28	ug/L	500	"	"	"	"	"
cis-1,3-Dichloropropene	<250	250	32	ug/L	500	"	"	"	"	"
Dibromochloromethane	<250	250	28	ug/L	500	"	"	"	"	"
Dibromomethane	<250	250	16	ug/L	500	"	"	"	"	"
Dichlorodifluoromethane	<1000	1000	32	ug/L	500	"	"	"	"	"
Dichlorofluoromethane	<1000	1000	120	ug/L	500	"	"	"	"	"
Ethyl ether	<2500	2500	130	ug/L	500	"	"	"	"	"
Ethylbenzene	910	250	32	ug/L	500	"	"	"	"	"
Hexachlorobutadiene	<250	250	24	ug/L	500	"	"	"	"	"
Isopropylbenzene	<250	250	32	ug/L	500	"	"	"	"	"
Methyl ethyl ketone	<2500	2500	180	ug/L	500	"	"	"	"	"
Methyl isobutyl ketone	<2500	2500	120	ug/L	500	"	"	"	"	"
Methyl tert-butyl ether	<250	250	120	ug/L	500	"	"	"	"	"
Methylene chloride	5000	2500	220	ug/L	500	"	"	"	"	"
Naphthalene	690	250	22	ug/L	500	"	"	"	"	"
n-Butylbenzene	<250	250	31	ug/L	500	"	"	"	"	"
n-Propylbenzene	<250	250	35	ug/L	500	"	"	"	"	"
o-Xylene	990	250	31	ug/L	500	"	"	"	"	"
p,m-Xylene	2600	500	65	ug/L	500	"	"	"	"	"
p-Isopropyltoluene	<250	250	32	ug/L	500	"	"	"	"	"
sec-Butylbenzene	<250	250	34	ug/L	500	"	"	"	"	"

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-05 (0403756-06) Groundwater Sampled: 11/03/04 12:32 Received: 11/04/04 16:45										
Styrene	<250	250	30	ug/L	500	B4K0907	11/09/04	11/09/04	EPA 8021B	
tert-Butylbenzene	<250	250	32	ug/L	500	"	"	"	"	"
Tetrachloroethene	<250	250	38	ug/L	500	"	"	"	"	"
Tetrahydrofuran	<2500	2500	140	ug/L	500	"	"	"	"	"
Toluene	6900	250	34	ug/L	500	"	"	"	"	"
trans-1,2-Dichloroethene	<250	250	30	ug/L	500	"	"	"	"	"
trans-1,3-Dichloropropene	<250	250	30	ug/L	500	"	"	"	"	"
Trichloroethene	<250	250	37	ug/L	500	"	"	"	"	"
Trichlorofluoromethane	<500	500	30	ug/L	500	"	"	"	"	"
Trichlorotrifluoroethane	<2500	2500	80	ug/L	500	"	"	"	"	"
Vinyl chloride	<250	250	32	ug/L	500	"	"	"	"	"
Surrogate: 4-Fluorochlorobenzene	111			75-120 %		"	"	"	"	"
MW-07 (0403756-07) Groundwater Sampled: 11/03/04 12:37 Received: 11/04/04 16:45										
1,1,1,2-Tetrachloroethane	<20	20	1.3	ug/L	20	B4K0908	11/09/04	11/10/04	EPA 8021B	
1,1,1-Trichloroethane	<10	10	1.3	ug/L	20	"	"	"	"	"
1,1,2,2-Tetrachloroethane	<10	10	1.1	ug/L	20	"	"	"	"	"
1,1,2-Trichloroethane	<10	10	1.0	ug/L	20	"	"	"	"	"
1,1-Dichloroethane	<10	10	1.1	ug/L	20	"	"	"	"	"
1,1-Dichloroethene	<10	10	1.2	ug/L	20	"	"	"	"	"
1,1-Dichloropropene	<10	10	1.0	ug/L	20	"	"	"	"	"
1,2,3-Trichlorobenzene	<10	10	0.52	ug/L	20	"	"	"	"	"
1,2,3-Trichloropropane	<10	10	1.2	ug/L	20	"	"	"	"	"
1,2,4-Trichlorobenzene	<10	10	0.44	ug/L	20	"	"	"	"	"
1,2,4-Trimethylbenzene	610	100	12	ug/L	200	"	"	11/11/04	"	
1,2-Dibromo-3-chloropropane	<10	10	0.50	ug/L	20	"	"	11/10/04	"	
1,2-Dibromoethane (EDB)	<10	10	0.78	ug/L	20	"	"	"	"	
1,2-Dichlorobenzene	<10	10	1.2	ug/L	20	"	"	"	"	
1,2-Dichloroethane	<10	10	1.1	ug/L	20	"	"	"	"	
1,2-Dichloropropane	<10	10	0.96	ug/L	20	"	"	"	"	
1,3,5-Trimethylbenzene	180	10	1.2	ug/L	20	"	"	"	"	
1,3-Dichlorobenzene	<10	10	1.1	ug/L	20	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Reporting Result	Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-07 (0403756-07) Groundwater Sampled: 11/03/04 12:37 Received: 11/04/04 16:45										
1,3-Dichloropropane	<10	10	1.3	ug/L	20	B4K0908	11/09/04	11/10/04	EPA 8021B	"
1,4-Dichlorobenzene	<10	10	1.2	ug/L	20	"	"	"	"	"
2,2-Dichloropropane	<10	10	1.5	ug/L	20	"	"	"	"	"
2-Chlorotoluene	<10	10	1.2	ug/L	20	"	"	"	"	"
4-Chlorotoluene	<10	10	1.2	ug/L	20	"	"	"	"	"
Acetone	<200	200	40	ug/L	20	"	"	"	"	"
Allyl chloride	<20	20	5.4	ug/L	20	"	"	"	"	"
Benzene	1000	100	13	ug/L	200	"	"	11/11/04	"	"
Bromobenzene	<10	10	0.78	ug/L	20	"	"	11/10/04	"	"
Bromochloromethane	<10	10	1.2	ug/L	20	"	"	"	"	"
Bromodichloromethane	<10	10	1.3	ug/L	20	"	"	"	"	"
Bromoform	<10	10	0.76	ug/L	20	"	"	"	"	"
Bromomethane	<40	40	1.2	ug/L	20	"	"	"	"	"
Carbon tetrachloride	<10	10	0.50	ug/L	20	"	"	"	"	"
Chlorobenzene	<10	10	1.3	ug/L	20	"	"	"	"	"
Chloroethane	<20	20	1.5	ug/L	20	"	"	"	"	"
Chloroform	<10	10	1.2	ug/L	20	"	"	"	"	"
Chloromethane	<40	40	1.5	ug/L	20	"	"	"	"	"
cis-1,2-Dichloroethene	<10	10	1.1	ug/L	20	"	"	"	"	"
cis-1,3-Dichloropropene	<10	10	1.3	ug/L	20	"	"	"	"	"
Dibromochloromethane	<10	10	1.1	ug/L	20	"	"	"	"	"
Dibromomethane	<10	10	0.66	ug/L	20	"	"	"	"	"
Dichlorodifluoromethane	<40	40	1.3	ug/L	20	"	"	"	"	"
Dichlorofluoromethane	<40	40	4.6	ug/L	20	"	"	"	"	"
Ethyl ether	<100	100	5.2	ug/L	20	"	"	"	"	"
Ethylbenzene	980	100	13	ug/L	200	"	"	11/11/04	"	"
Hexachlorobutadiene	<10	10	0.98	ug/L	20	"	"	11/10/04	"	"
Isopropylbenzene	37	10	1.3	ug/L	20	"	"	"	"	"
Methyl ethyl ketone	<100	100	7.0	ug/L	20	"	"	"	"	"
Methyl isobutyl ketone	<100	100	4.6	ug/L	20	"	"	"	"	"
Methyl tert-butyl ether	<10	10	4.8	ug/L	20	"	"	"	"	"
Methylene chloride	<100	100	8.8	ug/L	20	"	"	"	"	"

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	MDL	Units	Dilution	Batch	Prepared	Analyzed	Method	Notes
MW-07 (0403756-07) Groundwater Sampled: 11/03/04 12:37 Received: 11/04/04 16:45										
Naphthalene	230	10	0.90	ug/L	20	B4K0908	11/09/04	11/10/04	EPA 8021B	
n-Butylbenzene	24	10	1.2	ug/L	20	"	"	"	"	
n-Propylbenzene	110	10	1.4	ug/L	20	"	"	"	"	
o-Xylene	1100	100	12	ug/L	200	"	"	11/11/04	"	
p,m-Xylene	3000	200	26	ug/L	200	"	"	"	"	
p-Isopropyltoluene	<10	10	1.3	ug/L	20	"	"	11/10/04	"	
sec-Butylbenzene	<10	10	1.3	ug/L	20	"	"	"	"	
Styrene	<10	10	1.2	ug/L	20	"	"	"	"	
tert-Butylbenzene	<10	10	1.3	ug/L	20	"	"	"	"	
Tetrachloroethene	<10	10	1.5	ug/L	20	"	"	"	"	
Tetrahydrofuran	<100	100	5.6	ug/L	20	"	"	"	"	
Toluene	7800	100	14	ug/L	200	"	"	11/11/04	"	E1
trans-1,2-Dichloroethene	<10	10	1.2	ug/L	20	"	"	11/10/04	"	
trans-1,3-Dichloropropene	<10	10	1.2	ug/L	20	"	"	"	"	
Trichloroethene	<10	10	1.5	ug/L	20	"	"	"	"	
Trichlorofluoromethane	<20	20	1.2	ug/L	20	"	"	"	"	
Trichlorotrifluoroethane	<100	100	3.2	ug/L	20	"	"	"	"	
Vinyl chloride	<10	10	1.3	ug/L	20	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	117			75-120 %	"	"	"	"	"	
Trip Blank (0403756-08) Groundwater Sampled: 05/04/04 00:00 Received: 11/04/04 16:45										
Benzene	<0.50	0.50	0.067	ug/L	1	B4K0908	11/09/04	11/10/04	EPA 8021B	H3b
Ethylbenzene	<0.50	0.50	0.064	ug/L	1	"	"	"	"	
o-Xylene	<0.50	0.50	0.062	ug/L	1	"	"	"	"	
p,m-Xylene	<1.0	1.0	0.13	ug/L	1	"	"	"	"	
Toluene	<0.50	0.50	0.069	ug/L	1	"	"	"	"	
Surrogate: 4-Fluorochlorobenzene	117			75-120 %	"	"	"	"	"	

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

GRO/8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K1002 - EPA 5030 Water (Purge and Trap)

Blank (B4K1002-BLK1)										Prepared & Analyzed: 11/10/04
Gasoline range organics	<100	100	ug/L							
Surrogate: 4-Fluorochlorobenzene	25.0		ug/L	25.0		100	80-120			

LCS (B4K1002-BS1)										Prepared & Analyzed: 11/10/04
Gasoline range organics	1050	100	ug/L	1000		105	80-120			
Surrogate: 4-Fluorochlorobenzene	27.3		ug/L	25.0		109	80-120			

LCS Dup (B4K1002-BSD1)										Prepared: 11/10/04 Analyzed: 11/11/04
Gasoline range organics	1010	100	ug/L	1000		101	80-120	3.88	20	
Surrogate: 4-Fluorochlorobenzene	26.6		ug/L	25.0		106	80-120			

Duplicate (B4K1002-DUP1)	Source: 0403673-01									Prepared: 11/10/04 Analyzed: 11/11/04
Gasoline range organics	<100	100	ug/L	<100				NA	20	
Surrogate: 4-Fluorochlorobenzene	25.6		ug/L	25.0		102	80-120			

Matrix Spike (B4K1002-MS1)	Source: 0403673-01									Prepared: 11/10/04 Analyzed: 11/11/04
Surrogate: 4-Fluorochlorobenzene	25.9		ug/L	25.0		104	80-120			

Batch B4K1003 - EPA 5030 Water (Purge and Trap)

Blank (B4K1003-BLK1)										Prepared & Analyzed: 11/10/04
Gasoline range organics	<100	100	ug/L							
Surrogate: 4-Fluorochlorobenzene	22.8		ug/L	25.0		91.2	80-120			

LCS (B4K1003-BS1)										Prepared & Analyzed: 11/10/04
Gasoline range organics	1030	100	ug/L	1000		103	80-120			
Surrogate: 4-Fluorochlorobenzene	26.9		ug/L	25.0		108	80-120			

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

GRO/8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4K1003 - EPA 5030 Water (Purge and Trap)										
LCS Dup (B4K1003-BSD1) Prepared: 11/10/04 Analyzed: 11/11/04										
Gasoline range organics	1040	100	ug/L	1000	104	80-120	0.966	20		
Surrogate: 4-Fluorochlorobenzene	26.0		ug/L	25.0	104	80-120				
Duplicate (B4K1003-DUP1) Source: 0403734-04 Prepared: 11/10/04 Analyzed: 11/11/04										
Gasoline range organics	<100	100	ug/L	<100			NA	20		
Surrogate: 4-Fluorochlorobenzene	22.2		ug/L	25.0	88.8	80-120				
Batch B4K1108 - EPA 5030 Water (Purge and Trap)										
Blank (B4K1108-BLK1) Prepared & Analyzed: 11/11/04										
Gasoline range organics	<100	100	ug/L							
Surrogate: 4-Fluorochlorobenzene	22.8		ug/L	25.0	91.2	80-120				
LCS (B4K1108-BS1) Prepared & Analyzed: 11/11/04										
Gasoline range organics	1010	100	ug/L	1000	101	80-120				
Surrogate: 4-Fluorochlorobenzene	27.9		ug/L	25.0	112	80-120				
LCS Dup (B4K1108-BSD1) Prepared: 11/11/04 Analyzed: 11/12/04										
Gasoline range organics	1020	100	ug/L	1000	102	80-120	0.985	20		
Surrogate: 4-Fluorochlorobenzene	25.2		ug/L	25.0	101	80-120				
Duplicate (B4K1108-DUP1) Source: 0403739-05 Prepared & Analyzed: 11/11/04										
Gasoline range organics	<100	100	ug/L	<100			NA	20		
Surrogate: 4-Fluorochlorobenzene	21.7		ug/L	25.0	86.8	80-120				
Matrix Spike (B4K1108-MS1) Source: 0403739-05 Prepared: 11/11/04 Analyzed: 11/12/04										
Surrogate: 4-Fluorochlorobenzene	25.4		ug/L	25.0	102	80-120				

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
Batch B4K0907 - EPA 5030 Water (Purge and Trap)										
Blank (B4K0907-BLK1)										Prepared & Analyzed: 11/09/04
1,1,1,2-Tetrachloroethane	<1.0	1.0	ug/L							
1,1,1-Trichloroethane	<0.50	0.50	ug/L							
1,1,2,2-Tetrachloroethane	<0.50	0.50	ug/L							
1,1,2-Trichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethene	<0.50	0.50	ug/L							
1,1-Dichloropropene	<0.50	0.50	ug/L							
1,2,3-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,3-Trichloropropane	<0.50	0.50	ug/L							
1,2,4-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,4-Trimethylbenzene	<0.50	0.50	ug/L							
1,2-Dibromo-3-chloropropane	<0.50	0.50	ug/L							
1,2-Dibromoethane (EDB)	<0.50	0.50	ug/L							
1,2-Dichlorobenzene	<0.50	0.50	ug/L							
1,2-Dichloroethane	<0.50	0.50	ug/L							
1,2-Dichloropropane	<0.50	0.50	ug/L							
1,3,5-Trimethylbenzene	<0.50	0.50	ug/L							
1,3-Dichlorobenzene	<0.50	0.50	ug/L							
1,3-Dichloropropane	<0.50	0.50	ug/L							
1,4-Dichlorobenzene	<0.50	0.50	ug/L							
2,2-Dichloropropane	<0.50	0.50	ug/L							
2-Chlorotoluene	<0.50	0.50	ug/L							
4-Chlorotoluene	<0.50	0.50	ug/L							
Acetone	<10	10	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0907 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 11/09/04

Blank (B4K0907-BLK1)

Allyl chloride	<1.0	1.0	ug/L							
Benzene	<0.50	0.50	ug/L							
Bromobenzene	<0.50	0.50	ug/L							
Bromochloromethane	<0.50	0.50	ug/L							
Bromodichloromethane	<0.50	0.50	ug/L							
Bromoform	<0.50	0.50	ug/L							
Bromomethane	<2.0	2.0	ug/L							
Carbon tetrachloride	<0.50	0.50	ug/L							
Chlorobenzene	<0.50	0.50	ug/L							
Chloroethane	<1.0	1.0	ug/L							
Chloroform	<0.50	0.50	ug/L							
Chloromethane	<2.0	2.0	ug/L							
cis-1,2-Dichloroethene	<0.50	0.50	ug/L							
cis-1,3-Dichloropropene	<0.50	0.50	ug/L							
Dibromochloromethane	<0.50	0.50	ug/L							
Dibromomethane	<0.50	0.50	ug/L							
Dichlorodifluoromethane	<2.0	2.0	ug/L							
Dichlorofluoromethane	<2.0	2.0	ug/L							
Ethyl ether	<5.0	5.0	ug/L							
Ethylbenzene	<0.50	0.50	ug/L							
Hexachlorobutadiene	<0.50	0.50	ug/L							
Isopropylbenzene	<0.50	0.50	ug/L							
Methyl ethyl ketone	<5.0	5.0	ug/L							
Methyl isobutyl ketone	<5.0	5.0	ug/L							

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0907 - EPA 5030 Water (Purge and Trap)

Prepared & Analyzed: 11/09/04

Blank (B4K0907-BLK1)										
Methyl tert-butyl ether	<0.50	0.50	ug/L							
Methylene chloride	<5.0	5.0	ug/L							
Naphthalene	<0.50	0.50	ug/L							
n-Butylbenzene	<0.50	0.50	ug/L							
n-Propylbenzene	<0.50	0.50	ug/L							
o-Xylene	<0.50	0.50	ug/L							
p,m-Xylene	<1.0	1.0	ug/L							
p-Isopropyltoluene	<0.50	0.50	ug/L							
sec-Butylbenzene	<0.50	0.50	ug/L							
Styrene	<0.50	0.50	ug/L							
tert-Butylbenzene	<0.50	0.50	ug/L							
Tetrachloroethene	<0.50	0.50	ug/L							
Tetrahydrofuran	<5.0	5.0	ug/L							
Toluene	<0.50	0.50	ug/L							
trans-1,2-Dichloroethene	<0.50	0.50	ug/L							
trans-1,3-Dichloropropene	<0.50	0.50	ug/L							
Trichloroethene	<0.50	0.50	ug/L							
Trichlorofluoromethane	<1.0	1.0	ug/L							
Trichlorotrifluoroethane	<5.0	5.0	ug/L							
Vinyl chloride	<0.50	0.50	ug/L							
Surrogate: 4-Fluorochlorobenzene	10.5		ug/L	10.0		105	75-120			

LCS (B4K0907-BS1)

Prepared & Analyzed: 11/09/04

1,1-Dichloroethene	7.79	ug/L	10.0	77.9	75-125
Benzene	9.42	ug/L	10.0	94.2	75-125

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0907 - EPA 5030 Water (Purge and Trap)

LCS (B4K0907-BS1)							Prepared & Analyzed: 11/09/04			
Chlorobenzene	9.53		ug/L	10.0		95.3	75-125			
Toluene	8.65		ug/L	10.0		86.5	75-125			
Trichloroethene	7.74		ug/L	10.0		77.4	75-125			
Surrogate: 4-Fluorochlorobenzene	8.57		ug/L	10.0		85.7	75-120			

Matrix Spike (B4K0907-MS1)

	Source: 0403756-01		Prepared & Analyzed: 11/09/04							
1,1-Dichloroethene	8.79		ug/L	10.0	<	87.9	75-125			
Benzene	9.17		ug/L	10.0	<	91.7	75-125			
Chlorobenzene	9.29		ug/L	10.0	<	92.9	75-125			
Toluene	8.35		ug/L	10.0	<	83.5	75-125			
Trichloroethene	8.89		ug/L	10.0	<	88.9	75-125			
Surrogate 4-Fluorochlorobenzene	8.60		ug/L	10.0		86.0	75-120			

Matrix Spike Dup (B4K0907-MSD1)

	Source: 0403756-01		Prepared & Analyzed: 11/09/04							
1,1-Dichloroethene	9.20		ug/L	10.0	<	92.0	75-125	4.56	20	
Benzene	9.53		ug/L	10.0	<	95.3	75-125	3.85	20	
Chlorobenzene	9.65		ug/L	10.0	<	96.5	75-125	3.80	20	
Toluene	8.66		ug/L	10.0	<	86.6	75-125	3.64	20	
Trichloroethene	9.53		ug/L	10.0	<	95.3	75-125	6.95	20	
Surrogate 4-Fluorochlorobenzene	8.78		ug/L	10.0		87.8	75-120			

Batch B4K0908 - EPA 5030 Water (Purge and Trap)

Blank (B4K0908-BLK1)							Prepared: 11/09/04	Analyzed: 11/10/04		
1,1,1,2-Tetrachloroethane	<1.0		1.0	ug/L						
1,1,1-Trichloroethane	<0.50		0.50	ug/L						
1,1,2,2-Tetrachloroethane	<0.50		0.50	ug/L						
1,1,2-Trichloroethane	<0.50		0.50	ug/L						

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0908 - EPA 5030 Water (Purge and Trap)

Prepared: 11/09/04 Analyzed: 11/10/04

Blank (B4K0908-BLK1)										
1,1-Dichloroethane	<0.50	0.50	ug/L							
1,1-Dichloroethene	<0.50	0.50	ug/L							
1,1-Dichloropropene	<0.50	0.50	ug/L							
1,2,3-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,3-Trichloropropane	<0.50	0.50	ug/L							
1,2,4-Trichlorobenzene	<0.50	0.50	ug/L							
1,2,4-Trimethylbenzene	<0.50	0.50	ug/L							
1,2-Dibromo-3-chloropropane	<0.50	0.50	ug/L							
1,2-Dibromoethane (EDB)	<0.50	0.50	ug/L							
1,2-Dichlorobenzene	<0.50	0.50	ug/L							
1,2-Dichloroethane	<0.50	0.50	ug/L							
1,2-Dichloropropane	<0.50	0.50	ug/L							
1,3,5-Trimethylbenzene	<0.50	0.50	ug/L							
1,3-Dichlorobenzene	<0.50	0.50	ug/L							
1,3-Dichloropropane	<0.50	0.50	ug/L							
1,4-Dichlorobenzene	<0.50	0.50	ug/L							
2,2-Dichloropropane	<0.50	0.50	ug/L							
2-Chlorotoluene	<0.50	0.50	ug/L							
4-Chlorotoluene	<0.50	0.50	ug/L							
Acetone	<10	10	ug/L							
Allyl chloride	<1.0	1.0	ug/L							
Benzene	<0.50	0.50	ug/L							
Bromobenzene	<0.50	0.50	ug/L							
Bromochloromethane	<0.50	0.50	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0908 - EPA 5030 Water (Purge and Trap)

Prepared: 11/09/04 Analyzed: 11/10/04

Blank (B4K0908-BLK1)										
Bromodichloromethane	<0.50	0.50	ug/L							
Bromoform	<0.50	0.50	ug/L							
Bromomethane	<2.0	2.0	ug/L							
Carbon tetrachloride	<0.50	0.50	ug/L							
Chlorobenzene	<0.50	0.50	ug/L							
Chloroethane	<1.0	1.0	ug/L							
Chloroform	<0.50	0.50	ug/L							
Chloromethane	<2.0	2.0	ug/L							
cis-1,2-Dichloroethene	<0.50	0.50	ug/L							
cis-1,3-Dichloropropene	<0.50	0.50	ug/L							
Dibromochloromethane	<0.50	0.50	ug/L							
Dibromomethane	<0.50	0.50	ug/L							
Dichlorodifluoromethane	<2.0	2.0	ug/L							
Dichlorofluoromethane	<2.0	2.0	ug/L							
Ethyl ether	<5.0	5.0	ug/L							
Ethylbenzene	<0.50	0.50	ug/L							
Hexachlorobutadiene	<0.50	0.50	ug/L							
Isopropylbenzene	<0.50	0.50	ug/L							
Methyl ethyl ketone	<5.0	5.0	ug/L							
Methyl isobutyl ketone	<5.0	5.0	ug/L							
Methyl tert-butyl ether	<0.50	0.50	ug/L							
Methylene chloride	<5.0	5.0	ug/L							
Naphthalene	<0.50	0.50	ug/L							
n-Butylbenzene	<0.50	0.50	ug/L							

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0908 - EPA 5030 Water (Purge and Trap)

Prepared: 11/09/04 Analyzed: 11/10/04

Blank (B4K0908-BLK1)										
n-Propylbenzene	<0.50	0.50	ug/L							
o-Xylene	<0.50	0.50	ug/L							
p,m-Xylene	<1.0	1.0	ug/L							
p-Isopropyltoluene	<0.50	0.50	ug/L							
sec-Butylbenzene	<0.50	0.50	ug/L							
Styrene	<0.50	0.50	ug/L							
tert-Butylbenzene	<0.50	0.50	ug/L							
Tetrachloroethene	<0.50	0.50	ug/L							
Tetrahydrofuran	<5.0	5.0	ug/L							
Toluene	<0.50	0.50	ug/L							
trans-1,2-Dichloroethene	<0.50	0.50	ug/L							
trans-1,3-Dichloropropene	<0.50	0.50	ug/L							
Trichloroethene	<0.50	0.50	ug/L							
Trichlorofluoromethane	<1.0	1.0	ug/L							
Trichlorotrifluoroethane	<5.0	5.0	ug/L							
Vinyl chloride	<0.50	0.50	ug/L							
Surrogate: 4-Fluorochlorobenzene	11.7	ug/L	10.0		117	75-120				

LCS (B4K0908-BS1)										
1,1-Dichloroethene	8.56	ug/L	10.0		85.6	75-125				
Benzene	9.14	ug/L	10.0		91.4	75-125				
Chlorobenzene	9.19	ug/L	10.0		91.9	75-125				
Toluene	8.27	ug/L	10.0		82.7	75-125				
Trichloroethene	8.68	ug/L	10.0		86.8	75-125				
Surrogate: 4-Fluorochlorobenzene	8.71	ug/L	10.0		87.1	75-120				

LEGEND Technical Services, Inc

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

VOC GC 8021B - Quality Control

LEGEND Technical Services, Inc

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	%RPD	%RPD Limit	Notes
---------	--------	-----------------	-------	-------------	---------------	------	-------------	------	------------	-------

Batch B4K0908 - EPA 5030 Water (Purge and Trap)

Matrix Spike (B4K0908-MS1)

Source: 0403675-04 Prepared: 11/09/04 Analyzed: 11/10/04

1,1-Dichloroethene	9.66	ug/L	10.0	<	96.6	75-125				
Benzene	9.66	ug/L	10.0	<	96.6	75-125				
Chlorobenzene	9.78	ug/L	10.0	<	97.8	75-125				
Toluene	8.82	ug/L	10.0	<	88.2	75-125				
Trichloroethene	9.98	ug/L	10.0	<	99.8	75-125				
Surrogate: 4-Fluorochlorobenzene	8.77	ug/L	10.0		87.7	75-120				

Matrix Spike Dup (B4K0908-MSD1)

Source: 0403675-04 Prepared: 11/09/04 Analyzed: 11/10/04

1,1-Dichloroethene	8.42	ug/L	10.0	<	84.2	75-125	13.7	20		
Benzene	9.56	ug/L	10.0	<	95.6	75-125	1.04	20		
Chlorobenzene	9.98	ug/L	10.0	<	99.8	75-125	2.02	20		
Toluene	8.57	ug/L	10.0	<	85.7	75-125	2.88	20		
Trichloroethene	9.50	ug/L	10.0	<	95.0	75-125	4.93	20		
Surrogate: 4-Fluorochlorobenzene	8.91	ug/L	10.0		89.1	75-120				

LEGEND

Technical Services, Inc.

775 Vandalia Street
St Paul, MN 55114
651.642.1150

Coteau Environmental
728 Janes Circle Drive SW
Alexandria MN, 56308

Project: KC-Kwik Stop-Brooten, MN
Project Number: KC Kwik Stop-Brooten, MN
Project Manager: Mr. Scott Hunke

Date Reported:
November 19, 2004

Notes and Definitions

- H3b The trip-blank sample was received and analyzed past holding time.
- H Results in the Gasoline Range are primarily due to overlap from a heavier fuel hydrocarbon product.
- E1 Concentration estimated. Analyte exceeded calibration range. Reanalysis not possible due to insufficient sample.
- < Less than value listed
- dry Sample results reported on a dry weight basis
- RPD Relative Percent Difference
- NA Not applicable. The %RPD is not calculated from values less than the reporting limit.

LEGEND TECHNICAL SERVICES, INC.

775 Vandalia Street, St Paul, MN 55114 - Telephone: 651-642-1150, Fax: 651-642-1239

CHAIN-OF-CUSTODY RECORD

Client Name: Cutter Environmental		Bill To: Same	LEGEND Project #. 0403756		Analysis	
Address: 728 JAMES CIRCLE DR ACCOMPLISH, MN 56308		Turnaround Time: <input checked="" type="checkbox"/> Normal	<input type="checkbox"/> RUSH Date: _____	Condition Received: <input type="checkbox"/> Received at 4.5 °C <input checked="" type="checkbox"/> Received on ice <input type="checkbox"/> Received on blue ice <input type="checkbox"/> Received ambient <input type="checkbox"/> No temp blank <input type="checkbox"/> Acceptable	Number of Containers 5,000	
Attn: MCAT & DR SCOTT	PO#:	Phone: 320-846-4668	Fax: 605-882-452	Project #: BRC001, MN	Collection Date	Sample Matrix
Item No	Field ID No	Sample Description		Collection Date	Sample Matrix	Lab ID No
1	MW - 01	WATER		11/30/04	0734	-1
2	02			0846	-2	6
3	04			0942	-3	6
4	04			1038	-4	6
5	03			1140	-5	6
6	05			1232	-6	6
7	07			1237	-7	3
8	TRP:300D			5/4/04	-8	1
9	TRP:300D				1	
10	07				✓	✓
Comments:		Sample Collector (please print): SCOTT HUNKET	Item No.	Relinquished By: <i>[Signature]</i>	Date: 11/30/04	Time: 1500
		Item No.	Relinquished By:	Date: 11/30/04	Time: 1500	Accepted By: _____
		Comments:	Received By Lab.	Date: 11-4-04	Time: 16:4	Time: _____

PLEASE REVIEW TERMS AND CONDITIONS ON BACK BEFORE SIGNING

White Copy - Original Accompanies Shipment to Lab Yellow Copy - Lab Pink Copy - Customer or Field Copy

APPENDIX II
METHODOLOGIES AND PROCEDURES

METHODOLOGIES

Fluid Level Monitoring

Fluid levels in all monitor wells will be monitored using an electronic water level indicator, steel tape or interface probe. An interface probe or chalk and paste will be used to measure fluid levels when free product exists in the well. The fluid level will be obtained by lowering the measuring device into the well until the water surface has been encountered and by recording the distance from the top of the inside casing to the measuring device to the nearest 0.10 foot. Prior to each measurement, the fluid level measuring device will be cleaned with alcohol and distilled water.

Ground Water Sampling

Ground water sampling procedures will be conducted in accordance with the Minnesota Pollution Control Agency (MPCA) requirements. Monitor wells will be sampled from the suspected cleanest to the most contaminated. The field protocol for monitor well sampling will consist of fluid level measurement, monitor well development, and sample collection. The fluid level will be measured in the well to the nearest 0.01 foot. Following fluid level measurement, the well volume will be calculated and a minimum of 5 well casing volumes will be removed from the well prior to sampling using a dedicated stainless-steel or polyethylene bailer. Well stabilization data may be recorded during purging in the form of temperature, pH and electrical conductivity. Following sample collection, the samples will be shipped to a specified laboratory following appropriate documentation, preservation, and chain of custody procedures. Data collected during the sampling procedure will be documented in the field. All equipment utilized during sample collection will be cleaned with alcohol and deionized water.

Laboratory Analysis

Laboratory analysis of the soil and ground water samples will be conducted by a certified laboratory using standard EPA methods. Benzene, toluene, ethyl benzene, xylenes (BTEX), total petroleum hydrocarbons (TPH) as gasoline, TPH as fuel oil, and naphthalene analyses will be conducted in accordance with the California/USGS Method or equivalent method approved by the MPCA.

Vapor Survey

Based on the results of the survey of all potentially-impacted structures, a vapor survey will be conducted to identify any impacts of volatile organic compounds to the structures. A photoionization detector (PID) calibrated to benzene using an isobutylene gas standard in combination with an explosimeter, will be utilized to conduct the vapor survey. Readings of total petroleum hydrocarbons (TPH) in parts per million (ppm) and the lower explosive limit (LEL) will be recorded during the vapor survey by sampling air inside the potentially-impacted structures with the PID/explosimeter.

APPENDIX III
FIELD DATA SHEETS

LIENT FORMER KC KWICK STOP

LOCATION BROOTEN, MN

FLUID LEVEL SHEET

DATE 8/14/03

NAME 254

* = Contains Product

OBSERVATIONS COMMENTS

DwP = 1300

WATER SAMPLING DATA

DATE:	8/4/03
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-01
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.93
DEPTH TO WATER:	10.21
COLUMN LENGTH:	9.72
WELL VOLUME:	1.56
TOTAL VOLUME REMOVED:	7.75
SAMPLE ANALYSIS:	POLY BAILER BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN, 80's
SAMPLE DESCRIPTION:	BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	0845

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	8/14/03
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - 02
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.16
DEPTH TO WATER:	12.90
COLUMN LENGTH:	9.26
WELL VOLUME:	1.48
TOTAL VOLUME REMOVED:	7.5
SAMPLE TUBE:	POLY BAILER
SAMPLE TUBE:	POLY BAILER
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 80's
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	0937

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	8/14/03
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MU-03
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.42
DEPTH TO WATER:	13.08
COLUMN LENGTH:	9.34
WELL VOLUME:	1.49
TOTAL VOLUME REMOVED:	7.5
SAMPLE TYPE:	POLY BAILER
SAMPLE ANALYSIS:	POLY BAILER
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 80's
SAMPLE DESCRIPTION:	LIGHT BROWN, SLIGHT ODOUR
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1200

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	8/14/03
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - 04
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	21.83
DEPTH TO WATER:	13.21
COLUMN LENGTH:	8.62
WELL VOLUME:	1.38
TOTAL VOLUME REMOVED:	7
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 80°
SAMPLE DESCRIPTION:	
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1108

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	8/14/03
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-05
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.20
DEPTH TO WATER:	10.06
COLUMN LENGTH:	9.14
WELL VOLUME:	1.46
TOTAL VOLUME REMOVED:	7.5
SAMPLE TYPE:	POLY BAILER
SAMPLE TYPE:	POLY BAILER
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 80°
SAMPLE DESCRIPTION:	320ft. STRONG ODORE - SMELLS LIKE SEWAGE
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1247

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE	8/14/03
PROJECT	FORMER KC KWIK STOP
CITY/STATE/ZIP	BROOTEN MN
LOCATION:	MW-06
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.64
DEPTH TO WATER	10.58
COLUMN LENGTH	9.06
WELL VOLUME:	1.45
TOTAL VOLUME REMOVED:	7.25
SAMPLE ANALYSIS:	POLY BAILER POLY BAILER BTEX/TPH-GRO
WEATHER CONDITIONS	SUN 80's
SAMPLE DESCRIPTION:	BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1015

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

CLIENT FORMER KC KWICK STOP

LOCATION BROOTEN, MN

FLUID LEVEL SHEET

DATE 11/14/03

NAME Sdy

* = Contains Product

OBSERVATIONS/COMMENTS.

WATER SAMPLING DATA

DATE:	
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - U
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	
DEPTH TO WATER:	
COLUMN LENGTH:	
WELL VOLUME:	
TOTAL VOLUME REMOVED:	
SAMPLE ANALYSIS:	POLY BAILER POLY BAILER BTEX/TPH-GRO
WEATHER CONDITIONS	
SAMPLE DESCRIPTION:	Brown
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	0832

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE. For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	1NW - C2
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	
DEPTH TO WATER:	
COLUMN LENGTH:	
WELL VOLUME:	
TOTAL VOLUME REMOVED	
SAMPLE ANALYSIS:	POLY BAILER
	POLY BAILER
	BTEX/TPH-GRO
WEATHER CONDITIONS	
SAMPLE DESCRIPTION	LIGHT BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	0917

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE. For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-03
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	
DEPTH TO WATER:	
COLUMN LENGTH:	
WELL VOLUME:	
TOTAL VOLUME REMOVED:	
SAMPLE ANALYSIS:	POLY BAILER POLY BAILER BTEX/TPH-GRO
WEATHER CONDITIONS:	
SAMPLE DESCRIPTION:	LIGHT BROWN SLIGHT ODOR
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1137

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE. For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-04
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	
DEPTH TO WATER:	
COLUMN LENGTH:	
WELL VOLUME:	
TOTAL VOLUME REMOVED:	
SAMPLE ANALYSIS:	POLY BAILER
	POLY BAILER
WEATHER CONDITIONS:	
SAMPLE DESCRIPTION:	LIL.YT 3.20W~1
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	10:50

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE. For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - CS
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	
DEPTH TO WATER:	
COLUMN LENGTH:	
WELL VOLUME:	
TOTAL VOLUME REMOVED:	
SAMPLE ANALYSIS:	POLY BAILER POLY BAILER B'TEX/TPH-GRO
WEATHER CONDITIONS:	
SAMPLE DESCRIPTION:	LIGHT CLOUDY SLIGHT ODOUR
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	12:15

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - 36
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	
DEPTH TO WATER:	
COLUMN LENGTH:	
WELL VOLUME:	
TOTAL VOLUME REMOVED:	
SAMPLE ANALYSIS:	POLY BAILER
	POLY BAILER
WEATHER CONDITIONS:	
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1002

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE. For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

CLIENT FORMER KC KWICK STOP
LOCATION BROOTEN, MN
FLUID LEVEL SHEET

DATE 219104
NAME SDU

* = Contains Product

OBSERVATIONS/COMMENTS MU-07 (du.) 1155

VAPOR MONITORING

Date: 2/9/04

Site: KC KWIK STOP, B200.TER, msl

1 FLOOR -
MORRIS CROSS
320-346-2497

WATER SAMPLING DATA

DATE:	9-Feb-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - D1
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.93
DEPTH TO WATER:	12.13
COLUMN LENGTH:	7.80
WELL VOLUME:	1.25
TOTAL VOLUME REMOVED:	6.24
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	Cloudy 15 - 20°
SAMPLE DESCRIPTION:	BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1148

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	9-Feb-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-02
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.16
DEPTH TO WATER:	14.75
COLUMN LENGTH:	7.41
WELL VOLUME:	1.19
TOTAL VOLUME REMOVED:	6
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	Cloudy 15-20°
SAMPLE DESCRIPTION:	Light Brown
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1235

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	9-Feb-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	1m w - c3
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.42
DEPTH TO WATER:	15.05
COLUMN LENGTH:	7.31
WELL VOLUME:	1.18
TOTAL VOLUME REMOVED:	6
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	Cloudy, Light Show 15-20°
SAMPLE DESCRIPTION:	Light Brown, Slight Odor
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1457

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	9-Feb-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW -04
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	21.83
DEPTH TO WATER:	15.14
COLUMN LENGTH:	6.69
WELL VOLUME:	1.07
TOTAL VOLUME REMOVED:	5.5
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	CLOUDS 15-20°
SAMPLE DESCRIPTION:	LIGHT BROWN, SLIGHT ODOUR
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1405

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	9-Feb-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - 05
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.20
DEPTH TO WATER:	12.00
COLUMN LENGTH:	7.20
WELL VOLUME:	1.15
TOTAL VOLUME REMOVED:	6
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	Cloudy, 15-20°
SAMPLE DESCRIPTION:	Light gray, slight odor
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1550

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

WATER SAMPLING DATA

DATE:	9-Feb-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW -06
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.64
DEPTH TO WATER:	12.51
COLUMN LENGTH:	7.13
WELL VOLUME:	1.14
TOTAL VOLUME REMOVED:	5.75
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	Clouds 15-20°
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	SDH
SAMPLER:	
SAMPLE COLLECTION TIME:	1317

DISSOLVED OXYGEN (mg/L): _____

SOLUBLE FERROUS IRON (mg/L): _____

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

CLIENT FORMER KC KWICK STOP

CATION BROOK, MN

FLUID LEVEL SHEET

DATE 5/11/04

NAME SD4

* = Contains Product

OBSERVATIONS/COMMENTS

WATER SAMPLING DATA

DATE:	5/11/04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW -01
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.93
DEPTH TO WATER:	11.69
COLUMN LENGTH:	8.24
WELL VOLUME:	1.32
TOTAL VOLUME REMOVED:	6.75
SAMPLE ANALYSIS:	POLY BAILER
	POLY BAILER
WEATHER CONDITIONS:	CLOUDY 50's
SAMPLE DESCRIPTION:	Brown
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0745

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	5/11/04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	mw -02
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.16
DEPTH TO WATER:	14.33
COLUMN LENGTH:	7.83
WELL VOLUME:	1.25
TOTAL VOLUME REMOVED:	6.25
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	Cloudy wind, 50's
SAMPLE DESCRIPTION:	Light Brown
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0843

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

WATER SAMPLING DATA

DATE:	5/11/04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW -03
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.42
DEPTH TO WATER:	14.65
COLUMN LENGTH:	7.77
WELL VOLUME:	1.24
TOTAL VOLUME REMOVED:	6.25
SAMPLING EQUIPMENT:	POLY BAILER
SAMPLING EQUIPMENT:	POLY BAILER
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	CLOUDS 60's
SAMPLE DESCRIPTION:	LIGHT BROWN SLIGHT ODOOR
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1130

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

4/29/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	5/11/04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-04
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	21.83
DEPTH TO WATER:	14.73
COLUMN LENGTH:	7.10
WELL VOLUME:	1.14
TOTAL VOLUME REMOVED:	5.75
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	Clouds 60°s
SAMPLE DESCRIPTION:	Light Brown, slight odor
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1032

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

4/29/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	5/11/04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MU-05
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.20
DEPTH TO WATER:	11.58
COLUMN LENGTH:	7.62
WELL VOLUME:	1.22
TOTAL VOLUME REMOVED:	6
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	CLOUDS 60° S WINDY
SAMPLE DESCRIPTION:	LIGHT GRAY, ODOUR, RAINBOWS
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1220

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

4/29/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	5/11/04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-06
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.64
DEPTH TO WATER:	12.14
COLUMN LENGTH:	7.50
WELL VOLUME:	1.2
TOTAL VOLUME REMOVED:	6
SAMPLING EQUIPMENT:	POLY BAILER
SAMPLING EQUIPMENT:	POLY BAILER
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	CLOUDS 50°'S
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0927

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

4/29/04KC KwikSAMPLFM

CLIENT FORMER KC KWICK STOP

DATE 8/2/04

LOCATION BROOTEN, MN

FLUID LEVEL SHEET

NAME SD4

* = Contains Product

OBSERVATIONS/COMMENTS

WATER SAMPLING DATA

DATE:	2-Aug-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-01
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.93
DEPTH TO WATER:	13.48
COLUMN LENGTH:	9.48
WELL VOLUME:	1.52
TOTAL VOLUME REMOVED:	7.5
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	Cloudy Sun 70°'s
SAMPLE DESCRIPTION:	Light Brown
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0903

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

8/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	2-Aug-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-02
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.16
DEPTH TO WATER:	13.16
COLUMN LENGTH:	9.00
WELL VOLUME:	1.44
TOTAL VOLUME REMOVED:	7.25
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	SUN & CLOUDS 70° ^F
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0950

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

8/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	2-Aug-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	mw - 03
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.42
DEPTH TO WATER:	13.42
COLUMN LENGTH:	9.00
WELL VOLUME:	1.44
TOTAL VOLUME REMOVED:	7.25
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	SUN & CLOUDS 80's
SAMPLE DESCRIPTION:	LIGHT BROWN, SLIGHT ODOOR
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1225

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

8/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	2-Aug-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-04
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	21.83
DEPTH TO WATER:	13.55
COLUMN LENGTH:	8.28
WELL VOLUME:	1.33
TOTAL VOLUME REMOVED:	6.75
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	SUN & CLOUDS 70° S
SAMPLE DESCRIPTION:	LIGHT BROWN, SLIGHT ODOR
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1138

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

8/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	2-Aug-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-05
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.20
DEPTH TO WATER:	10.32
COLUMN LENGTH:	8.88
WELL VOLUME:	1.42
TOTAL VOLUME REMOVED:	7.25
SAMPLING EQUIPMENT:	POLY BAILER
SAMPLE ANALYSIS:	POLY BAILER VOC's/TPH-GRO
WEATHER CONDITIONS:	SUN & CLOUDS 80° S
SAMPLE DESCRIPTION:	LIGHT GRAY STRONG ODOR
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1335

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

8/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	2-Aug-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-06
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.64
DEPTH TO WATER:	10.91
COLUMN LENGTH:	8.73
WELL VOLUME:	1.39
TOTAL VOLUME REMOVED:	7
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	VOC's/TPH-GRO
WEATHER CONDITIONS:	SUN & CLOUDS 70°'S
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1042

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

VAPOR MONITORING

Date 8/2/04

Site: KC KWIK STOP, BROWNSTEIN, MN

CLIENT FORMER KC KWICK STOP
LOCATION BROOKEN, MN
FLUID LEVEL SHEET

DATE 11/3/04

NAME Sdy

• = Contains Product

OBSERVATIONS/COMMENTS

VAPOR MONITORING

Date: 11/3/04

Site: KC KWIK STOP - 13200 TENT

WATER SAMPLING DATA

DATE:	3-Nov-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-01
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.93
DEPTH TO WATER:	10.52
COLUMN LENGTH:	9.41
WELL VOLUME:	1.51
TOTAL VOLUME REMOVED:	7.5
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 50°'S
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0754

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

11/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	3-Nov-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-02
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.16
DEPTH TO WATER:	13.20
COLUMN LENGTH:	8.96
WELL VOLUME:	1.43
TOTAL VOLUME REMOVED:	7.25
SAMPLE ANALYSIS:	POLY BAILER POLY BAILER BTEX/TPH-GRO
WEATHER CONDITIONS:	Sun 30°'s
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0846

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

11/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	3-Nov-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	<u>MW - C3</u>
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	22.42
DEPTH TO WATER:	13.49
COLUMN LENGTH:	8.43
WELL VOLUME:	1.43
TOTAL VOLUME REMOVED:	7.25
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 40°'S
SAMPLE DESCRIPTION:	LIGHT BROWN - SLIGHT ODOR
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1140

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

11/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	3-Nov-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - C 4
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	21.83
DEPTH TO WATER:	13.58
COLUMN LENGTH:	8.25
WELL VOLUME:	1.32
TOTAL VOLUME REMOVED:	6.75
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 40° S
SAMPLE DESCRIPTION:	LIGHT Brown - SLIGHT ODOUR
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1038

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

11/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	3-Nov-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW-05
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.20
DEPTH TO WATER:	10.38
COLUMN LENGTH:	8.82
WELL VOLUME:	1.41
TOTAL VOLUME REMOVED:	7
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUN 40° S
SAMPLE DESCRIPTION:	LIGHT GRAY - STRONG ODORE
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	1232

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

11/2/04KC KwikSAMPLFM

WATER SAMPLING DATA

DATE:	3-Nov-04
PROJECT:	FORMER KC KWIK STOP
CITY/STATE/ZIP:	BROOTEN MN
LOCATION:	MW - 06
KEY NUMBER:	
CASING DIAMETER:	2-inch
WELL DEPTH:	19.64
DEPTH TO WATER:	10.97
COLUMN LENGTH:	8.67
WELL VOLUME:	1.39
TOTAL VOLUME REMOVED:	7
POLY BAILER	
POLY BAILER	
SAMPLE ANALYSIS:	BTEX/TPH-GRO
WEATHER CONDITIONS:	SUNNY 40° S
SAMPLE DESCRIPTION:	LIGHT BROWN
REMARKS:	
SAMPLER:	sdh
SAMPLE COLLECTION TIME:	0942

NOTE: For 2-inch wells, multiply column length in feet times 0.16 to obtain one (1) well volume in gallons.

REMOVE 5 well volumes before sampling!

COTEAU ENVIRONMENTAL

11/2/04KC KwikSAMPLFM

