Boiler Services, Inc.

July 15, 1997

7570 NE Hwy. 65 Fridley, MN 55432 (612) 784-8178

Minnesota Pollution Control Agency 520 Lafayette Road North St. Paul, MN 55155

JUL 2 1 1997

ATTN: Elizabeth Clysdale

MPCA, HAZARDOUS WASTE DIVISION

MPCA Tank Site #830 Mayer Mobil 308 Ash Avenue Mayer, MN 55360 Date: June 10, 1997 1-8,000 Gal UST Diesel 1-6,000 Gal UST Gasoline 1-2,000 Gal UST Gasoline 1-1,000 Gal UST Diesel

Tanks were removed by Boiler Services, Inc. MPCA#0012 Supervised by Tom Marchessault, Sup#1134 Transported and disposed of by Solberg Enterprises, Clearwater, MN

Soil samples were taken for analysis under each tank.

Strong gasoline odor and dark stained soil was discovered under the 2,000 Gallon gasoline UST. See attached site map.

MPCA Duty officer was notified on 6/11/97.

The 2,000 Gallon tank seemed to be sound. However, this facility has been an automotive repair garage since 1931. The contamination was found in an area that was used for a repair pit until the mid 1980's.

MPCA Leak ID#10324

MPCA Project Manager: Elizabeth Clysdale

Sincerely,

Tom Marchessault

BOILER SERVICES, INC.

cc Mayer Mobile MPCA