

Petroleum Tank Release Compliance Checklist

SITE NAME: 1410 Dittmer Oil LEAK0000 1940

USE THE FOLLOWING GUIDELINES TO DETERMINE IF THE LEAKING TANK IS IN COMPLIANCE

 UNREGULATED TANKS.....are ASTs/USTs 110 gallons or less, OR heating oil ASTs/USTs 1,100 gallons or less with product consumed on the premises, OR farm/residential ASTs/USTs 1,100 gallons or less containing motor fuel not for resale.
 STATE REGULATED TANKS.....are heating oil USTs with a capacity more than 1,100 gallons.
 X FEDERALLY REGULATED TANKS.....are all USTs not specified above.
 ABOVEGROUND TANKS.....are unregulated if they meet the same criteria as "Unregulated Tanks". If ASTs are regulated, use items marked with **.

UNREGULATED TANKS, STATE TANKS, FEDERAL TANKS ADEQUATE INADEQUATE

**Release Notification: Date release discovered: MPCA 10/27/89 Petro App 10/26/89
Date release reported: MPCA 10/27/89 Petro App 10/27/89
Was there environmental damage due to delay? Yes No X
****Cooperation/Due Care Issue: Yes No X**
(i.e. release during tank removal, land treatment prior to approval, land treatment monitoring results not received)
Comments:

STATE TANKS, FEDERAL TANKS ADEQUATE INADEQUATE

**Tank Registration: AST/UST number: 9099 Registration Date: 1/31/86 (USTS)
Regulated USTs should be registered by 12/1/87. Regulated ASTs should be registered by 1/1/91.
Unregistered tanks removed before compliance dates receive no reduction for being unregistered.
Certified UST Installer: Yes No N/A X Installation Date(s): Contractor Cert#
Applicable after 7/9/90.
Certified UST Remover: Yes No N/A X Removal Date(s): Contractor Cert #
Applicable after 7/9/90.
Corrosion Protection: Tanks: Yes X No N/A Piping: Yes No X N/A X
Applicable for steel piping/steel USTs installed after 6/1/86. Steel piping/steel USTs installed before 6/1/86 require corrosion protection no later than 12/22/98. Heating oil piping/heating oil USTs installed before 6/1/86 don't ever require corrosion protection.
****AST Secondary Containment: Yes No N/A**
Applicable after 1964 for ASTs > 1,100 gallons or any AST within 500' of surface water.

FEDERAL TANKS ADEQUATE INADEQUATE

Prior Removal Notice: Yes Number of Days No N/A X
Applicable after 1/1/91; heating oil UST's > 1,100 gallons after 8/1/92.
Spill/Overfill Protection: Yes X No N/A
Applicable for USTs installed after 12/22/88. USTs installed before 12/22/88 require spill and overfill protection by 12/22/98.
Leak Detection:
Tanks: Yes X No N/A
If tank was installed:
before 1965 or unknown Then the leak detection deadline is: 12/22/89
1965-1969 12/22/90
1970-1974 12/22/91
1975-1979 12/22/92
1980-12/22/88 12/22/93
Tanks installed after 12/22/88 should have leak detection at installation.
Piping: Yes X No Applicable for all piping.

Completed by: Kristi M Davern Date: 3/1/94
(9/23/93)