

Petroleum Tank Release Compliance Checklist

SITE NAME:

Wells Construction Products Co.

LEAK#000

6378

USE THE FOLLOWING GUIDELINES TO DETERMINE IF THE LEAKING TANK IS IN COMPLIANCE

UNREGULATED TANKS.....are ASTs/USTs 110 gallons or less, OR heating oil ASTs/USTs 1,100 gallons or less with product consumed on the premises, OR farm/residential ASTs/USTs 1,100 gallons or less containing motor fuel not for resale.

STATE REGULATED TANKS.....are heating oil USTs with a capacity more than 1,100 gallons.

FEDERALLY REGULATED TANKS.....are all USTs not specified above.

ABOVEGROUND TANKS.....are unregulated if they meet the same criteria as "Unregulated Tanks". If ASTs are regulated, use items marked with "**".

UNREGULATED TANKS, STATE TANKS, FEDERAL TANKS

ADEQUATE

INADEQUATE

**Release Notification: Date release discovered: MPCA 6/4/93 Petro App 6/4/93
Date release reported: MPCA 6/4/93 Petro App 6/4/93
Was there environmental damage due to delay? Yes _____ No

**Cooperation/Due Care Issue: Yes _____ No

Comments: _____

STATE TANKS, FEDERAL TANKS

ADEQUATE

INADEQUATE

**Tank Registration: AST/UST number: 6684 Registration Date: 2/25/86
Regulated USTs should be registered by 12/1/87. Regulated ASTs should be registered by 1/1/91.
Unregistered tanks removed before compliance dates receive no reduction for being unregistered.

Tank status current: Yes No _____

Certified UST Installer: Yes _____ No _____ N/A Installation Date(s): 1/79/84 Contractor Cert# _____
Applicable after 7/9/90.

Certified UST Remover: Yes No _____ N/A _____ Removal Date(s): 6/3/93 Contractor Cert # 092
Applicable after 7/9/90.

Corrosion Protection: Tanks: Yes _____ No _____ N/A Piping: Yes _____ No _____ N/A
Applicable for steel piping/steel USTs installed after 6/1/86. Steel piping/steel USTs installed before 6/1/86 require corrosion protection no later than 12/22/98. Heating oil piping/heating oil USTs installed before 6/1/86 don't ever require corrosion protection.

**AST Secondary Containment: Yes _____ No _____ N/A
Applicable after 1964 for ASTs > 1,100 gallons or any AST within 500' of surface water.

Prior Removal Notice: Yes Date of Notice 3/11/93 No _____ N/A _____
Applicable after 1/1/91. Applicable for heating oil USTs > 1,100 gallons after 8/1/92.

FEDERAL TANKS

ADEQUATE

INADEQUATE

Spill/Overfill Protection: Yes _____ No _____ N/A
Applicable for USTs installed after 12/22/88. USTs installed before 12/22/88 require spill and overfill protection by 12/22/98.

Leak Detection:

Tanks: Yes No _____ N/A _____

If tank was installed: Then the leak detection deadline is:

before 1965 or unknown	12/22/89
1965-1969	12/22/90
1970-1974	12/22/91
1975-1979	12/22/92
1980-12/22/88	12/22/93

Tanks installed after 12/22/88 should have leak detection at installation.

Piping: Yes No _____ N/A _____ Applicable for pressurized piping installed after 12/22/88.
Pressurized piping installed before 12/22/88 must have leak detection by 12/22/90.

Completed by: Kriste M Davenport
(5/3/94)

Date: 8/19/94

from data base