

5850

post
image



MINNESOTA PETROLEUM MARKETERS ASSOCIATION

3244 RICE STREET
ST. PAUL, MN 55126-3047
651/484-7227
800/864-3813
FAX 651/484-9189

RECEIVED

JUN 7 2003

MPCA - Brainerd
Baxter, MN

OFFICERS

BOB KROGMAN
Executive Director

STEVE DAHL
President

ALAN STAPLES
Vice-President

ODD JOHNSON
Treasurer

DWAYNE HOHN
Secretary

DIRECTORS

Jim Curtis

Milt Latvala

Bob Carlson

Kevin Beck

Tim Orton

Rick Gappa

Glenn Winter

Wade Carlson

Bruce Kath

Domenic Losurdo

Ron Dehn

John Dvorak

Randy Dooley

Kevin Devereaux

Dewayne Hage

Clif Gipp

Terry Thronson

Tim Yocum

June 2003

Here is your SIR Evaluation for the month of May 2003.

Please note the monthly monitoring results.

All tank and lines show tight.

Make sure these become part of your permanent leak detection file.

If you have any questions, please don't hesitate to contact us.

Holly Werner
Associate Director

Enclosure

Brian -
Here is your report. It looks good.
Next month everything should be much
more timely.
Thanks
Holly

Management Document

Yearly Summary
PRIBYL INC.
May, 2003

Tank	Product	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Jan	Feb	Mar	Apr	May
PRIBYL INC. - 29 WEST MAIN - Crosby - MN 9220-2	Premium												P

Legend: P - Pass *F* - Fail Inj - Inconclusive ND - No Data Submitted NA - Not Analyzed

Printed: July 01, 2003

Page: 1



VEEDER-ROOT



Veeder-Root Services Company dba/USTMAN
 12265 W. Bayard Ave. * Suite 300 * Lakewood, CO 80228
 1-800-253-8054 * (303) 986-8011 * FAX (303) 986-8227

Monthly Recap Report with Statistics PRIBYL INC. May, 2003

Status: Pass

Tank: 9220-2 Station: PRIBYL INC. Address: 29 WEST MAIN CROSBY, MN 56441				Product: Premium Capacity: 8000		
Date	Closing Stock	Sales	Deliveries	Calculated Inventory	Over/Short	Cummulative O/S
	Gallons	Gallons	Gallons	Gallons	+/- Gallons	Gallons
05/01/2003	769	73	0	0	0	0
05/02/2003	750	31	0	738	12	12
05/03/2003	695	64	0	686	9	21
05/04/2003	640	43	0	652	-12	9
05/05/2003	1589	39	1001	1602	-13	-4
05/06/2003	1555	25	0	1564	-9	-13
05/07/2003	1544	23	0	1532	12	-1
05/08/2003	1487	42	0	1502	-15	-16
05/09/2003	1354	144	0	1343	11	-5
05/10/2003	1278	76	0	1278	0	-5
05/11/2003	1236	22	0	1256	0	-5
05/12/2003	1235	39	0	1227	8	3
05/13/2003	1171	56	0	1179	-8	-5
05/14/2003	1149	26	0	1145	4	-1
05/15/2003	1097	57	0	1092	5	4
05/16/2003	1045	50	0	1047	-2	2
05/17/2003	944	102	0	943	1	3
05/18/2003	875	73	0	871	4	7
05/19/2003	817	57	0	818	-1	6
05/20/2003	769	53	0	764	5	11
05/21/2003	1704	43	1000	1726	-22	-11
05/22/2003	1670	38	0	1666	4	-7
05/23/2003	1589	76	0	1592	-3	-10
05/24/2003	1510	75	0	1514	-4	-14
05/25/2003	1476	37	0	1473	3	-11
05/26/2003	1454	50	0	1426	28	17
05/27/2003	1365	70	0	1384	-19	-2
05/29/2003	1245	79	0	1286	-41	-43
05/30/2003	1139	113	0	1132	7	-36
05/31/2003	1036	87	0	1052	4	-32
Totals:		1755	2001			
Additional Information:						
Highest:	1704	144	1001		28	
Lowest:	640	22	1000		-41	
Average:	1208	59	1001		-1.1	
SIR Calculations:						
Calculated Leak Rate: -0.04				Data Quality: Good		



BATCH SCANNING SHEET

updated 3/23/2012

8/13

Scan Queue* (circle one):

AST/UST Scan

Air Quality**

C&E - CR-APT. - Scan

C&E - ER Scan Queue

CSW/ISW/MS4 Scan

Generic

Hazardous Waste

Major AST

Major AST Permit Application

Permitting - Scan

~~Remediation/Leak Sites~~

Rulemaking

*No batch sheet needed for: Bar Code Scanning, DMRs, or Grants

** Air Quality - Only Criteria & Mercury Emissions Inventories

Status:

Prepped by:

Andra Laska

Date:

8/22/13

Prep QC'd by:

Date:

Scanned by:

Tim Sorensen

Date:

9/15/13

Scan QC'd by:

Date:

Batch Number:

File Type (for archiving):

~~XXXX~~ *Mixed Tanks*

Comments:

*Prep, Scan & Index
Archive after Scan*