



28 January, 2003

CROSBY CITGO
 ID: 5850

Service Station
Type of Site: Underground Only

Address: 29 W MAIN - PO BOX 206
 CROSBY, MN 56441
 County: Crow Wing
 Site Phone: 218-546-5902

Region: 2
 AST Registration:
 UST Registration: 5/4/86

***** OWNER INFORMATION *****

Owner Name: BRIAN PRIBYL
 Owner ID: 175535
 Address: 29 W MAIN ST
 CROSBY, MN 56441

***** TANK INFORMATION SUMMARY *****

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
001	U	Reconditioned	Gasoline	10,000	05/01/1986		05/04/1986
002	U	Reconditioned	Gasoline	8,000	05/01/1986		05/04/1986
003	U	Closed In-Place	Gasoline	4,000	01/01/1975		05/04/1986
004	U	Closed In-Place	Gasoline	2,000	12/01/1975		05/04/1986
005	U	Removed	Fuel Oil	1,000	01/01/1900	08/29/1991	05/04/1986

Removal Contractor: INDEPENDENT PETROLEUM SERVICE INC

***** 001 - COMMON TANK INFORMATION *****

Our Tank Nbr: 001 U	Client Tank Nbr: 001
Dispenser Type: Suction	Total Capacity: 10,000
Tank Const Mtl: STI-P3	Stored Product: Gasoline
Used For Heating?: U	Tank Status: Reconditioned
Tank Disposal Company:	2nd Cont Tank:
Tank Cath Prot:	Pipe Cath Prot: Not Needed
Pipe Material: Other	Piping Material Desc: ATT POLY PIPE
HW Generator ID:	Product Replaced Date:
Tank Registration Date: 05/04/1986	Unreg Tank Report Date:

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments: 1	Compart Capacity: 10000
Compart Number: 1	Compart Stored Desc: GASOLINE
Compart Stored Prod: Gasoline	
Compart Other Desc:	

--- Overfill Information ---

Overfill Prot Alarm: Y	Overfill Prot Autoshut:
Overfill Prot Ballfloat:	Overfill Prot Manual:
Overfill Prot No Info:	Overfill Prot None:
Overfill Prot Type Unk:	

--- Tank Release Protection ---

Daily Stick: N	Auto Line Leak Detection: Y
Tightness Test: N	Annual Tightness Test: N
Manual Gauging: N	Vapor Monitoring: N
Auto Gauging: Y	Groundwater Monitor: N
Soil Vapor Monitor: N	Interstit Monitor: Y
Groundwater Monitor: N	3 Year Tightness Test: N
Interstit Monitor: N	European Suction: N
SIR Approve Date:	SIR Approve Date:
SIR Vendor Nbr: 0	SIR Vendor Nbr: 0
Other Desc:	
Other Flag: N	

--- Piping Release Protection ---



CROSBY CITCO

Service Station

Site ID: 5850

Type of Site: Underground Only

***** 002 - COMMON TANK INFORMATION *****

Our Tank Nbr: 002 U
Dispenser Type: Suction
Tank Const Mtl: STI-P3
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Other
HW Generator ID:
Tank Registration Date: 05/04/1986

Client Tank Nbr: 002
Total Capacity: 8,000
Stored Product: Gasoline
Tank Status: Reconditioned
2nd Cont Tank:
Pipe Cath Prot: Not Needed
Piping Material Desc: ATT POLY PIPE
Product Replaced Date:
Unreg Tank Report Date:

----- 002 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Gasoline
Compart Other Desc:

Compart Capacity: 8000
Compart Stored Desc: GASOLINE

--- Overfill Information ---

Overfill Prot Alarm: Y
Overfill Prot Ballfloat:
Overfill Prot No Info:
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: N
Tightness Test: N
Manual Gauging: N
Auto Gauging: Y
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: Y
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: Y
3 Year Tightness Test: N
European Suction: N
SIR Approve Date:
SIR Vendor Nbr: 0

***** 003 - COMMON TANK INFORMATION *****

Our Tank Nbr: 003 U
Dispenser Type: Suction
Tank Const Mtl: Bare/Paint/Asph Coat Steel
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Galvanized steel
HW Generator ID:
Tank Registration Date: 05/04/1986

Client Tank Nbr: 003
Total Capacity: 4,000
Stored Product: Gasoline
Tank Status: Closed In-Place
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- 003 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Gasoline
Compart Other Desc:

Compart Capacity: 4000
Compart Stored Desc: GASOLINE

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:



CROSBY CITCO

SID: 5850

Service Station

Type of Site: Underground Only

Overfill Prot Type Unk:
 --- Tank Release Protection ---
 Daily Stick: Y
 Tightness Test: Y
 Manual Gauging: N
 Auto Gauging: N
 Soil Vapor Monitor: N
 Groundwater Monitor: N
 Interstit Monitor: N
 SIR Approve Date:
 SIR Vendor Nbr: 0
 Other Desc:
 Other Flag: N

--- Piping Release Protection ---
 Auto Line Leak Detection: N
 Annual Tightness Test: N
 Vapor Monitoring: N
 Groundwater Monitor: N
 Interstit Monitor: N
 3 Year Tightness Test: N
 European Suction: Y
 SIR Approve Date:
 SIR Vendor Nbr: 0

***** 004 - COMMON TANK INFORMATION *****

Our Tank Nbr: 004 U
 Dispenser Type: Suction
 Tank Const Mtl: Bare/Paint/Asph Coat Steel
 Used For Heating?: U
 Tank Disposal Company:
 Tank Cath Prot:
 Pipe Material: Galvanized steel
 HW Generator ID:
 Tank Registration Date: 05/04/1986

Client Tank Nbr: 004
 Total Capacity: 2,000
 Stored Product: Gasoline
 Tank Status: Closed In-Place
 2nd Cont Tank:
 Pipe Cath Prot: None
 Piping Material Desc:
 Product Replaced Date:
 Unreg Tank Report Date:

----- 004 - UST TANK INFORMATION -----

Tank Compartments: 1
 Compart Number: 1
 Compart Stored Prod: Gasoline
 Compart Other Desc:

Compart Capacity: 2000
 Compart Stored Desc: GASOLINE

--- Overfill Information ---
 Overfill Prot Alarm:
 Overfill Prot Ballfloat:
 Overfill Prot No Info: Y
 Overfill Prot Type Unk:

Overfill Prot Autoshut:
 Overfill Prot Manual:
 Overfill Prot None:

--- Tank Release Protection ---
 Daily Stick: Y
 Tightness Test: Y
 Manual Gauging: N
 Auto Gauging: N
 Soil Vapor Monitor: N
 Groundwater Monitor: N
 Interstit Monitor: N
 SIR Approve Date:
 SIR Vendor Nbr: 0
 Other Desc:
 Other Flag: N

--- Piping Release Protection ---
 Auto Line Leak Detection: N
 Annual Tightness Test: N
 Vapor Monitoring: N
 Groundwater Monitor: N
 Interstit Monitor: N
 3 Year Tightness Test: N
 European Suction: Y
 SIR Approve Date:
 SIR Vendor Nbr: 0

***** 005 - COMMON TANK INFORMATION *****

Our Tank Nbr: 005 U
 Dispenser Type: Suction
 Tank Const Mtl: Bare/Paint/Asph Coat Steel
 Used For Heating?: Y
 Tank Disposal Company:
 Tank Cath Prot:

Client Tank Nbr: 005
 Total Capacity: 1,000
 Stored Product: Fuel Oil
 Tank Status: Removed
 2nd Cont Tank:
 Pipe Cath Prot: None



CROSBY CITCO

Service Station

Site ID: 5850

Type of Site: Underground Only

Pipe Material: Steel/Iron
HW Generator ID:
Tank Registration Date: 05/04/1986

Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- 005 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Fuel Oil
Compart Other Desc:

Compart Capacity: 1000
Compart Stored Desc: FUEL OIL

---- Overfill Information ----

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

---- Tank Release Protection ----

Daily Stick: N
Tightness Test: N
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

---- Piping Release Protection ----

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CORRESPONDENCE *****

Number: 1
Company:
Type: Registration Form

Date: 01/01/1901
Person At Co:
PCS:

Signature: BRIAN PRIBYL (NEW OWNER)

Title : NEW OWNER

Date Form Received: 2/6/92

The following comment was entered on: 05/04/86

#4 TANKS 003 & 004 INSTALLED APPROX 10-11 YEARS; #8 UNKNOWN; #11 PIPING COATED WITH ASPHALT; PLAN TO USE TANK 003 & 004 AGAIN WITH DIFFERENT CONTENTS (DIESEL); SECTION C LEGAL DESC - SEC 29W, IN CITY OF CROSBY LOTS 1 & 2, BLOCK 9

TANKS 003-005 REMOVED PER FORM RECEIVED 9/9/91 (TANK 005 NOTIFICATION AND REMOVAL RECEIVED AT SAME)

CHANGE OF OWNERSHIP AS OF 2/1/92 PREVIOUS OWNER: RON MAY/PO BOX 43/DEER WOOD MN 56444 PER FORM RECEIVED ON 2/6/92

Number: 2
Company: ROLLIES
Type: Phone Call

Date: 04/23/1996
Person At Co: JIM TENHOFF
PCS:

PER CALL FROM JIM TENHOFF OF ROLLIES. PROJECT WAS NOT CALLED IN. STAN WAS ON SITE. WARNING CITATION WAS GIVE TO ROLLIES FOR NOT NOTIFYING PCA OF THE TEN DAY NOTICE.-LH



CROSBY CITCO

ID: 5850

Service Station

Type of Site: Underground Only

Number: 3

Company: ROLLIES SALES

Type: Meeting

Date: 04/30/1996

Person At Co: JIM TENHOFF

PCS:

I RECEIVED A CALL FROM JIM TENHOFF WHILE I WAS IN WALKER FOR AN INSTALL INSP. STATING THAT HE WAS ON HIS WAY OVER TO CROSBY CITCO. APPARENTLY COMMUNICATION GOT MESSED UP AND THE 10-DAY NOTICE WAS NOT RECEIVED. HE WAS ASKING TO GO AHEAD ON THE PIPING—DOUBLE WALL FLEXABLE. I SAID I WOULD MEET HIM AT THE SITE AT 1:30PM. AND WE COULD TALK.

WHEN I ARRIVED JIM WAS THE ONLY ROLLIES REP. SINCE ALL THEIR CREW WAS BUSY AND WOULD BE BACK THE NEXT DAY TO COMPLETE THE PIPING AND CHANGE OVER. APPARENTLY, THE CERTIFIED STAFF WERE THERE ON 4-23-96 TO DISCONNECT THE PIPING. SINCE JIM T. IS NOT CERTIFIED HE WAS THERE TO WORK W/ THE ON SITE GEN. CONTRACTOR AND ELECTRICIAN AND REMOVE CONCRETE FOR THE NEXT DAY. TALKED W/ THE OWNER AND EXPLAINED THE 10-DAY NOTICE AS WELL. COMPLETED A NOTICE FOR CORRECTIVE ACTION RE; THE LACK OF PROPER 10-DAY NOTIFICATION. WILL AWAIT RESPONSE FROM ROLLIES ON THE NCA.....STAN

Number: 4

Company: CROSBY CITCO

Type: Registration Form

Date: 01/02/1997

Person At Co: BRIAN PRIBYL

PCS:

Signature: BRIAN PRIBYL

Title: OWNER

Form Received: 12/9/96 (NOTIFICATION FOR TANKS 006-007)

ALSO REMOVAL NOTIFICATION GIVEN BY ROLLIES TO ALSO REMOVE 2 TANKS REMOVAL NOTIFICATION FORM AND NOTIFICATION FORM FOR TANKS 006-007 SENT TO ROLLIES FOR CONTRACTOR SIGNATURE- ALSO NEEDED IS SIZE, PRODUCT IN TANKS AND LEAK DETECTION INFO (NOT PROVIDED ON FORM)

Number: 5

Company: CROSBY CITCO

Type: Registration Form

Date: 11/13/1997

Person At Co: BRIAN PRIBYL

PCS:

10/27/97 STAN K. VISITED SITE AND LEARNED TANK 004 FILLED IN PLACE 1993

Number: 6

Company: CROSBY CITGO

Type: Meeting

Date: 01/14/1998

Person At Co: BRIAN PRIBYL

PCS:

MET W/ BRIAN PRIBYL ON 10-27-97. BOUGHT SITE IN 1992. TANK 004 FILLED IN PLACE IN 1993. TANKS 001 & 002 UPGRADED BY ROLLIES SALES W/ DOUBLE WALL PIPING AND SPILL & OVERFILL—MARCH OF 1996.