



27 January, 2003

CROSBY ONE STOP
Site ID: 6581

Service Station
Type of Site: Underground Only

Address: 2 E MAIN
 CROSBY, MN 56441
 County: Crow Wing
 Site Phone: 320-546-5565

Region: 2
 AST Registration:
 UST Registration: 5/6/86

***** OWNER INFORMATION *****

Owner Name: MART BJERKNES
 Owner ID: 186892
 Address: HC 61-B0X 329E
 DEERWOOD, MN 56444

***** TANK INFORMATION SUMMARY *****

Nbr	A/U	Status	Substance Stored	Capacity	Installed	Removed	Reg Date
001	U	Removed	Alcohol Blend	15,000	10/02/1991		07/28/1993
Install Contractor: INDEPENDENT PETROLEUM SERVICE INC							
002	U	Removed	Used Or Waste Oil	500			
CS1	U	Removed	Gasoline	8,000	01/01/1970	09/01/1992	05/06/1986
CS2	U	Removed	Gasoline	8,000	01/01/1970	09/01/1992	05/06/1986
CS3	U	Removed	Gasoline	2,000	01/01/1966	09/01/1992	05/06/1986
CS4	U	Removed	Gasoline	2,000	01/01/1966	09/01/1992	05/06/1986
CS5	U	Removed	Diesel	4,000	01/01/1970	09/01/1992	05/06/1986
CS6	U	Active	Alcohol Blend	4,000	09/01/1992		04/06/1998
CS7	U	Active	Gasoline	8,000	09/01/1992		04/06/1998
	U	Active	Diesel	4,000	09/01/1992		04/06/1998

***** 001 - COMMON TANK INFORMATION *****

Our Tank Nbr: 001 U	Client Tank Nbr: 001
Dispenser Type: Suction	Total Capacity: 15,000
Tank Const Mtl: STI-P3	Stored Product: Alcohol Blend
Used For Heating?: N	Tank Status: Removed
Tank Disposal Company:	2nd Cont Tank:
Tank Cath Prot:	Pipe Cath Prot: Anode
Pipe Material: Coated Steel	Piping Material Desc:
HW Generator ID:	Product Replaced Date:
Tank Registration Date: 07/28/1993	Unreg Tank Report Date:

----- 001 - UST TANK INFORMATION -----

# of Tank Compartments: 1	Compartment Capacity: 15000
Compartment Number: 1	Compartment Stored Desc: ALCOHOL BLEND
Compartment Stored Prod: Alcohol Blend	
Compartment Other Desc:	

--- Overfill Information ---

Overfill Prot Alarm:	Overfill Prot Autosht:
Overfill Prot Ballfloat: Y	Overfill Prot Manual:
Overfill Prot No Info:	Overfill Prot None:
Overfill Prot Type Unk:	

--- Tank Release Protection ---

Daily Stick: Y	Auto Line Leak Detection: N
Tightness Test: N	Annual Tightness Test: N
Manual Gauging: Y	Vapor Monitoring: N
Auto Gauging: Y	Groundwater Monitor: N
Soil Vapor Monitor: N	Interstit Monitor: N
Groundwater Monitor: N	3 Year Tightness Test: N

--- Piping Release Protection ---



CROSBY ONE STOP

Service Station

Site ID: 6581

Type of Site: Underground Only

Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

European Suction: N
SIR Approve Date:
SIR Vendor Nbr: 0

***** 002 - COMMON TANK INFORMATION *****

Our Tank Nbr: 002 U
Dispenser Type: Gravity
Tank Const Mtl: Bare/Paint/Asph Coat Steel
Used For Heating?: N
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Steel/Iron
HW Generator ID:
Tank Registration Date:

Client Tank Nbr: 002
Total Capacity: 500
Stored Product: Used Or Waste Oil
Tank Status: Removed
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date: 09/20/1991

----- 002 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Used Or Waste Oil
Compart Other Desc:

Compart Capacity: 500
Compart Stored Desc: WASTE OIL

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: N
Tightness Test: N
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: N
SIR Approve Date:
SIR Vendor Nbr: 0

***** CS1 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS1 U
Dispenser Type: Suction
Tank Const Mtl: Bare/Paint/Asph Coat Steel
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Galvanized steel
HW Generator ID:
Tank Registration Date: 05/06/1986

Client Tank Nbr: CS1
Total Capacity: 8,000
Stored Product: Gasoline
Tank Status: Removed
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- CS1 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Gasoline
Compart Other Desc:

Compart Capacity: 8000
Compart Stored Desc: GASOLINE



OSBY ONE STOP
Site ID: 6581

Service Station
Type of Site: Underground Only

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: Y
Tightness Test: Y
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CS2 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS2 U
Dispenser Type: Suction
Tank Const Mt: Bare/Paint/Asph Coat Steel
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Galvanized steel
HW Generator ID:
Tank Registration Date: 05/06/1986

Client Tank Nbr: CS2
Total Capacity: 8,000
Stored Product: Gasoline
Tank Status: Removed
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- CS2 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compartment Number: 1
Compartment Stored Prod: Gasoline
Compartment Other Desc:

Compartment Capacity: 8000
Compartment Stored Desc: GASOLINE

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: Y
Tightness Test: Y
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CS3 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS3 U

Client Tank Nbr: CS3



CROSBY ONE STOP

Service Station

Site ID: 6581

Type of Site: Underground Only

Dispenser Type: Suction
Tank Const Mtl: Bare/Paint/Asph Coat Steel
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Galvanized steel
HW Generator ID:
Tank Registration Date: 05/06/1986

Total Capacity: 2,000
Stored Product: Gasoline
Tank Status: Removed
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- CS3 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Gasoline
Compart Other Desc:

Compart Capacity: 2000
Compart Stored Desc: GASOLINE

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: Y
Tightness Test: Y
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CS4 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS4 U
Dispenser Type: Suction
Tank Const Mtl: Bare/Paint/Asph Coat Steel
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Galvanized steel
HW Generator ID:
Tank Registration Date: 05/06/1986

Client Tank Nbr: CS4
Total Capacity: 2,000
Stored Product: Gasoline
Tank Status: Removed
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- CS4 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compart Number: 1
Compart Stored Prod: Gasoline
Compart Other Desc:

Compart Capacity: 2000
Compart Stored Desc: GASOLINE

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

--- Piping Release Protection ---



OSBY ONE STOP
Site ID: 6581

Service Station
Type of Site: Underground Only

Daily Stick: Y
Tightness Test: Y
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CS5 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS5 U
Dispenser Type: Suction
Tank Const Mtl: Bare/Paint/Asph Coat Steel
Used For Heating?: U
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Galvanized steel
HW Generator ID:
Tank Registration Date: 05/06/1986

Client Tank Nbr: CS5
Total Capacity: 4,000
Stored Product: Diesel
Tank Status: Removed
2nd Cont Tank:
Pipe Cath Prot: None
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- CS5 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compartment Number: 1
Compartment Stored Prod: Diesel
Compartment Other Desc:

Compartment Capacity: 4000
Compartment Stored Desc: DIESEL

--- Overfill Information ---

Overfill Prot Alarm:
Overfill Prot Ballfloat:
Overfill Prot No Info: Y
Overfill Prot Type Unk:

Overfill Prot Autos shut:
Overfill Prot Manual:
Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: Y
Tightness Test: Y
Manual Gauging: N
Auto Gauging: N
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CS6 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS6 U
Dispenser Type: Suction
Tank Const Mtl: STI-P3
Used For Heating?: N
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Coated Steel
HW Generator ID:

Client Tank Nbr: CS6
Total Capacity: 4,000
Stored Product: Alcohol Blend
Tank Status: Active
2nd Cont Tank:
Pipe Cath Prot: Anode
Piping Material Desc:
Product Replaced Date:



CROSBY ONE STOP

Service Station

Site ID: 6581

Type of Site: Underground Only

Tank Registration Date: 04/06/1998

Unreg Tank Report Date:

----- CS6 - UST TANK INFORMATION -----

of Tank Compartments: 1

Compart Number: 1

Compart Stored Prod: Alcohol Blend

Compart Other Desc:

Compart Capacity: 4000

Compart Stored Desc: ALCOHOL BLEND

--- Overfill Information ---

Overfill Prot Alarm:

Overfill Prot Ballfloat:

Overfill Prot No Info:

Overfill Prot Type Unk:

Overfill Prot Autoshut: Y

Overfill Prot Manual:

Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: N

Tightness Test: N

Manual Gauging: N

Auto Gauging: Y

Soil Vapor Monitor: N

Groundwater Monitor: N

Interstit Monitor: N

SIR Approve Date:

SIR Vendor Nbr: 0

Other Desc:

Other Flag: N

--- Piping Release Protection ---

Auto Line Leak Detection: N

Annual Tightness Test: N

Vapor Monitoring: N

Groundwater Monitor: N

Interstit Monitor: N

3 Year Tightness Test: N

European Suction: Y

SIR Approve Date:

SIR Vendor Nbr: 0

***** CS7 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS7 U

Dispenser Type: Suction

Tank Const Mtl: STI-P3

Used For Heating?: N

Tank Disposal Company:

Tank Cath Prot:

Pipe Material: Coated Steel

HW Generator ID:

Tank Registration Date: 04/06/1998

Client Tank Nbr: CS7

Total Capacity: 8,000

Stored Product: Gasoline

Tank Status: Active

2nd Cont Tank:

Pipe Cath Prot: Anode

Piping Material Desc:

Product Replaced Date:

Unreg Tank Report Date:

----- CS7 - UST TANK INFORMATION -----

of Tank Compartments: 1

Compart Number: 1

Compart Stored Prod: Gasoline

Compart Other Desc:

Compart Capacity: 8000

Compart Stored Desc: GASOLINE

--- Overfill Information ---

Overfill Prot Alarm:

Overfill Prot Ballfloat: Y

Overfill Prot No Info:

Overfill Prot Type Unk:

Overfill Prot Autoshut:

Overfill Prot Manual:

Overfill Prot None:

--- Tank Release Protection ---

Daily Stick: N

Tightness Test: N

Manual Gauging: N

Auto Gauging: Y

Soil Vapor Monitor: N

Groundwater Monitor: N

Interstit Monitor: N

--- Piping Release Protection ---

Auto Line Leak Detection: N

Annual Tightness Test: N

Vapor Monitoring: N

Groundwater Monitor: N

Interstit Monitor: N

3 Year Tightness Test: N

European Suction: Y



CROSBY ONE STOP
Site ID: 6581

Service Station
Type of Site: Underground Only

SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

SIR Approve Date:
SIR Vendor Nbr: 0

***** CS8 - COMMON TANK INFORMATION *****

Our Tank Nbr: CS8 U
Dispenser Type: Suction
Tank Const Mtl: STI-P3
Used For Heating?: N
Tank Disposal Company:
Tank Cath Prot:
Pipe Material: Coated Steel
HW Generator ID:
Tank Registration Date: 04/06/1998

Client Tank Nbr: CS8
Total Capacity: 4,000
Stored Product: Diesel
Tank Status: Active
2nd Cont Tank:
Pipe Cath Prot: Anode
Piping Material Desc:
Product Replaced Date:
Unreg Tank Report Date:

----- CS8 - UST TANK INFORMATION -----

of Tank Compartments: 1
Compartment Number: 1
Compartment Stored Prod: Diesel
Compartment Other Desc:

Compartment Capacity: 4000
Compartment Stored Desc: DIESEL

---- Overfill Information ----

Overfill Prot Alarm:
Overfill Prot Ballfloat: Y
Overfill Prot No Info:
Overfill Prot Type Unk:

Overfill Prot Autoshut:
Overfill Prot Manual:
Overfill Prot None:

---- Tank Release Protection ----

Daily Stick: N
Tightness Test: N
Manual Gauging: N
Auto Gauging: Y
Soil Vapor Monitor: N
Groundwater Monitor: N
Interstit Monitor: N
SIR Approve Date:
SIR Vendor Nbr: 0
Other Desc:
Other Flag: N

---- Piping Release Protection ----

Auto Line Leak Detection: N
Annual Tightness Test: N
Vapor Monitoring: N
Groundwater Monitor: N
Interstit Monitor: N
3 Year Tightness Test: N
European Suction: Y
SIR Approve Date:
SIR Vendor Nbr: 0

***** CORRESPONDENCE *****

Number: 1
Company:
Type: Registration Form

Date: 01/01/1901
Person At Co:
PCS:

The following comment was entered on: 05/06/86
SECTION C LEGAL DESC - LOTS IN BLOCK 6, LAKE PARK, DIV OF CROSBY

Number: 2
Company: CROSBY 1-STOP
Type: Meeting

Date: 04/05/1998
Person At Co: MARTY BJERKNES
PCS:

ON SITE ON 4-3-98 TALKED W/ DIANE BJERKNES; AND SHE INDICATED THEY BOUGHT SITE FROM ROBERT MACK OF THE EZ STOP SOTRES IN JULY OF 1995. THIS SITE WAS ORIGINALLY OWNER BY BLOMBERG OIL CO OF AITKIN MN. BLOMBETRG SOLD TO

**CROSBY ONE STOP**

Service Station

Site ID: 6581

Type of Site: Underground Only

EZ-STOP IN 1991. MARTY BJERKNES AND DUANNE WEITNAUER BOUGHT FROM EZ-STOP IN JULY OF 1995.

AT THIS TIME IT APPEARS THAT THE SITE WAS UPGRADED AS THE TANKS CS1 --CS5 WERE REMOVED AND 3 STIPS TANKS WERE INSTALLED.

WILL BE MEETING W/ MARTY BJERKNES ON 4-6-98 TO COMPLETE NOTIFICATION FORM AND STAUS OF EXISTING SITE UPGRADE.....

Number: 3

Date: 04/06/1998

Company: CROSBY-1-STOP

Person At Co: MARTY BJERKNES

Type: Meeting

PCS:

MET W/OWNER MARTY BJERKNES ON 4-6-98. SITE WAS UPGRADED IN FALL OF 1992 BY BOB MACK OF EZ-STOP BEFORE SELLING TO MARTY IN JULY OF 1995

THE INSTALL WAS DONE BY INDPT. PETRO HOWEVER NO NOTIFICATION FORM WAS COMPLETED.(WE COMPLETED ON ONSITE TODAY)

TANK SITE IS UPGRADED WITH SPILL/OVERFILL AND C.P.(STIP3 TANKS.

ATG IS ALSO BEING USED; HOWEVER NEEDS TO BE CALIBRATED AS IT IS NOT GOING INTO A LEAK MODE.

ALSO COMPLETED CORROSION TESTS ON TANKS AND THE TWO GAS TANKS WERE FINE HOWEVER THE DIESEL WAS ONLY -.65 AND WILL NEED TO BE CHECKEK OUT.

Number: 4

Date: 10/27/1998

Company: CROSBY ONE ST

Person At Co: MARTY BJECKWOD

Type: Registration Form

PCS:

Signature: MARTY BJECKWEB

Title : OWNER

Date Form Received: 4/6/98 (NOTIFICATION FOR TANKS C56-C57-C58)

3/30/99

STAN K. LEARNED SITE #17713 IS SAME SITE AS #6581- #17713 TO BE DELETED.

TANKS 001 AND 001 HAVE BEEN REMOVED-

TANKS REGISTERED 7/28/93 PER FORM SUBMITTED BY DAVID MILLER, DIR OF OPER.

#17889 TO BE DELETED- SAME TANKS AS 6581