

PETROLEUM TANK RELEASE COMPLIANCE CHECKLIST

SITE NAME International Plaza LEAK0000 4981

TANK SIZE	PRODUCT TYPE	PRODUCT USE	DATE INSTALLED	DATE REMOVED
<u>30 gal.</u>	<u>hydraulic</u>	<u>elevator</u>		

A

USE THE FOLLOWING CRITERIA TO DETERMINE IF THE LEAKING TANK IS IN COMPLIANCE:

- USTs <sup>AST</sup> 110 gallons or less, OR heating oil USTs 1,100 gallons or less consumed on the premises OR farm/residential USTs 1,100 gallons or less containing motor fuel not for resale  criteria I
- Heating oil USTs > 1,100 gallons \_\_\_ criteria I, II
- All USTs > 110 gallons NOT specified above \_\_\_ criteria I, II, III
- ASTs > 110 gallons \_\_\_ \*\* only ~~criteria I~~

CRITERIA I

- \*\*Release Notification: Violation OK  
 Date release discovered: (MPCA) 10/17/91 (PetroApp) 10/17/91  
 Date release reported: (MPCA) 10/17/91 (PetroApp) 10/17/91  
 Was there additional environmental damage due to reporting delay? Yes \_\_\_ No \_\_\_
- \*\*Cooperation/Due Care Issue: Violation OK  
 (i.e. land application prior to approval, release during tank removal, etc.)

Comments: \_\_\_\_\_

CRITERIA II

- \*\*Tank Registration: Violation \_\_\_\_\_  
 (AST) or UST number: \_\_\_\_\_ Compliance dates: UST before 12/1/87  
 Date registered: \_\_\_\_\_ AST before 1/1/91
- Certified UST remover/installer: Yes \_\_\_ No \_\_\_ N/A \_\_\_ Violation \_\_\_\_\_  
 (applicable after 7/9/90) Cert# \_\_\_\_\_
- Corrosion Protection: Yes \_\_\_ No \_\_\_ N/A \_\_\_ Violation \_\_\_\_\_  
 (applicable for USTs installed after 8/1/85; existing USTs require corrosion protection no later than December 1998.)

CRITERIA III

- Prior removal notice: Yes \_\_\_ No \_\_\_ N/A \_\_\_ Violation \_\_\_\_\_  
 (applicable after 01/01/91, also heating oil USTs > 1,100 gallons after 8/1/92)

(over)

Leak Detection: Yes  No  N/A  Violation   
(use following table to determine need for leak detection)  
tank installed... leak detection deadline

before 1965	Dec. 1989
1965 - 1969	Dec. 1990
1970 - 1974	Dec. 1991
1975 - 1979	Dec. 1992
1980 - Dec. 1988	Dec. 1993

(tanks installed after 12/22/88 should have leak detection at installation)

Spill/Overfill Prevention: Yes  No  N/A  Violation   
(applicable for USTs installed after 12/22/88; existing USTs require  
spill/overfill prevention no later than December 1998.)

\*\*AST Secondary Containment: Yes  No  N/A  Violation

Completed by: Donald K. Milley Date: 12/14/93

(03/30/93)