

QUICK MEMORANDUM FORM

MINNESOTA POLLUTION CONTROL AGENCY
520 Lafayette Road
St. Paul, Minnesota 55155
Telephone (612) 296-6300

Date:

TO:Tanks
FROM:Kevin Faus, MN.PCA
Tanks and Spills Section
Division of Hazardous Waste
(612) 297-8671

=====

SUBJECT:International Plaza, Bloomington

An elevator shaft in a parking lot at 7900 International Drive, Bloomington has lost about 50+ gallons of hydraulic oil down the shaft. Upon inspection it became apparent that the shaft is bottomless and that groundwater has come into the shaft from the bottom. The cylinder has been removed and as you look into the bore hole oil is seen foating on top of water.

Because of the above I believe this to be dealt more approprietly in the tanks unit as it may involve short term or long term cleanup and may involve petrofund.

A standard spill letter has been sent but not a tank standard letter. There has not been any investigation other than looking down the hole.

1mRegional Offices: Duluth, Brainerd, Detroit Lakes, Marshall, Rochester
Equal Opportunity Employer
copy 1-addressee copy 2-site file